

Business Sector Market Assessment and Baseline:

Commercial New Construction

Vol. 2 Appendices

Final Report



Prepared for the Vermont Department of Public Service

Madison, Wisconsin, October 5, 2009





| List of Ta | ables: | iii |
|------------|-------------------------------------|------|
| Append | ix A: General and Building Envelope | A-1 |
| A.1. | Facility Details | A-1 |
| | A.1.1. Premise Weighted Results | A-1 |
| A.2. | On-Site Generation | A-3 |
| | A.2.1. Square Foot Weighted Results | A-3 |
| | A.2.2. Premise Weighted Results | A-3 |
| A.3. | Maintenance | A-4 |
| | A.3.1. Square Foot Weighted Results | A-4 |
| | A.3.2. Premise Weighted Results | A-7 |
| A.4. | Building Envelope | A-9 |
| | A.4.1. Square Foot Weighted Results | A-9 |
| | A.4.2. Premise Weighted Results | A-13 |
| Append | ix B: Indoor Lighting | B-1 |
| B.1. | Types of Indoor Lighting | B-1 |
| | B.1.1. Square Foot Weighted Results | B-1 |
| | B.1.2. Premise Weighted Results | B-1 |
| B.2. | Lighting Densities | B-2 |
| B.3. | Square Foot Weighted Results | B-5 |
| | B.3.1. Usage | B-5 |
| | B.3.2. Ballast Types | B-9 |
| | B.3.3. Control Types | B-13 |
| B.4. | Premise Weighted Results | B-19 |
| | B.4.1. Usage | B-19 |
| | B.4.2. Ballast Types | B-23 |
| | B.4.3. Control Types | B-27 |
| B.5. | Energy Efficient Opportunities | B-33 |
| | B.5.1. Square Foot Weighted Results | B-33 |
| | B.5.2. Premise Weighted Results | B-40 |
| Append | ix C: Outdoor Lighting | C-1 |
| C.1. | Types of Outdoor Lighting | C-1 |
| | Usage | |
| C.3. | Control Types | C-3 |



| C.4. | Ballast Types | C-4 |
|---------|-------------------------------------------------|------|
| | Energy Efficiency Opportunities | |
| | C.5.1. Premise Weighted | |
| | C.5.2. Wattage Weighted | |
| Appendi | x D: Cooling | |
| | Cooling Types by Tonnage | |
| | Conditioned Square Foot Weighted Results | |
| | D.2.1. Equipment Types | |
| | D.2.2. Energy Efficiency Opportunities | |
| | D.2.3. Equipment Details | |
| | D.2.4. Thermostat Controls | |
| | D.2.5. Economizers | D-6 |
| | D.2.6. Energy Efficiency Opportunities | D-7 |
| D.3. | Premise Weighted Results | D-9 |
| | D.3.1. Equipment Types | D-9 |
| | D.3.2. Equipment Details | D-9 |
| | D.3.3. Thermostat Controls | D-11 |
| | D.3.4. Economizers | D-12 |
| D.4. | Surveyed Chiller Results | D-13 |
| Appendi | x E: Heating Results | E-1 |
| E.1. | Overall Heating | E-1 |
| | E.1.1. Conditioned Square Foot Weighted Results | E-1 |
| | E.1.2. Premise Weighted Results | |
| E.2. | Electric Heating | E-6 |
| | E.2.1. Conditioned Square Foot Weighted Results | E-6 |
| | E.2.2. Premise Weighted Results | |
| E.3. | Natural Gas Heating | E-10 |
| | E.3.1. Conditioned Square Foot Weighted Results | E-10 |
| | E.3.2. Premise Weighted Results | |
| E.4. | - | |
| | E.4.1. Conditioned Square Foot Weighted Results | |
| | E.4.2. Premise Weighted Results | |
| E.5. | LPG Heating | |



| | E.5.1. Conditioned Square Foot Weighted Results | E-17 |
|------------|-------------------------------------------------------------|------|
| | E.5.2. Premise Weighted Results | E-18 |
| E.6. | Boiler Energy Efficiency Opportunities | E-20 |
| | E.6.1. Conditioned Square Foot Weighted Results | E-20 |
| | E.6.2. Premise Weighted Results | E-21 |
| E.7. | Furnace Energy Efficiency Opportunities | E-21 |
| | E.7.1. Conditioned Square Foot Weighted Results | E-21 |
| | E.7.2. Premise Weighted Results | E-22 |
| Appendi | x F: Domestic Hot Water Results | F-1 |
| F.1. | Overall Results | F-1 |
| F.2. | Electric DHW Results | F-2 |
| F.3. | Natural Gas DHW Results | F-3 |
| F.4. | Fuel Oil DHW Results | F-4 |
| F.5. | LPG DHW Results | F-5 |
| Appendi | x G: Air Handler Results | G-1 |
| G.1. | Conditioned Square Foot Weighted Results | G-1 |
| | Premise Weighted Results | |
| Appendi | x H: Cooking Equipment Results | H-1 |
| H.1. | Square Foot Weighted | H-1 |
| H.2. | Premise Weighted | H-2 |
| Appendi | x I: Miscellaneous Equipment | I-1 |
| I.1. | Details | I-1 |
| I.2. | Energy Efficiency Opportunities | |
| List of Ta | ables: | |
| Table A- | Primary Economic Activity (Premise) | A-1 |
| Table A-2 | 2 Secondary Economic Activity (Premise) | A-1 |
| Table A-3 | Number of Floors (Premise) | A-1 |
| Table A-4 | l Total Indoor Floorspace (Premise) | A-2 |
| Table A- | 5 Total Conditioned Floorspace (Premise) | A-2 |
| Table A-6 | S Year of Original Construction (Premise) | A-2 |
| Table A-7 | Percent of Floor Space from Original Construction (Premise) | A-2 |
| | | |



| Table A-8 On-Site Generation Details (Square Foot) | A-3 |
|----------------------------------------------------------------------------|------|
| Table A-9 On-Site Generation Fuel Types (Square Foot) | |
| Table A-10 On-Site Generation Usage (Square Foot) | |
| Table A-11 On-Site Generation Details (Premise) | |
| Table A-12 On-Site Generation Fuel Types (Premise) | |
| Table A-13 On-Site Generation Usage (Premise) | |
| Table A-14 Maintenance Contracts (Square Foot) | |
| Table A-15 Packaged HVAC Maintenance (Square Foot) | |
| Table A-16 Chiller Maintenance (Square Foot) | |
| Table A-17 Boiler Maintenance (Square Foot) | |
| Table A-18 Air Handler Maintenance (Square Foot) | |
| Table A-19 Built-up Air Handler Maintenance (Square Foot) | |
| Table A-20 Maintenance Contracts (Premise) | |
| Table A-21 Packaged HVAC Maintenance (Premise) | A-7 |
| Table A-22 Chiller Maintenance (Premise) | A-8 |
| Table A-23 Boiler Maintenance (Premise) | A-8 |
| Table A-24 Air Handler Maintenance (Premise) | A-8 |
| Table A-25 Built-up Air Handler Maintenance (Premise) | |
| Table A-26 Area of Exterior Walls (Square Foot) | |
| Table A-27 Wall Types (Square Foot) | A-9 |
| Table A-28 Wall Frame Types (Square Foot) | A-9 |
| Table A-29 Above Ground Exterior Wall Insulation Level (Square Foot) | A-10 |
| Table A-30 Below Ground Exterior Wall Insulation Level (Square Foot) | A-10 |
| Table A-31 Percent of Wall Area Glazed (Square Foot) | A-10 |
| Table A-32 Window Glaze Types (Square Foot) | A-11 |
| Table A-33 Window Treatment Types (Square Foot) | A-11 |
| Table A-34 Roof Size (Square Foot) | A-11 |
| Table A-35 Roof Configuration (Square Foot) | A-11 |
| Table A-36 Roof Deck Material (Square Foot) | A-12 |
| Table A-37 Roof Surface Material (Square Foot) | A-12 |
| Table A-38 Roof Insulation Types (Square Foot) | A-12 |
| Table A-39 Roof Insulation Level (Square Foot) | A-12 |
| Table A-40 Building Envelope Energy Efficiency Opportunities (Square Foot) | A-13 |



| Table A-41 Area of Exterior Walls (Premise) | A-13 |
|------------------------------------------------------------------------|------|
| Table A-42 Wall Types (Premise) | |
| Table A-43 Wall Frame Types (Premise) | |
| Table A-44 Above Ground Exterior Wall Insulation Level (Premise) | |
| Table A-45 Below Ground Exterior Wall Insulation Level (Premise) | |
| Table A-46 Percent of Wall Area Glazed (Premise) | |
| Table A-47 Window Glaze Types (Premise) | A-15 |
| Table A-48 Window Treatment Types (Premise) | A-15 |
| Table A-49 Roof Size (Premise) | A-16 |
| Table A-50 Roof Configuration (Premise) | A-16 |
| Table A-51 Roof Deck Material (Premise) | A-16 |
| Table A-52 Roof Surface Material (Premise) | A-16 |
| Table A-53 Roof Insulation Types (Premise) | A-17 |
| Table A-54 Roof Insulation Level (Premise) | A-17 |
| Table A-55 Building Envelope Energy Efficiency Opportunities (Premise) | A-17 |
| Table B-1 Types of Indoor Lighting (Square Foot) | B-1 |
| Table B-2 Types of Indoor Lighting (Premise) | B-1 |
| Table B-3 Default Values Used For Missing Data | B-2 |
| Table B-4 Overall Light Density | B-2 |
| Table B-5 Incandescent Density | B-3 |
| Table B-6 CFL Light Density | B-3 |
| Table B-7 HID Light Density | B-3 |
| Table B-8 T5 Light Density | B-3 |
| Table B-9 Standard T8 Light Density | B-3 |
| Table B-10 HP T8 Light Density | B-4 |
| Table B-11 Unknown T8 Light Density | B-4 |
| Table B-12 T12 Light Density | B-4 |
| Table B-13 Unknown Fluorescent Tube Light Density | B-4 |
| Table B-14 Other Fluorescent Light Density | B-4 |
| Table B-15 Other Light Density | B-5 |
| Table B-16 Quartz Light Density | B-5 |
| Table B-17 Overall Light Usage (Square Foot) | B-5 |
| Table B-18 Incandescent Light Usage (Square Foot) | B-5 |



| Table B-19 CFL Light Usage (Square Foot) | |
|-----------------------------------------------------------------------|------|
| Table B-20 HID Light Usage (Square Foot) | B-6 |
| Table B-21 T5 Light Usage (Square Foot) | B-6 |
| Table B-22 Standard T8 Light Usage (Square Foot) | B-7 |
| Table B-23 HP T8 Light Usage (Square Foot) | B-7 |
| Table B-24 Unknown T8 Light Usage (Square Foot) | B-7 |
| Table B-25 T12 Light Usage (Square Foot) | B-8 |
| Table B-26 Unknown Fluorescent Tube Light Usage (Square Foot) | B-8 |
| Table B-27 Other Fluorescent Light Usage (Square Foot) | B-8 |
| Table B-28 Other Light Usage (Square Foot) | B-9 |
| Table B-29 Quartz Light Usage (Square Foot) | B-9 |
| Table B-30 Overall Light Ballast Types (Square Foot) | B-9 |
| Table B-31 CFL Light Ballast Types (Square Foot) | B-10 |
| Table B-32 HID Light Ballast Types (Square Foot) | B-10 |
| Table B-33 T5 Light Ballast Types (Square Foot) | B-10 |
| Table B-34 Standard T8 Light Ballast Types (Square Foot) | B-11 |
| Table B-35 HP T8 Light Ballast Types (Square Foot) | |
| Table B-36 Unknown T8 Light Ballast Types (Square Foot) | B-11 |
| Table B-37 T12 Light Ballast Types (Square Foot) | B-12 |
| Table B-38 Unknown Fluorescent Tube Light Ballast Types (Square Foot) | B-12 |
| Table B-39 Other Fluorescent Light Ballast Types (Square Foot) | B-12 |
| Table B-40 Overall Light Control Types (Square Foot) | B-13 |
| Table B-41 Incandescent Light Control Types (Square Foot) | B-13 |
| Table B-42 CFL Light Control Types (Square Foot) | B-14 |
| Table B-43 HID Light Control Types (Square Foot) | B-14 |
| Table B-44 T5 Light Control Types (Square Foot) | B-15 |
| Table B-45 Standard T8 Light Control Types (Square Foot) | B-15 |
| Table B-46 HP T8 Light Control Types (Square Foot) | B-16 |
| Table B-47 Unknown T8 Light Control Types (Square Foot) | B-16 |
| Table B-48 T12 Light Control Types (Square Foot) | |
| Table B-49 Unknown Fluorescent Tube Light Control Types (Square Foot) | B-17 |
| Table B-50 Other Fluorescent Light Control Types (Square Foot) | |
| Table B-51 Other Light Control Types (Square Foot) | B-18 |



| Table B-52 Quartz Light Control Types (Square Foot) | B-19 |
|-------------------------------------------------------------------|------|
| Table B-53 Overall Light Usage (Premise) | B-19 |
| Table B-54 Incandescent Light Usage (Premise) | B-19 |
| Table B-55 CFL Light Usage (Premise) | B-20 |
| Table B-56 HID Light Usage (Premise) | B-20 |
| Table B-57 T5 Light Usage (Premise) | B-20 |
| Table B-58 Standard T8 Light Usage (Premise) | B-21 |
| Table B-59 HP T8 Light Usage (Premise) | B-21 |
| Table B-60 Unknown T8 Light Usage (Premise) | B-21 |
| Table B-61 T12 Light Usage (Premise) | B-22 |
| Table B-62 Unknown Fluorescent Tube Light Usage (Premise) | B-22 |
| Table B-63 Other Fluorescent Light Usage (Premise) | B-22 |
| Table B-64 Other Light Usage (Premise) | B-23 |
| Table B-65 Quartz Light Usage (Premise) | B-23 |
| Table B-66 Overall Light Ballast Types (Premise) | B-23 |
| Table B-67 CFL Light Ballast Types (Premise) | B-24 |
| Table B-68 HID Light Ballast Types (Premise) | B-24 |
| Table B-69 T5 Light Ballast Types (Premise) | B-24 |
| Table B-70 Standard T8 Light Ballast Types (Premise) | B-25 |
| Table B-71 HP T8 Light Ballast Types (Premise) | B-25 |
| Table B-72 Unknown T8 Light Ballast Types (Premise) | B-25 |
| Table B-73 T12 Light Ballast Types (Premise) | B-26 |
| Table B-74 Unknown Fluorescent Tube Light Ballast Types (Premise) | B-26 |
| Table B-75 Other Fluorescent Light Ballast Types (Premise) | B-26 |
| Table B-76 Overall Light Control Types (Premise) | B-27 |
| Table B-77 Incandescent Light Control Types (Premise) | B-27 |
| Table B-78 CFL Light Control Types (Premise) | B-28 |
| Table B-79 HID Light Control Types (Premise) | B-28 |
| Table B-80 T5 Light Control Types (Premise) | B-29 |
| Table B-81 Standard T8 Light Control Types (Premise) | B-29 |
| Table B-82 HP T8 Light Control Types (Premise) | B-30 |
| Table B-83 Unknown T8 Light Control Types (Premise) | B-30 |
| Table B-84 T12 Light Control Types (Premise) | B-31 |
| | |



| Table B-85 Unknown Fluorescent Tube Light Control Types (Premise) | B-31 |
|--------------------------------------------------------------------------------|------|
| Table B-86 Other Fluorescent Light Control Types (Premise) | B-32 |
| Table B-87 Other Light Control Types (Premise) | B-32 |
| Table B-88 Quartz Light Control Types (Premise) | B-33 |
| Table B-89 Overall EE Opportunities (Square Foot) | B-33 |
| Table B-90 Incandescent EE Opportunities (Square Foot) | B-34 |
| Table B-91 CFL EE Opportunities (Square Foot) | B-34 |
| Table B-92 HID EE Opportunities (Square Foot) | B-35 |
| Table B-93 T5 EE Opportunities (Square Foot) | B-35 |
| Table B-94 St T8 EE Opportunities (Square Foot) | B-36 |
| Table B-95 HP T8 EE Opportunities (Square Foot) | B-36 |
| Table B-96 Unknown T8 EE Opportunities (Square Foot) | B-37 |
| Table B-97 T12 EE Opportunities (Square Foot) | B-37 |
| Table B-98 Unknown Fluorescent Tube EE Opportunities (Square Foot) | B-38 |
| Table B-99 Other Fluorescent EE Opportunities (Square Foot) | B-38 |
| Table B-100 Other Light Type EE Opportunities (Square Foot) | B-39 |
| Table B-101 Quartz EE Opportunities (Square Foot) | B-39 |
| Table B-102 Overall EE Opportunities (Premise) | B-40 |
| Table B-103 Incandescent EE Opportunities (Premise) | B-40 |
| Table B-104 CFL EE Opportunities (Premise) | B-41 |
| Table B-105 HID EE Opportunities (Premise) | B-41 |
| Table B-106 T5 EE Opportunities (Premise) | B-42 |
| Table B-107 St T8 EE Opportunities (Premise) | B-42 |
| Table B-108 HP T8 EE Opportunities (Premise) | B-43 |
| Table B-109 Unknown T8 EE Opportunities (Premise) | B-43 |
| Table B-110 T12 EE Opportunities (Premise) | B-44 |
| Table B-111 Unknown Fluorescent Tube EE Opportunities (Premise) | B-44 |
| Table B-112 Other Fluorescent EE Opportunities (Premise) | B-45 |
| Table B-113 Other Light Type EE Opportunities (Premise) | B-45 |
| Table B-114 Quartz EE Opportunities (Premise) | B-46 |
| Table C-1 Outdoor Lamp Types (Wattage) | |
| Table C-2 Specific HID Lamps as a Percent of Overall Outdoor Lighting(Wattage) | C-1 |
| Table C-3 Specific HID Lamps as a Percent of Outdoor HID Lighting (Wattage) | |



| Table C-4 Outdoor Lighting Usage (Wattage)C- | -2 |
|----------------------------------------------------------------------------------|----|
| Table C-5 Parking Lot Lamps (Wattage) | |
| Table C-6 Advertising Lamps (Wattage) | |
| Table C-7 Building Facade Lamps (Wattage) | |
| Table C-8 Walkway Lamps (Wattage) | |
| Table C-9 Overall Outdoor Lighting Control Types (Wattage) | |
| Table C-10 Outdoor HID Control Types (Wattage) | |
| Table C-11 Outdoor Fluorescent Control Types (Wattage) | |
| Table C-12 Outdoor Incandescent / Quartz Control Types (Wattage) | |
| Table C-13 Overall Outdoor Lighting Ballast Types (Wattage) | |
| Table C-14 Outdoor HID Ballast Types (Wattage) | |
| Table C-15 Outdoor Fluorescent Ballast Types (Wattage) | |
| Table C-16 Outdoor Standard Metal Halide Ballast Types (Wattage) | |
| Table C-17 Outdoor High Pressure Sodium Ballast Types (Wattage) | -6 |
| Table C-18 Overall Outdoor Lighting EE Ops (Premise)C- | -6 |
| Table C-19 Overall Outdoor Lighting EE Ops (Wattage) | -6 |
| Table C-20 HID Outdoor Lighting EE Ops (Wattage) | -7 |
| Table C-21 Fluorescent Outdoor Lighting EE Ops (Wattage) | -7 |
| Table C-22 Incandescent / Quartz Outdoor Lighting EE Ops (Wattage) | -7 |
| Table C-23 Standard Metal Halide Outdoor Lighting EE Ops (Wattage) | -8 |
| Table C-24 High Pressure Sodium Outdoor Lighting EE Ops (Wattage) | -8 |
| Table D-1 Percent of Floorspace with CoolingD- | -1 |
| Table D-2 Percent of Premises with Cooling | -1 |
| Table D-3 Percent of Known Tons by Cooling Type (Premise) | -1 |
| Table D-4 Percent of Facilities with Cooling of Type (Conditioned Square Foot)D- | -2 |
| Table D-5 Percent of Units with Cooling of Type (Conditioned Square Foot)D- | -2 |
| Table D-6 Overall Cooling EE Ops (Premise)D- | -2 |
| Table D-7 Packaged HVAC EE Ops (Premise)D- | -3 |
| Table D-8 Split System HVAC EE Ops (Premise)D- | -3 |
| Table D-9 Heat Pump EE Ops (Premise) | -3 |
| Table D-10 Overall Cooling Characteristics (Conditioned Square Foot) | -4 |
| Table D-11 Packaged HVAC Cooling Characteristics (Conditioned Square Foot)D- | -4 |
| Table D-12 Split System HVAC Cooling Characteristics (Conditioned Square Foot)D- | -4 |



| T. I. D. 40 II. (D. 10 E. 10 E. 1) | ъ. |
|---------------------------------------------------------------------------------|------|
| Table D-13 Heat Pump Cooling Characteristics (Conditioned Square Foot) | |
| Table D-14 Overall Cooling Thermostat Types (Conditioned Square Foot) | |
| Table D-15 Packaged HVAC Thermostat Types (Conditioned Square Foot) | |
| Table D-16 Split System HVAC Thermostat Types (Conditioned Square Foot) | |
| Table D-17 Heat Pump Thermostat Types (Conditioned Square Foot) | |
| Table D-18 Overall Cooling Economizer Types (Conditioned Square Foot) | |
| Table D-19 Packaged HVAC Cooling Economizer Types (Conditioned Square Foot) | D-7 |
| Table D-20 Split System HVAC Cooling Economizer Types (Conditioned Square Foot) | D-7 |
| Table D-21 Overall Cooling EE Ops (Conditioned Square Foot) | D-7 |
| Table D-22 Packaged HVAC EE Ops (Conditioned Square Foot) | |
| Table D-23 Split System HVAC EE Ops (Conditioned Square Foot) | D-8 |
| Table D-24 Heat Pump EE Ops (Conditioned Square Foot) | D-8 |
| Table D-25 Percent of Facilities with Cooling of Type (Conditioned Square Foot) | D-9 |
| Table D-26 Percent of Units with Cooling of Type (Conditioned Square Foot) | D-9 |
| Table D-27 Overall Cooling Characteristics (Premise) | D-9 |
| Table D-28 Packaged HVAC Cooling Characteristics (Premise) | D-10 |
| Table D-29 Split System HVAC Cooling Characteristics (Premise) | D-10 |
| Table D-30 Heat Pump Cooling Characteristics (Premise) | D-10 |
| Table D-31 Overall Cooling Thermostat Types (Premise) | D-11 |
| Table D-32 Packaged HVAC Thermostat Types (Premise) | D-11 |
| Table D-33 Split System HVAC Thermostat Types (Premise) | D-11 |
| Table D-34 Heat Pump Thermostat Types (Premise) | D-12 |
| Table D-35 Overall Cooling Economizer Types (Premise) | D-12 |
| Table D-36 Packaged HVAC Cooling Economizer Types (Premise) | D-12 |
| Table D-37 Split System HVAC Cooling Economizer Types (Premise) | D-13 |
| Table D-38 Chiller Details | D-13 |
| Table D-39 Chiller EE Opportunities | D-13 |
| Table E-1 Heating Fuel Types (Conditioned Square Foot) | E-1 |
| Table E-2 Percent of Heating Units of Fuel Type (Conditioned Square Foot) | E-1 |
| Table E-3 Heating Equipment Types (Conditioned Square Foot) | |
| Table E-4 Percent of Heating Units by Equipment Type (Conditioned Square Foot) | |
| Table E-5 Heating Control Types (Conditioned Square Foot) | |
| Table E-6 Efficiency of Heating Equipment (Conditioned Square Foot) | |
| , , , , , , , , , , , , , , , , , , , , | |



| Table E-7 Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-3 Table E-8 Heating Fuel Types (Premise) | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|-------------|
| Table E-9 Percent of Heating Units of Fuel Type (Premise) | Table E-7 Heating Energy Efficiency Opportunities (Conditioned Square Foot) | E-3 |
| Table E-10 Heating Equipment Types (Premise) | Table E-8 Heating Fuel Types (Premise) | E-3 |
| Table E-11 Percent of Heating Units by Equipment Type (Premise) | Table E-9 Percent of Heating Units of Fuel Type (Premise) | E-4 |
| Table E-12 Heating Control Types (Premise) | Table E-10 Heating Equipment Types (Premise) | E-4 |
| Table E-13 Capacity of Heating Equipment (Premise) | Table E-11 Percent of Heating Units by Equipment Type (Premise) | E-4 |
| Table E-14 Efficiency of Heating Equipment (Premise) | Table E-12 Heating Control Types (Premise) | E-5 |
| Table E-15 Heating Energy Efficiency Opportunities (Premise) | Table E-13 Capacity of Heating Equipment (Premise) | E-5 |
| Table E-15 Heating Energy Efficiency Opportunities (Premise) | Table E-14 Efficiency of Heating Equipment (Premise) | E-5 |
| Table E-17 Electric Heating Control Types (Conditioned Square Foot) | | |
| Table E-18 Electric Heating Efficiency of Equipment (Conditioned Square Foot) | Table E-16 Percent of Electric Heating Units Equipment Types (Conditioned Square Foot) | E-6 |
| Table E-19 Electric Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-7 Table E-20 Percent of Electric Heating Units Equipment Types (Premise) E-8 Table E-21 Electric Heating Control Types (Premise) E-8 Table E-22 Electric Heating Capacity of Equipment (Premise) E-8 Table E-23 Electric Heating Efficiency of Equipment (Premise) E-9 Table E-24 Electric Heating Energy Efficiency Opportunities (Premise) E-9 Table E-25 Percent of Natural Gas Heating Units Equipment Types (Conditioned Square Foot) E-10 Table E-26 Natural Gas Heating Control Types (Conditioned Square Foot) E-10 Table E-27 Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-10 Table E-28 Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-11 Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) E-11 Table E-30 Natural Gas Heating Control Types (Premise) E-12 Table E-31 Natural Gas Capacity of Heating Equipment (Premise) E-12 Table E-32 Natural Gas Heating Energy Efficiency Opportunities (Premise) E-12 Table E-33 Natural Gas Heating Energy Efficiency Opportunities (Premise) E-12 Table E-34 Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot) E-13 Table E-35 Fuel Oil Heating Control Types (Conditioned Square Foot) E-14 Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) E-14 | Table E-17 Electric Heating Control Types (Conditioned Square Foot) | E-7 |
| Table E-20 Percent of Electric Heating Units Equipment Types (Premise) | Table E-18 Electric Heating Efficiency of Equipment (Conditioned Square Foot) | E-7 |
| Table E-21 Electric Heating Control Types (Premise) | Table E-19 Electric Heating Energy Efficiency Opportunities (Conditioned Square Foot) | E-7 |
| Table E-22 Electric Heating Capacity of Equipment (Premise) | Table E-20 Percent of Electric Heating Units Equipment Types (Premise) | E-8 |
| Table E-23 Electric Heating Efficiency of Equipment (Premise) | Table E-21 Electric Heating Control Types (Premise) | E-8 |
| Table E-24 Electric Heating Energy Efficiency Opportunities (Premise) | Table E-22 Electric Heating Capacity of Equipment (Premise) | E-8 |
| Table E-25 Percent of Natural Gas Heating Units Equipment Types (Conditioned Square Foot) E-10 Table E-26 Natural Gas Heating Control Types (Conditioned Square Foot) | Table E-23 Electric Heating Efficiency of Equipment (Premise) | E- 9 |
| Table E-26 Natural Gas Heating Control Types (Conditioned Square Foot) E-10 Table E-27 Natural Gas Efficiency of Heating Equipment (Conditioned Square Foot) E-10 Table E-28 Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-11 Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) E-11 Table E-30 Natural Gas Heating Control Types (Premise) E-12 Table E-31 Natural Gas Capacity of Heating Equipment (Premise) E-12 Table E-32 Natural Gas Efficiency of Equipment (Premise) E-12 Table E-33 Natural Gas Heating Energy Efficiency Opportunities (Premise) E-13 Table E-34 Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot) E-14 Table E-35 Fuel Oil Heating Control Types (Conditioned Square Foot) E-14 Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) E-14 | Table E-24 Electric Heating Energy Efficiency Opportunities (Premise) | E-9 |
| Table E-26 Natural Gas Heating Control Types (Conditioned Square Foot) | | |
| Table E-27 Natural Gas Efficiency of Heating Equipment (Conditioned Square Foot) E-10 Table E-28 Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-11 Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) E-11 Table E-30 Natural Gas Heating Control Types (Premise) E-12 Table E-31 Natural Gas Capacity of Heating Equipment (Premise) E-12 Table E-32 Natural Gas Efficiency of Equipment (Premise) E-12 Table E-33 Natural Gas Heating Energy Efficiency Opportunities (Premise) E-13 Table E-34 Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot) E-14 Table E-35 Fuel Oil Heating Control Types (Conditioned Square Foot) E-14 Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) E-14 | | . E-10 |
| Table E-28 Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-11 Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) E-12 Table E-30 Natural Gas Heating Control Types (Premise) E-12 Table E-31 Natural Gas Capacity of Heating Equipment (Premise) E-12 Table E-32 Natural Gas Efficiency of Equipment (Premise) E-12 Table E-33 Natural Gas Heating Energy Efficiency Opportunities (Premise) E-13 Table E-34 Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot) E-14 Table E-36 Fuel Oil Heating Control Types (Conditioned Square Foot) E-14 | Table E-26 Natural Gas Heating Control Types (Conditioned Square Foot) | . E-10 |
| Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) | Table E-27 Natural Gas Efficiency of Heating Equipment (Conditioned Square Foot) | . E-10 |
| Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) | Table E-28 Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foo | t) |
| Table E-30 Natural Gas Heating Control Types (Premise) | | . E-11 |
| Table E-31 Natural Gas Capacity of Heating Equipment (Premise) | Table E-29 Percent of Natural Gas Heating Units Equipment Types (Premise) | . E-11 |
| Table E-32 Natural Gas Efficiency of Equipment (Premise) | Table E-30 Natural Gas Heating Control Types (Premise) | . E-12 |
| Table E-33 Natural Gas Heating Energy Efficiency Opportunities (Premise) | Table E-31 Natural Gas Capacity of Heating Equipment (Premise) | . E-12 |
| Table E-34 Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot). E-13 Table E-35 Fuel Oil Heating Control Types (Conditioned Square Foot) E-14 Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) E-14 | Table E-32 Natural Gas Efficiency of Equipment (Premise) | . E-12 |
| Table E-35 Fuel Oil Heating Control Types (Conditioned Square Foot) E-14 Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) E-14 | Table E-33 Natural Gas Heating Energy Efficiency Opportunities (Premise) | . E-13 |
| Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) E-14 | Table E-34 Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot) | . E-13 |
| | Table E-35 Fuel Oil Heating Control Types (Conditioned Square Foot) | . E-14 |
| Table E-37 Fuel Oil Heating Energy Efficiency Opportunities (Conditioned Square Foot) E-14 | Table E-36 Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot) | . E-14 |
| | Table E-37 Fuel Oil Heating Energy Efficiency Opportunities (Conditioned Square Foot) | . E-14 |



| Table E-38 Percent of Fuel Oil Heating Units Equipment Types (Premise) | E-15 |
|-----------------------------------------------------------------------------------|------|
| Table E-39 Fuel Oil Heating Control Types (Premise) | E-15 |
| Table E-40 Fuel Oil Heating Capacity of Equipment (Premise) | E-15 |
| Table E-41 Fuel Oil Heating Efficiency of Equipment (Premise) | E-16 |
| Table E-42 Fuel Oil Heating Energy Efficiency Opportunities (Premise) | E-16 |
| Table E-43 Percent of LPG Heating Units Equipment Types (Conditioned Square Foot) | E-17 |
| Table E-44 LPG Heating Control Types (Conditioned Square Foot) | E-17 |
| Table E-45 LPG Heating Efficiency of Equipment (Conditioned Square Foot) | E-17 |
| Table E-46 LPG Heating Energy Efficiency Opportunities (Conditioned Square Foot) | E-18 |
| Table E-47 Percent of LPG Heating Units Equipment Types (Premise) | E-18 |
| Table E-48 LPG Heating Heating Control Types (Premise) | E-19 |
| Table E-49 LPG Heating Capacity of Equipment (Premise) | E-19 |
| Table E-50 LPG Heating Efficiency of Equipment (Premise) | E-19 |
| Table E-51 LPG Heating Energy Efficiency Opportunities (Premise) | E-20 |
| Table E-52 Boiler Energy Efficiency Opportunities (Conditioned Square Foot) | E-20 |
| Table E-53 Boiler Energy Efficiency Opportunities (Premise) | E-21 |
| Table E-54 Furnace Energy Efficiency Opportunities (Conditioned Square Foot) | E-21 |
| Table E-55 Furnace Energy Efficiency Opportunities (Premise) | E-22 |
| Table F-1 Overall DHW Fuel Type (Premise) | F-1 |
| Table F-2 Overall DHW Type (Premise) | F-1 |
| Table F-3 Overall DHW Tank Capacity (Premise) | F-1 |
| Table F-4 Overall DHW EE Ops (Premise) | F-2 |
| Table F-5 Electric DHW Type (Premise) | F-2 |
| Table F-6 Electric DHW Tank Capacity (Premise) | F-2 |
| Table F-7 Electric DHW Details (Premise) | F-3 |
| Table F-8 Electric DHW EE Ops (Premise) | F-3 |
| Table F-9 Natural Gas DHW Type (Premise) | F-3 |
| Table F-10 Natural Gas DHW Tank Capacity (Premise) | F-4 |
| Table F-11 Natural Gas DHW EE Ops (Premise) | F-4 |
| Table F-12 Fuel Oil DHW Type (Premise) | F-4 |
| Table F-13 Fuel Oil DHW Tank Capacity (Premise) | F-5 |
| Table F-14 Fuel Oil DHW EE Ops (Premise) | F-5 |
| Table F-15 LPG DHW Type (Premise) | F-5 |



| Table F-16 LPG DHW Tank Capacity (Premise) | F-6 |
|-----------------------------------------------------------------------------------|-----|
| Table F-17 LPG DHW EE Ops (Premise) | F-6 |
| Table G-1 Air Handlers and Economizers (Conditioned Square Foot) | G-1 |
| Table G-2 Air Handler Percent of Fans with Control Type (Conditioned Square Foot) | G-1 |
| Table G-3 Air Handler EE Ops by Building Type (Conditioned Square Foot) | G-1 |
| Table G-4 Air Handlers and Economizers (Premise) | G-1 |
| Table G-5 Air Handler Percent of Fans with Control Type (Premise) | G-2 |
| Table G-6 Air Handler EE Ops by Building Type (Premise) | G-2 |
| Table H-1 Cooking Equipment (Square Foot) | H-1 |
| Table H-2 Electric Cooking Equipment (Square Foot) | H-1 |
| Table H-3 Cooking EE Options in Place (Square Foot) | H-1 |
| Table H-4 Cooking EE Opportunities (Square Foot) | H-2 |
| Table H-5 Cooking Equipment (Premise) | H-2 |
| Table H-6 Electric Cooking Equipment (Premise) | H-2 |
| Table H-7 Cooking EE Options in Place (Premise) | H-3 |
| Table H-8 Cooking EE Opportunities (Premise) | H-3 |
| Table I-1 Computer Equipment Inventory (Premise) | I-1 |
| Table I-2 Copier Equipment Inventory (Premise) | I-1 |
| Table I-3 Vending Equipment Inventory (Premise) | I-2 |
| Table I-4 Elevator Equipment Inventory (Premise) | I-2 |
| Table I-5 Laundry Equipment Inventory (Premise) | I-3 |
| Table I-6 Office Equipmet EE Opportunities (Premise) | I-3 |
| Table I-7 Vending Machine EE Opportunities (Premise) | I-3 |
| Table I-8 Elevator EE Opportunities (Premise) | I-4 |
| Table I-9 Laundry EE Opportunities (Premise) | I-4 |





Appendix A: General and Building Envelope

A.1. Facility Details

A.1.1. Premise Weighted Results

Table A-1
Primary Economic Activity (Premise)

| Economic Activity | # of Sites | Weighted Percent |
|-------------------|------------|---------------------|
| Retail | 6 | 22% |
| Office | 4 | 15% |
| Restaurant | 1 | 4% |
| Warehouse | 1 | 4% |
| Other Health | 6 | 22% |
| School | 2 | 7% |
| Other | 7 | 26% |

Table A-2 Secondary Economic Activity (Premise)

| Economic Activity | # of Sites | Weighted Percent |
|-------------------|------------|---------------------|
| None | 16 | 59% |
| Retail | 1 | 4% |
| Office | 2 | 7% |
| Restaurant | 2 | 7% |
| Warehouse | 0 | 0% |
| Other Health | 1 | 4% |
| School | 0 | 0% |
| Other | 2 | 7% |
| Unknown | 3 | 11% |

Table A-3 Number of Floors (Premise)

| Number of Floors | # of Sites | Weighted Percent |
|------------------|------------|---------------------|
| One | 13 | 48% |
| Two | 8 | 30% |
| Three | 5 | 19% |
| Four or more | 1 | 4% |



Table A-4
Total Indoor Floorspace (Premise)

| Total Indoor Floorspace (Sq. Ft.) | # of Sites | Percent |
|-----------------------------------|------------|---------|
| <= 2000 | 0 | 0% |
| 2001 - 5000 | 8 | 30% |
| 5001 - 10000 | 6 | 22% |
| 10001 - 20000 | 5 | 19% |
| 20001 - 50000 | 6 | 22% |
| 50001+ | 2 | 7% |

Table A-5
Total Conditioned Floorspace (Premise)

| Total Conditioned Floorspace (Sq. Ft.) | · J#OtSites I Pe | |
|-------------------------------------------|------------------|-----|
| <= 2000 | 1 | 4% |
| 2001 - 5000 | 7 | 26% |
| 5001 - 10000 | 7 | 26% |
| 10001 - 20000 | 5 | 19% |
| 20001 - 50000 | 5 | 19% |
| 50001+ | 2 | 7% |

Table A-6
Year of Original Construction (Premise)

| Time Period | # of Sites | Weighted Percent |
|-------------|------------|---------------------|
| Before 2005 | 2 | 7% |
| 2005 | 1 | 4% |
| 2006 | 13 | 48% |
| 2007 | 9 | 33% |
| 2008 | 2 | 7% |
| Unknown | 0 | 0% |

Table A-7
Percent of Floor Space from Original Construction (Premise)

| Percent of Space | # of Sites | Weighted |
|------------------|------------|----------|
| reicent of Space | # OI Sites | Percent |
| 0 - 25% | 0 | 0% |
| 26 - 50% | 1 | 4% |
| 51 - 75% | 0 | 0% |
| 76 - 100% | 25 | 93% |
| Unknown | 1 | 4% |



A.2. On-Site Generation

A.2.1. Square Foot Weighted Results

Table A-8
On-Site Generation Details (Square Foot)

| Onsite Generation Details | Percent | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------|---------|------------|----------------------------------|-----|
| Have On-Site Generation | 20% | 27 | 8% | 33% |
| Cogeneration Capable | 0% | 7 | 0% | 0% |

Table A-9
On-Site Generation Fuel Types (Square Foot)

| Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------|---------|------------|----------------------------------|----------------------------------|
| Natural Gas | 0% | 7 | 0% | 0% |
| LPG | 14% | 7 | -2% | 29% |
| Diesel | 81% | 7 | 64% | 99% |
| Other | 5% | 7 | -2% | 12% |
| Unknown Fuel Type | 0% | 7 | 0% | 0% |

Table A-10
On-Site Generation Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------|---------|------------|----------------------------------|----------------------------------|
| Emergency | 100% | 7 | 100% | 100% |
| Peak Shaving | 0% | 7 | 0% | 0% |
| Baseload | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |
| Unknown Usage | 0% | 7 | 0% | 0% |

A.2.2. Premise Weighted Results

Table A-11
On-Site Generation Details (Premise)

| Onsite Generation Details | Percent/ Size | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|------------------|------------|----------------------------------|----------------------------------|
| Have Onsite Generation | 26% | 27 | 15% | 37% |
| Size (kW) | 68 | 7 | 25.1 | 110.1 |
| Unknown Size | 0% | 7 | 0% | 0% |
| Cogeneration Capable | 0% | 7 | 0% | 0% |



Table A-12
On-Site Generation Fuel Types (Premise)

| Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------|---------|------------|----------------------------------|----------------------------------|
| Natural Gas | 0% | 7 | 0% | 0% |
| LPG | 29% | 7 | 6% | 51% |
| Diesel | 57% | 7 | 32% | 82% |
| Other | 14% | 7 | -3% | 32% |
| Unknown Fuel Type | 0% | 7 | 0% | 0% |

Table A-13
On-Site Generation Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------|---------|------------|----------------------------------|----------------------------------|
| Emergency | 100% | 7 | 100% | 100% |
| Peak Shaving | 0% | 7 | 0% | 0% |
| Baseload | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |
| Unknown Usage | 0% | 7 | 0% | 0% |

A.3. Maintenance

A.3.1. Square Foot Weighted Results

Table A-14
Maintenance Contracts (Square Foot)

| maintenance contracts (equal o 1 con) | | | | |
|------------------------------------------------|-----------------------------------|------------|----------------------------------|----------------------------------|
| Conditioning Type with Maintenance Contract | Percent of Conditioned Floorspace | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Packaged HVAC | 53.6% | 14 | 25.5% | 81.8% |
| Boiler | 82.9% | 20 | 69.1% | 96.7% |
| Air Handler | 36.0% | 11 | 14.0% | 58.1% |
| Chiller | 43.2% | 2 | -3.3% | 89.7% |
| Built-up HVAC | 41.5% | 5 | 6.9% | 76.1% |



Table A-15
Packaged HVAC Maintenance (Square Foot)

| Packaged HVAC Service Type # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
|----------------------------------------------|---------|------------|----------------------------------|----------------------------------|--|
| Coils Cleaned | | | | | |
| 0 Times | 2.2% | 14 | -0.9% | 5.4% | |
| Less than Once | 14.2% | 14 | -0.3% | 28.6% | |
| Once | 66.7% | 14 | 45.6% | 87.8% | |
| Twice | 13.4% | 14 | 2.6% | 24.3% | |
| 3+ | 0.0% | 14 | 0.0% | 0.0% | |
| Refrigerant Checked | | | | | |
| 0 Times | 2.2% | 14 | -0.9% | 5.4% | |
| Less than Once | 14.2% | 14 | -0.3% | 28.6% | |
| Once | 71.5% | 14 | 52.0% | 91.0% | |
| Twice | 8.6% | 14 | -0.4% | 17.7% | |
| 3+ | 0.0% | 14 | 0.0% | 0.0% | |
| Dampers Checked | | | | | |
| 0 Times | 0.0% | 14 | 0.0% | 0.0% | |
| Less than Once | 14.2% | 14 | -0.3% | 28.6% | |
| Once | 64.7% | 14 | 42.8% | 86.6% | |
| Twice | 10.7% | 14 | 0.8% | 20.6% | |
| 3+ | 4.8% | 14 | -0.7% | 10.2% | |

Table A-16
Chiller Maintenance (Square Foot)

| Chiller Serviced # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 0.0% | 2 | 0.0% | 0.0% |
| Less than Once | 0.0% | 2 | 0.0% | 0.0% |
| Once | 0.0% | 2 | 0.0% | 0.0% |
| Twice | 0.0% | 2 | 0.0% | 0.0% |
| 3+ | 56.8% | 2 | 10.3% | 103.3% |



Table A-17
Boiler Maintenance (Square Foot)

| Boiler Efficiency Checked # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 0.0% | 20 | 0.0% | 0.0% |
| Less than Once | 0.0% | 20 | 0.0% | 0.0% |
| Once | 70.9% | 20 | 53.3% | 88.4% |
| Twice | 15.0% | 20 | 1.0% | 29.0% |
| 3+ | 2.3% | 20 | -0.1% | 4.6% |

Table A-18
Air Handler Maintenance (Square Foot)

| Air Handler Controls Checked # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 4.0% | 11 | -1.6% | 9.6% |
| Less than Once | 7.3% | 11 | -2.6% | 17.2% |
| Once | 59.3% | 11 | 35.0% | 83.6% |
| Twice | 0.0% | 11 | 0.0% | 0.0% |
| 3+ | 17.1% | 11 | 0.0% | 34.1% |

Table A-19
Built-up Air Handler Maintenance (Square Foot)

| Built-up Air Handler Serviced # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 5.3% | 5 | -2.4% | 12.9% |
| Less than Once | 9.6% | 5 | -3.8% | 22.9% |
| Once | 37.1% | 5 | 0.7% | 73.5% |
| Twice | 0.0% | 5 | 0.0% | 0.0% |
| 3+ | 16.2% | 5 | -5.0% | 37.3% |



A.3.2. Premise Weighted Results

Table A-20 Maintenance Contracts (Premise)

| Conditioning Type with Maintenance Contract | Percent of Conditioned Premises | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------------------|---------------------------------------|------------|----------------------------------|----------------------------------|
| Packaged HVAC | 71.4% | 14 | 55.3% | 87.6% |
| Boiler | 80.0% | 20 | 68.0% | 92.0% |
| Air Handler | 63.6% | 11 | 44.2% | 83.1% |
| Chiller | 50.0% | 2 | 2.6% | 97.4% |
| Built-up HVAC | 40.0% | 5 | 10.6% | 69.4% |

Table A-21
Packaged HVAC Maintenance (Premise)

| Packaged HVAC Maintenance (Premise) | | | | | | |
|----------------------------------------------|---------|------------|----------------------------------|----------------------------------|--|--|
| Packaged HVAC Service Type # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
| Coils Cleaned | | | | | | |
| 0 Times | 7.1% | 14 | -2.1% | 16.4% | | |
| Less than Once | 14.3% | 14 | 1.8% | 26.8% | | |
| Once | 35.7% | 14 | 18.6% | 52.9% | | |
| Twice | 35.7% | 14 | 18.6% | 52.9% | | |
| 3+ | 0.0% | 14 | 0.0% | 0.0% | | |
| Refrigerant Checked | | | | | | |
| 0 Times | 7.1% | 14 | -2.1% | 16.4% | | |
| Less than Once | 14.3% | 14 | 1.8% | 26.8% | | |
| Once | 57.1% | 14 | 39.4% | 74.9% | | |
| Twice | 14.3% | 14 | 1.8% | 26.8% | | |
| 3+ | 0.0% | 14 | 0.0% | 0.0% | | |
| Dampers Checked | | | | | | |
| 0 Times | 0.0% | 14 | 0.0% | 0.0% | | |
| Less than Once | 14.3% | 14 | 1.8% | 26.8% | | |
| Once | 35.7% | 14 | 18.6% | 52.9% | | |
| Twice | 21.4% | 14 | 6.7% | 36.1% | | |
| 3+ | 14.3% | 14 | 1.8% | 26.8% | | |



Table A-22 Chiller Maintenance (Premise)

| Chiller Serviced # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 0.0% | 2 | 0.0% | 0.0% |
| Less than Once | 0.0% | 2 | 0.0% | 0.0% |
| Once | 0.0% | 2 | 0.0% | 0.0% |
| Twice | 0.0% | 2 | 0.0% | 0.0% |
| 3+ | 50.0% | 2 | 2.6% | 97.4% |

Table A-23
Boiler Maintenance (Premise)

| Boiler Efficiency Checked # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 0.0% | 20 | 0.0% | 0.0% |
| Less than Once | 0.0% | 20 | 0.0% | 0.0% |
| Once | 65.0% | 20 | 50.7% | 79.3% |
| Twice | 10.0% | 20 | 1.0% | 19.0% |
| 3+ | 10.0% | 20 | 1.0% | 19.0% |

Table A-24
Air Handler Maintenance (Premise)

| Air Handler Controls Checked # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 9.1% | 11 | -2.5% | 20.7% |
| Less than Once | 9.1% | 11 | -2.5% | 20.7% |
| Once | 45.5% | 11 | 25.3% | 65.6% |
| Twice | 0.0% | 11 | 0.0% | 0.0% |
| 3+ | 18.2% | 11 | 2.6% | 33.8% |

Table A-25
Built-up Air Handler Maintenance (Premise)

| Built-up Air Handler Serviced # Times / Year | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| 0 Times | 20.0% | 5 | -4.0% | 44.0% |
| Less than Once | 20.0% | 5 | -4.0% | 44.0% |
| Once | 20.0% | 5 | -4.0% | 44.0% |
| Twice | 0.0% | 5 | 0.0% | 0.0% |
| 3+ | 20.0% | 5 | -4.0% | 44.0% |



A.4. Building Envelope

A.4.1. Square Foot Weighted Results

A.4.1.1. Walls

Table A-26
Area of Exterior Walls (Square Foot)

| 7.104 0. =xto110. 114.10 (0444.10 1 004) | | | | | |
|------------------------------------------|---------|------------|-------------------------------|-------------------------------|--|
| Area of Exterior Walls | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
| Less than 5,000 | 12% | 27 | 5% | 19% | |
| 5,000 to 10,000 | 17% | 27 | 7% | 26% | |
| 10,000 to15,000 | 20% | 27 | 7% | 33% | |
| 15,000 to 20,000 | 5% | 27 | -2% | 12% | |
| Greater than 20,000 | 35% | 27 | 14% | 57% | |
| Unknown | 11% | 27 | -3% | 24% | |

Table A-27
Wall Types (Square Foot)

| Wall Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------|---------|------------|-------------------------------|-------------------------------|
| Frame | 40% | 27 | 20% | 59% |
| Brick | 11% | 27 | -3% | 24% |
| Concrete | 0% | 27 | 0% | 0% |
| Brick and Block | 2% | 27 | -1% | 4% |
| Composite Panel | 35% | 27 | 17% | 53% |
| Other Masonry | 0% | 27 | 0% | 0% |
| Other | 13% | 27 | 3% | 22% |
| Unknown | 0% | 27 | 0% | 0% |

Table A-28
Wall Frame Types (Square Foot)

| Frame Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------|---------|------------|-------------------------------|-------------------------------|
| Metal | 40% | 27 | 22% | 58% |
| Wood | 58% | 27 | 39% | 76% |
| Other | 0% | 27 | 0% | 0% |
| Unknown | 2% | 27 | 0% | 5% |



Table A-29
Above Ground Exterior Wall Insulation Level (Square Foot)

| 7 to 5 to 5 to 6 to 6 to 6 to 6 to 6 to 6 | | | | | |
|-------------------------------------------|---------|------------|-------------------------------|-------------------------------|--|
| Above Ground Wall Insulation (R-Value) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
| Average R-Value | 22 | 27 | 21 | 24 | |
| Less than 10 | 1% | 27 | 0% | 1% | |
| 10 to 15 | 1% | 27 | 0% | 2% | |
| 15 to 20 | 26% | 27 | 10% | 41% | |
| 20 to 30 | 37% | 27 | 17% | 57% | |
| Greater than 30 | 5% | 27 | 1% | 10% | |
| Unknown | 30% | 27 | 13% | 47% | |

Table A-30
Below Ground Exterior Wall Insulation Level (Square Foot)

| Zolow Ground Zatorio: Han internation Zoroi (oqualo 1 00) | | | | | |
|-----------------------------------------------------------|---------|------------|-------------------------------|-------------------------------|--|
| Below Ground Wall Insulation (R-Value) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
| Average R-Value | 7 | 27 | 5 | 9 | |
| Less than 10 | 27% | 27 | 6% | 47% | |
| 10 to 15 | 5% | 27 | -1% | 11% | |
| 15 to 20 | 2% | 27 | -1% | 5% | |
| 20 to 30 | 1% | 27 | 0% | 3% | |
| Greater than 30 | 0% | 27 | 0% | 0% | |
| No Below Ground Walls | 36% | 27 | 19% | 53% | |
| Unknown | 29% | 27 | 12% | 46% | |

A.4.1.2. Windows

Table A-31
Percent of Wall Area Glazed (Square Foot)

| Percent of Wall Area Glazed (Percent) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------|---------|------------|-------------------------------|-------------------------------|
| Average Percent of Wall area Glazed | 24% | 27 | 19% | 30% |
| None | 7% | 27 | 0% | 13% |
| Less than 10 Percent | 7% | 27 | 1% | 14% |
| 10 to 20 | 20% | 27 | 9% | 32% |
| 20 to 30 | 43% | 27 | 23% | 63% |
| 30 to 40 | 7% | 27 | -2% | 15% |
| Greater than 40 | 15% | 27 | 1% | 29% |
| Unknown | 1% | 27 | 0% | 2% |



Table A-32
Window Glaze Types (Square Foot)

| Glaze Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------|---------|------------|-------------------------------|-------------------------------|
| Single | 1% | 27 | 0% | 1% |
| Double | 82% | 27 | 70% | 94% |
| Triple | 7% | 27 | -1% | 16% |
| Not Applicable | 7% | 27 | 0% | 13% |
| Unknown | 4% | 27 | -1% | 9% |

Table A-33
Window Treatment Types (Square Foot)

| Trindow Trodamont Typos (Square 1 oct) | | | | | |
|----------------------------------------|---------|------------|-------------------------------|-------------------------------|--|
| Window Treatment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
| Clear | 46% | 27 | 27% | 66% | |
| Tinted | 0% | 27 | 0% | 0% | |
| Reflective | 0% | 27 | 0% | 0% | |
| Gas-Filled | 11% | 27 | 2% | 19% | |
| Low E | 35% | 27 | 17% | 52% | |
| Opaque | 0% | 27 | 0% | 0% | |
| Unknown | 9% | 27 | 1% | 16% | |

A.4.1.3. Roofs

Table A-34
Roof Size (Square Foot)

| Roof Size (Square Feet) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|-------------------------------|-------------------------------|
| Average Roof Size | 20,205 | 27 | 15,260 | 25,149 |
| Less than 5,000 | 11% | 27 | 5% | 18% |
| 5,000 to 10,000 | 4% | 27 | 1% | 7% |
| 10,000 to 15,000 | 22% | 27 | 10% | 34% |
| 15000 to 20,000 | 23% | 27 | 2% | 43% |
| 20,000 to 25,0000 | 16% | 27 | 4% | 28% |
| Greater than 25,000 | 24% | 27 | 5% | 42% |
| Unknown | 2% | 27 | -1% | 4% |

Table A-35
Roof Configuration (Square Foot)

| Roof Configuration | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------|---------|------------|-------------------------------|-------------------------------|
| Flat | 37% | 27 | 16% | 57% |
| Pitched | 63% | 27 | 43% | 84% |
| Interior Space | 0% | 27 | 0% | 0% |



Table A-36
Roof Deck Material (Square Foot)

| Roof Deck Material | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
|--------------------|---------|------------|-------------------------------|-------------------------------|--|
| Concrete | 2% | 27 | -1% | 5% | |
| Wood | 44% | 27 | 25% | 63% | |
| Metal | 31% | 27 | 14% | 47% | |
| Other | 2% | 27 | -1% | 5% | |
| Unknown | 21% | 27 | 0% | 42% | |

Table A-37
Roof Surface Material (Square Foot)

| Roof Surface Material | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|-------------------------------|-------------------------------|
| Shingles/Felt | 30% | 27 | 13% | 47% |
| Built-Up | 19% | 27 | -2% | 40% |
| Membrane | 22% | 27 | 7% | 37% |
| Other | 27% | 27 | 13% | 40% |
| Unknown | 2% | 27 | 0% | 5% |

Table A-38
Roof Insulation Types (Square Foot)

| Roof Insulation Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------|---------|------------|-------------------------------|-------------------------------|
| None | 1% | 27 | 0% | 1% |
| Rigid | 35% | 27 | 15% | 55% |
| Batt/Blown | 35% | 27 | 17% | 52% |
| Other | 9% | 27 | 2% | 17% |
| Unknown | 21% | 27 | 6% | 36% |

Table A-39
Roof Insulation Level (Square Foot)

| Roof Insulation (R-Value) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|-------------------------------|-------------------------------|
| Average R-Value | 36 | 27 | 32 | 40 |
| Less than 20 | 7% | 27 | 0% | 14% |
| 20 to 30 | 1% | 27 | 0% | 3% |
| 30 to 40 | 35% | 27 | 15% | 56% |
| 40 to 50 | 12% | 27 | 3% | 21% |
| Greater than 50 | 5% | 27 | 1% | 9% |
| Unknown | 40% | 27 | 21% | 59% |



A.4.1.4. Building Envelope Energy Efficiency Opportunities

Table A-40
Building Envelope Energy Efficiency Opportunities (Square Foot)

| Energy Efficincy Opportunities | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------|---------|------------|-------------------------------|-------------------------------|
| Add Wall Insulation | 8% | 27 | 1% | 16% |
| Cool Roof | 3% | 27 | 0% | 6% |
| Add Roof Insulation | 2% | 27 | 0% | 4% |

A.4.2. Premise Weighted Results

A.4.2.1. Walls

Table A-41
Area of Exterior Walls (Premise)

| Area of Exterior Walls | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|-------------------------------|-------------------------------|
| Less than 5,000 | 37% | 27 | 25% | 49% |
| 5,000 to 10,000 | 30% | 27 | 18% | 41% |
| 10,000 to15,000 | 15% | 27 | 6% | 24% |
| 15,000 to 20,000 | 4% | 27 | -1% | 9% |
| Greater than 20,000 | 11% | 27 | 3% | 19% |
| Unknown | 4% | 27 | -1% | 9% |

Table A-42 Wall Types (Premise)

| Wall Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------|---------|------------|-------------------------------|-------------------------------|
| Frame | 52% | 27 | 39% | 65% |
| Brick | 4% | 27 | -1% | 9% |
| Concrete | 0% | 27 | 0% | 0% |
| Brick and Block | 4% | 27 | -1% | 9% |
| Composite Panel | 26% | 27 | 15% | 37% |
| Other Masonry | 0% | 27 | 0% | 0% |
| Other | 15% | 27 | 6% | 24% |
| Unknown | 0% | 27 | 0% | 0% |



Table A-43
Wall Frame Types (Premise)

| Frame Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------|---------|------------|-------------------------------|-------------------------------|
| Metal | 41% | 27 | 28% | 53% |
| Wood | 52% | 27 | 39% | 65% |
| Other | 0% | 27 | 0% | 0% |
| Unknown | 7% | 27 | 1% | 14% |

Table A-44
Above Ground Exterior Wall Insulation Level (Premise)

| 715010 Ground Exterior train incaration Ector (Fronties) | | | | | | |
|----------------------------------------------------------|---------|------------|-------------------------------|-------------------------------|--|--|
| Above Ground Wall Insulation (R-Value) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
| Average R-Value | 22 | 27 | 20 | 25 | | |
| Less than 10 | 4% | 27 | -1% | 9% | | |
| 10 to 15 | 4% | 27 | -1% | 9% | | |
| 15 to 20 | 33% | 27 | 21% | 45% | | |
| 20 to 30 | 22% | 27 | 12% | 33% | | |
| Greater than 30 | 11% | 27 | 3% | 19% | | |
| Unknown | 26% | 27 | 15% | 37% | | |

Table A-45
Below Ground Exterior Wall Insulation Level (Premise)

| Below Ground Wall Insulation (R-Value) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|-------------------------------|-------------------------------|
| Average R-Value | 9 | 27 | 6 | 12 |
| Less than 10 | 19% | 27 | 9% | 29% |
| 10 to 15 | 7% | 27 | 1% | 14% |
| 15 to 20 | 4% | 27 | -1% | 9% |
| 20 to 30 | 4% | 27 | -1% | 9% |
| Greater than 30 | 0% | 27 | 0% | 0% |
| No Below Ground Walls | 44% | 27 | 32% | 57% |
| Unknown | 22% | 27 | 12% | 33% |



A.4.2.2. Windows

Table A-46
Percent of Wall Area Glazed (Premise)

| Percent of Wall Area Glazed (Percent) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------|---------|------------|-------------------------------|-------------------------------|
| Average Percent of Wall area Glazed | 19% | 27 | 15% | 23% |
| None | 7% | 27 | 1% | 14% |
| Less than 10 Percent | 15% | 27 | 6% | 24% |
| 10 to 20 | 33% | 27 | 21% | 45% |
| 20 to 30 | 26% | 27 | 15% | 37% |
| 30 to 40 | 4% | 27 | -1% | 9% |
| Greater than 40 | 11% | 27 | 3% | 19% |
| Unknown | 4% | 27 | -1% | 9% |

Table A-47
Window Glaze Types (Premise)

| Glaze Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------|---------|------------|-------------------------------|-------------------------------|
| Single | 4% | 27 | -1% | 9% |
| Double | 78% | 27 | 67% | 88% |
| Triple | 7% | 27 | 1% | 14% |
| Not Applicable | 7% | 27 | 1% | 14% |
| Unknown | 4% | 27 | -1% | 9% |

Table A-48
Window Treatment Types (Premise)

| Window Treatment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|-------------------------------|-------------------------------|
| Clear | 33% | 27 | 21% | 45% |
| Tinted | 0% | 27 | 0% | 0% |
| Reflective | 0% | 27 | 0% | 0% |
| Gas-Filled | 15% | 27 | 6% | 24% |
| Low E | 37% | 27 | 25% | 49% |
| Opaque | 0% | 27 | 0% | 0% |
| Unknown | 15% | 27 | 6% | 24% |



A.4.2.3. Roofs

Table A-49 Roof Size (Premise)

| 11001 0120 (1.10111100) | | | | | | | | | |
|-------------------------|---------|------------|-------------------------------|-------------------------------|--|--|--|--|--|
| Roof Size (Square Feet) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | | | | |
| Average Roof Size | 12,075 | 27 | 9,278 | 14,872 | | | | | |
| Less than 5,000 | 33% | 27 | 21% | 45% | | | | | |
| 5,000 to 10,000 | 11% | 27 | 3% | 19% | | | | | |
| 10,000 to 15,000 | 26% | 27 | 15% | 37% | | | | | |
| 15000 to 20,000 | 7% | 27 | 1% | 14% | | | | | |
| 20,000 to 25,0000 | 11% | 27 | 3% | 19% | | | | | |
| Greater than 25,000 | 7% | 27 | 1% | 14% | | | | | |
| Unknown | 4% | 27 | -1% | 9% | | | | | |

Table A-50 Roof Configuration (Premise)

| Roof Configuration | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
|--------------------|---------|------------|-------------------------------|-------------------------------|--|
| Flat | 22% | 27 | 12% | 33% | |
| Pitched | 78% | 27 | 67% | 88% | |
| Interior Space | 0% | 27 | 0% | 0% | |

Table A-51
Roof Deck Material (Premise)

| Roof Deck Material | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
|--------------------|---------|------------|-------------------------------|-------------------------------|--|
| Concrete | 4% | 27 | -1% | 9% | |
| Wood | 52% | 27 | 39% | 65% | |
| Metal | 30% | 27 | 18% | 41% | |
| Other | 4% | 27 | -1% | 9% | |
| Unknown | 11% | 27 | 3% | 19% | |

Table A-52
Roof Surface Material (Premise)

| Roof Surface Material | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|-------------------------------|-------------------------------|
| Shingles/Felt | 37% | 27 | 25% | 49% |
| Built-Up | 4% | 27 | -1% | 9% |
| Membrane | 15% | 27 | 6% | 24% |
| Other | 37% | 27 | 25% | 49% |
| Unknown | 7% | 27 | 1% | 14% |



Table A-53
Roof Insulation Types (Premise)

| Roof Insulation Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
|----------------------|---------|------------|-------------------------------|-------------------------------|--|
| None | 4% | 27 | -1% | 9% | |
| Rigid | 22% | 27 | 12% | 33% | |
| Batt/Blown | 41% | 27 | 28% | 53% | |
| Other | 15% | 27 | 6% | 24% | |
| Unknown | 19% | 27 | 9% | 29% | |

Table A-54
Roof Insulation Level (Premise)

| Roof Insulation (R-Value) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|-------------------------------|-------------------------------|
| Average R-Value | 37 | 27 | 33 | 41 |
| Less than 20 | 7% | 27 | 1% | 14% |
| 20 to 30 | 4% | 27 | -1% | 9% |
| 30 to 40 | 26% | 27 | 15% | 37% |
| 40 to 50 | 15% | 27 | 6% | 24% |
| Greater than 50 | 11% | 27 | 3% | 19% |
| Unknown | 37% | 27 | 25% | 49% |

A.4.2.4. Building Envelope Energy Efficiency Opportunities

Table A-55
Building Envelope Energy Efficiency Opportunities (Premise)

| Energy Efficincy Opportunities | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
|--------------------------------|---------|------------|-------------------------------|-------------------------------|--|
| Add Wall Insulation | 11% | 27 | 3% | 19% | |
| Cool Roof | 7% | 27 | 1% | 14% | |
| Add Roof Insulation | 7% | 27 | 1% | 14% | |





Appendix B: Indoor Lighting

B.1. Types of Indoor Lighting

B.1.1. Square Foot Weighted Results

Table B-1
Types of Indoor Lighting (Square Foot)

| Types of indoor Lighting (Square Foot) | | | | | | | | | |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|--|--|--|--|--|
| Light Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | | | | |
| Incandescent | 36% | 26 | 23% | 48% | | | | | |
| CFL | 57% | 26 | 43% | 70% | | | | | |
| HID | 3% | 26 | 0% | 7% | | | | | |
| T5 | 30% | 26 | 15% | 45% | | | | | |
| Standard T8 | 39% | 26 | 27% | 51% | | | | | |
| High Performance T8 | 20% | 26 | 11% | 30% | | | | | |
| T12 | 3% | 26 | 0% | 7% | | | | | |
| Quartz | 5% | 26 | 0% | 11% | | | | | |
| Other Fluorescent | 19% | 26 | 7% | 32% | | | | | |
| Unknown Fluorescent Tube | 10% | 26 | 2% | 19% | | | | | |
| Other | 25% | 26 | 15% | 34% | | | | | |
| Unknown T8 | 5% | 26 | 1% | 8% | | | | | |

B.1.2. Premise Weighted Results

Table B-2
Types of Indoor Lighting (Premise)

| | | | Lower 80% | Upper 80% |
|--------------------------|---------|------------|------------|------------|
| Light Type | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| Incandescent | 46% | 26 | 33% | 59% |
| CFL | 58% | 26 | 45% | 71% |
| HID | 12% | 26 | 3% | 20% |
| T5 | 42% | 26 | 29% | 55% |
| Standard T8 | 46% | 26 | 33% | 59% |
| High Performance T8 | 35% | 26 | 22% | 47% |
| T12 | 12% | 26 | 3% | 20% |
| Quartz | 8% | 26 | 1% | 15% |
| Other Fluorescent | 27% | 26 | 15% | 39% |
| Unknown Fluorescent Tube | 19% | 26 | 9% | 30% |
| Other | 38% | 26 | 26% | 51% |
| Unknown T8 | 19% | 26 | 9% | 30% |



Lighting Densities

Table B-3 **Default Values Used For Missing Data**

| 1110 | | |
|---------------------------|----------|----------|
| | Magnetic | Electron |
| Lamp Quantity per ballast | 1 | |
| MH or HPS <=100W | 90 | NA |
| 250W MH HID | 295 | 2 |
| 320W MH HID | 365 | 3 |
| | | |

270 345 375 350W MH HID 400W MH HID 250W HPS HID 295 NA 310W HPS HID 365 NA 400W HPS HID 465 NA

Source: Efficiency Vermont Technical Reference User Manual No. 2008-53 Source: Advance Atlas 2008-2009, based on 277V systems

ΗΙΝ

| Magnetic | | | Magnetic Energy Saving | | | Electronic | | | | | | |
|---------------------------|----|----|------------------------|----|----|------------|----|----|----|----|----|-----|
| Lamp Quantity per ballast | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 |
| CFL <20W | 15 | 35 | NA | NA | NA | NA | NA | NA | 14 | 27 | NA | NA |
| CFL >=20W | 29 | 50 | NA | NA | NA | NA | NA | NA | 27 | 51 | NA | NA |
| Dimming CFL <20W | 20 | NA | NA | NA | NA | NA | NA | NA | 18 | 33 | 86 | 112 |
| Dimming CFL >=20W | 25 | NA | NA | NA | NA | NA | NA | NA | 31 | 58 | NA | NA |

Source: Efficiency Vermont Technical Reference User Manual No. 2008-53 Source: Advance Atlas 2008-2009, based on 277V systems

Source: Advance Atlas 2008-2009, based on 277V systems (assumed 13W lamps for <20W and 26W lamps for >=20W)

| | Magnetic | | | | Magnetic Energy Saving | | | | Electronic | | | | |
|---------------------------|----------|----|----|----|------------------------|----|----|-----|------------|----|-----|-----|-----|
| Lamp Quantity per ballast | | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 |
| T5 | NA | | NA | NA | NA | NA | NA | NA | NA | 32 | 64 | 96 | 128 |
| T5HO | NA | | NA | NA | NA | NA | NA | NA | NA | 62 | 117 | 179 | 234 |
| T8 | | 41 | 76 | NA | NA | NA | NA | NA | NA | 29 | 55 | 86 | 112 |
| HPT8 | NA | | NA | NA | NA | NA | NA | NA | NA | 28 | 59 | 87 | 108 |
| T10 | | 53 | 88 | NA | NA | NA | NA | NA | NA | 35 | 71 | 112 | NA |
| T12 | | 50 | 86 | NA | 172 | 43 | 72 | 103 | 144 | 35 | 71 | 107 | NA |

Source: Efficiency Vermont Technical Reference User Manual No. 2008-53 Source: Advance Atlas 2008-2009, based on 277V systems Average wattage based on CEE Approved ballasts

Operating Hours

| op or atting riotal o | |
|-----------------------|--------|
| | Annual |
| Building Type | Hours |
| Office | 3435 |
| Restaurant | 4156 |
| Retail | 3068 |
| Grocery/Supermarket | 4612 |
| Warehouse | 2388 |
| Elem/Sec School | 2080 |
| College | 5010 |
| Health | 3392 |
| Hospital | 4532 |
| Hotel/Motel | 2697 |
| Manufacturing | 3500 |
| Other/misc. | 2278 |

Source: Efficiency Vermont Technical Reference User Manual No. 2008-53

Table B-4 **Overall Light Density**

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|--------|------------|----------------------------------|--------|
| Lighting Power Density (W/sqft) | 0.88 | 26 | 0.68 | 1.09 |
| Total Lighting kWh per Premise | 38,884 | 26 | 29,908 | 47,861 |
| Watts per Fixture | 52 | 25 | 24 | 80 |



Table B-5 Incandescent Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|--------|------------|----------------------------------|----------------------------------|
| Lighting Power Density (W/sqft) | 0.44 | 11 | 0.31 | 0.57 |
| Total Lighting kWh per Premise | 11,052 | 11 | 4,841 | 17,264 |
| Watts per Fixture | 90 | 11 | 82 | 97 |

Table B-6 CFL Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|-------|------------|----------------------------------|--------|
| Lighting Power Density (W/sqft) | 0.15 | 14 | 0.12 | 0.18 |
| Total Lighting kWh per Premise | 7,082 | 14 | 3,628 | 10,535 |
| Watts per Fixture | 32 | 14 | 30 | 34 |

Table B-7
HID Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|-------|------------|----------------------------------|----------------------------------|
| Lighting Power Density (W/sqft) | 1.46 | 1 | 1.46 | 1.46 |
| Total Lighting kWh per Premise | 7,665 | 1 | 7,665 | 7,665 |
| Watts per Fixture | 175 | 1 | 175 | 175 |

Table B-8
T5 Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|--------|------------|----------------------------------|----------------------------------|
| Lighting Power Density (W/sqft) | 0.73 | 10 | 0.33 | 1.13 |
| Total Lighting kWh per Premise | 19,057 | 10 | 8,844 | 29,269 |
| Watts per Fixture | 241 | 10 | 174 | 307 |

Table B-9
Standard T8 Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|--------|------------|----------------------------------|--------|
| Lighting Power Density (W/sqft) | 0.26 | 8 | 0.07 | 0.44 |
| Total Lighting kWh per Premise | 11,878 | 8 | 6,472 | 17,284 |
| Watts per Fixture | 70 | 8 | 54 | 85 |



Table B-10 HP T8 Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|--------|------------|----------------------------------|----------------------------------|
| Lighting Power Density (W/sqft) | 0.38 | 7 | 0.27 | 0.49 |
| Total Lighting kWh per Premise | 13,748 | 7 | 7,676 | 19,820 |
| Watts per Fixture | 71 | 7 | 61 | 80 |

Table B-11
Unknown T8 Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|-------|------------|----------------------------------|-------|
| Lighting Power Density (W/sqft) | 0.47 | 5 | 0.26 | 0.67 |
| Total Lighting kWh per Premise | 4,340 | 5 | 1,523 | 7,156 |
| Watts per Fixture | 47 | 5 | 38 | 57 |

Table B-12 T12 Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|------|------------|----------------------------------|------|
| Lighting Power Density (W/sqft) | 0.02 | 1 | 0.02 | 0.02 |
| Total Lighting kWh per Premise | 431 | 1 | 431 | 431 |
| Watts per Fixture | 38 | 1 | 38 | 38 |

Table B-13
Unknown Fluorescent Tube Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|--------|------------|----------------------------------|--------|
| Lighting Power Density (W/sqft) | 0.46 | 3 | 0.05 | 0.86 |
| Total Lighting kWh per Premise | 31,754 | 3 | 2,525 | 60,984 |
| Watts per Fixture | 24 | 3 | 19 | 29 |

Table B-14
Other Fluorescent Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | • • |
|---------------------------------|-------|------------|----------------------------------|-------|
| Lighting Power Density (W/sqft) | 0.13 | 5 | 0.05 | 0.22 |
| Total Lighting kWh per Premise | 2,684 | 5 | 1,563 | 3,804 |
| Watts per Fixture | 49 | 5 | 42 | 56 |



Table B-15 Other Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|-------|------------|----------------------------------|----------------------------------|
| Lighting Power Density (W/sqft) | 0.05 | 6 | (0.00) | 0.10 |
| Total Lighting kWh per Premise | 1,100 | 5 | 727 | 1,472 |
| Watts per Fixture | 23 | 6 | 14 | 33 |

Table B-16
Quartz Light Density

| Statistic | Mean | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|------|------------|----------------------------------|----------------------------------|
| Lighting Power Density (W/sqft) | 0.07 | 2 | 0.03 | 0.12 |
| Total Lighting kWh per Premise | 733 | 2 | 689 | 778 |
| Watts per Fixture | 50 | 2 | 50 | 50 |

B.3. Square Foot Weighted Results

B.3.1. Usage

Table B-17
Overall Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 97% | 25 | 95% | 99% |
| Task | 0% | 25 | 0% | 0% |
| Exit | 2% | 25 | 0% | 3% |
| Display | 1% | 25 | -1% | 3% |
| Other | 0% | 25 | 0% | 0% |
| Unknown | 0% | 25 | 0% | 0% |

Table B-18
Incandescent Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 99% | 11 | 98% | 100% |
| Task | 1% | 11 | 0% | 1% |
| Exit | 0% | 11 | 0% | 0% |
| Display | 0% | 11 | 0% | 1% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-19
CFL Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 99% | 15 | 97% | 101% |
| Task | 0% | 15 | 0% | 0% |
| Exit | 0% | 15 | 0% | 0% |
| Display | 1% | 15 | -1% | 3% |
| Other | 0% | 15 | 0% | 0% |
| Unknown | 0% | 15 | 0% | 0% |

Table B-20 HID Light Usage (Square Foot)

| ins signit sough (equal or sou) | | | | |
|---------------------------------|---------|------------|----------------------------------|----------------------------------|
| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Area | 92% | 3 | 79% | 105% |
| Task | 0% | 3 | 0% | 0% |
| Exit | 0% | 3 | 0% | 0% |
| Display | 8% | 3 | -5% | 21% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-21
T5 Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 11 | 100% | 100% |
| Task | 0% | 11 | 0% | 0% |
| Exit | 0% | 11 | 0% | 0% |
| Display | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-22 Standard T8 Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 12 | 100% | 100% |
| Task | 0% | 12 | 0% | 0% |
| Exit | 0% | 12 | 0% | 0% |
| Display | 0% | 12 | 0% | 0% |
| Other | 0% | 12 | 0% | 0% |
| Unknown | 0% | 12 | 0% | 0% |

Table B-23
HP T8 Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 8 | 100% | 100% |
| Task | 0% | 8 | 0% | 0% |
| Exit | 0% | 8 | 0% | 0% |
| Display | 0% | 8 | 0% | 0% |
| Other | 0% | 8 | 0% | 0% |
| Unknown | 0% | 8 | 0% | 0% |

Table B-24
Unknown T8 Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 99% | 5 | 98% | 100% |
| Task | 1% | 5 | 0% | 2% |
| Exit | 0% | 5 | 0% | 0% |
| Display | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-25
T12 Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 23% | 3 | -8% | 53% |
| Task | 77% | 3 | 47% | 108% |
| Exit | 0% | 3 | 0% | 0% |
| Display | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-26

Unknown Fluorescent Tube Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 5 | 100% | 100% |
| Task | 0% | 5 | 0% | 0% |
| Exit | 0% | 5 | 0% | 0% |
| Display | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |

Table B-27
Other Fluorescent Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 7 | 100% | 100% |
| Task | 0% | 7 | 0% | 0% |
| Exit | 0% | 7 | 0% | 0% |
| Display | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |
| Unknown | 0% | 7 | 0% | 0% |



Table B-28
Other Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 8% | 10 | -3% | 19% |
| Task | 0% | 10 | 0% | 1% |
| Exit | 67% | 10 | 32% | 102% |
| Display | 25% | 10 | -7% | 56% |
| Other | 0% | 10 | 0% | 0% |
| Unknown | 0% | 10 | 0% | 0% |

Table B-29
Quartz Light Usage (Square Foot)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| | | _ | | |
| Area | 0% | 2 | 0% | 0% |
| Task | 0% | 2 | 0% | 0% |
| Exit | 0% | 2 | 0% | 0% |
| Display | 100% | 2 | 100% | 100% |
| Other | 0% | 2 | 0% | 0% |
| Unknown | 0% | 2 | 0% | 0% |

B.3.2. Ballast Types

Table B-30
Overall Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 25 | 0% | 0% |
| Energy Saving Magnetic | 0% | 25 | 0% | 1% |
| Electronic | 49% | 25 | 36% | 63% |
| Other | 0% | 25 | 0% | 0% |
| No Ballast | 50% | 25 | 37% | 64% |
| Unknown | 0% | 25 | 0% | 0% |



Table B-31
CFL Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 15 | 0% | 0% |
| Energy Saving Magnetic | 0% | 15 | 0% | 0% |
| Electronic | 84% | 15 | 70% | 97% |
| Other | 0% | 15 | 0% | 0% |
| No Ballast | 16% | 15 | 3% | 30% |
| Unknown | 0% | 15 | 0% | 0% |

Table B-32
HID Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 3 | 0% | 0% |
| Energy Saving Magnetic | 85% | 3 | 64% | 106% |
| Electronic | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| No Ballast | 15% | 3 | -6% | 36% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-33
T5 Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 11 | 0% | 1% |
| Energy Saving Magnetic | 0% | 11 | 0% | 0% |
| Electronic | 52% | 11 | 13% | 90% |
| Other | 0% | 11 | 0% | 0% |
| No Ballast | 48% | 11 | 10% | 87% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-34
Standard T8 Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 12 | 0% | 0% |
| Energy Saving Magnetic | 5% | 12 | -2% | 11% |
| Electronic | 75% | 12 | 56% | 94% |
| Other | 0% | 12 | 0% | 0% |
| No Ballast | 20% | 12 | 2% | 38% |
| Unknown | 0% | 12 | 0% | 0% |

Table B-35
HP T8 Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 8 | 0% | 0% |
| Energy Saving Magnetic | 0% | 8 | 0% | 0% |
| Electronic | 100% | 8 | 100% | 100% |
| Other | 0% | 8 | 0% | 0% |
| No Ballast | 0% | 8 | 0% | 0% |
| Unknown | 0% | 8 | 0% | 0% |

Table B-36
Unknown T8 Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 5 | 0% | 0% |
| Energy Saving Magnetic | 0% | 5 | 0% | 0% |
| Electronic | 100% | 5 | 100% | 100% |
| Other | 0% | 5 | 0% | 0% |
| No Ballast | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-37
T12 Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 5% | 3 | -3% | 13% |
| Energy Saving Magnetic | 0% | 3 | 0% | 0% |
| Electronic | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| No Ballast | 95% | 3 | 87% | 103% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-38
Unknown Fluorescent Tube Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 5 | 0% | 0% |
| Energy Saving Magnetic | 0% | 5 | 0% | 0% |
| Electronic | 100% | 5 | 99% | 100% |
| Other | 0% | 5 | 0% | 0% |
| No Ballast | 0% | 5 | 0% | 1% |
| Unknown | 0% | 5 | 0% | 0% |

Table B-39
Other Fluorescent Light Ballast Types (Square Foot)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 7 | 0% | 0% |
| Energy Saving Magnetic | 0% | 7 | 0% | 0% |
| Electronic | 2% | 7 | 1% | 4% |
| Other | 0% | 7 | 0% | 0% |
| No Ballast | 98% | 7 | 96% | 99% |
| Unknown | 0% | 7 | 0% | 0% |



B.3.3. Control Types

Table B-40
Overall Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 82% | 25 | 72% | 92% |
| Dimmer | 2% | 25 | -1% | 4% |
| Motion/Occupancy Sensor | 9% | 25 | 2% | 15% |
| Photocell | 0% | 25 | 0% | 0% |
| Timeclock | 0% | 25 | 0% | 0% |
| Photocell/Timeclock | 0% | 25 | 0% | 0% |
| Photocell with Dimming | 0% | 25 | 0% | 0% |
| EMS | 5% | 25 | -1% | 11% |
| None/Continuous | 3% | 25 | 1% | 6% |
| Other | 0% | 25 | 0% | 0% |
| Unknown | 0% | 25 | 0% | 0% |

Table B-41
Incandescent Light Control Types (Square Foot)

| Incandescent Light Control Types (Square Foot) | | | | |
|------------------------------------------------|---------|------------|-------------------------|-------------------------|
| Control Type | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence |
| | | | Limit | Limit |
| Manual On/Off Switch | 98% | 11 | 95% | 101% |
| Dimmer | 2% | 11 | -1% | 5% |
| Motion/Occupancy Sensor | 0% | 11 | 0% | 0% |
| Photocell | 0% | 11 | 0% | 0% |
| Timeclock | 0% | 11 | 0% | 0% |
| Photocell/Timeclock | 0% | 11 | 0% | 0% |
| Photocell with Dimming | 0% | 11 | 0% | 0% |
| EMS | 0% | 11 | 0% | 0% |
| None/Continuous | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-42
CFL Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 93% | 15 | 89% | 98% |
| Dimmer | 2% | 15 | -1% | 5% |
| Motion/Occupancy Sensor | 3% | 15 | 1% | 5% |
| Photocell | 0% | 15 | 0% | 0% |
| Timeclock | 0% | 15 | 0% | 0% |
| Photocell/Timeclock | 0% | 15 | 0% | 0% |
| Photocell with Dimming | 0% | 15 | 0% | 0% |
| EMS | 2% | 15 | -1% | 4% |
| None/Continuous | 0% | 15 | 0% | 0% |
| Other | 0% | 15 | 0% | 0% |
| Unknown | 0% | 15 | 0% | 0% |

Table B-43
HID Light Control Types (Square Foot)

| | T | | Lower 80% | Upper 80% |
|-------------------------|---------|------------|---------------------|---------------------|
| Control Type | Percent | # of Cases | Confidence Limit | Confidence Limit |
| Manual On/Off Switch | 15% | 3 | -6% | 36% |
| Dimmer | 0% | 3 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 3 | 0% | 0% |
| Photocell | 85% | 3 | 64% | 106% |
| Timeclock | 0% | 3 | 0% | 0% |
| Photocell/Timeclock | 0% | 3 | 0% | 0% |
| Photocell with Dimming | 0% | 3 | 0% | 0% |
| EMS | 0% | 3 | 0% | 0% |
| None/Continuous | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |



Table B-44
T5 Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 39% | 11 | 11% | 68% |
| Dimmer | 0% | 11 | 0% | 0% |
| Motion/Occupancy Sensor | 13% | 11 | 0% | 25% |
| Photocell | 0% | 11 | 0% | 0% |
| Timeclock | 0% | 11 | 0% | 0% |
| Photocell/Timeclock | 0% | 11 | 0% | 0% |
| Photocell with Dimming | 0% | 11 | 0% | 0% |
| EMS | 48% | 11 | 10% | 87% |
| None/Continuous | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |

Table B-45
Standard T8 Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 86% | 12 | 70% | 101% |
| Dimmer | 0% | 12 | 0% | 0% |
| Motion/Occupancy Sensor | 1% | 12 | 0% | 2% |
| Photocell | 0% | 12 | 0% | 0% |
| Timeclock | 0% | 12 | 0% | 0% |
| Photocell/Timeclock | 0% | 12 | 0% | 0% |
| Photocell with Dimming | 0% | 12 | 0% | 0% |
| EMS | 14% | 12 | -1% | 29% |
| None/Continuous | 0% | 12 | 0% | 0% |
| Other | 0% | 12 | 0% | 0% |
| Unknown | 0% | 12 | 0% | 0% |



Table B-46
HP T8 Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 15% | 8 | -3% | 33% |
| Dimmer | 0% | 8 | 0% | 0% |
| Motion/Occupancy Sensor | 72% | 8 | 57% | 88% |
| Photocell | 0% | 8 | 0% | 0% |
| Timeclock | 0% | 8 | 0% | 0% |
| Photocell/Timeclock | 0% | 8 | 0% | 0% |
| Photocell with Dimming | 0% | 8 | 0% | 0% |
| EMS | 0% | 8 | 0% | 0% |
| None/Continuous | 13% | 8 | 10% | 16% |
| Other | 0% | 8 | 0% | 0% |
| Unknown | 0% | 8 | 0% | 0% |

Table B-47
Unknown T8 Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 82% | 5 | 74% | 90% |
| Dimmer | 0% | 5 | 0% | 0% |
| Motion/Occupancy Sensor | 18% | 5 | 10% | 26% |
| Photocell | 0% | 5 | 0% | 0% |
| Timeclock | 0% | 5 | 0% | 0% |
| Photocell/Timeclock | 0% | 5 | 0% | 0% |
| Photocell with Dimming | 0% | 5 | 0% | 0% |
| EMS | 0% | 5 | 0% | 0% |
| None/Continuous | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-48
T12 Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 100% | 3 | 100% | 100% |
| Dimmer | 0% | 3 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 3 | 0% | 0% |
| Photocell | 0% | 3 | 0% | 0% |
| Timeclock | 0% | 3 | 0% | 0% |
| Photocell/Timeclock | 0% | 3 | 0% | 0% |
| Photocell with Dimming | 0% | 3 | 0% | 0% |
| EMS | 0% | 3 | 0% | 0% |
| None/Continuous | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-49
Unknown Fluorescent Tube Light Control Types (Square Foot)

| | | | Lower 80% | Upper 80% |
|-------------------------|---------|------------|------------|------------|
| Control Type | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| Manual On/Off Switch | 100% | 5 | 100% | 100% |
| Dimmer | 0% | 5 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 5 | 0% | 0% |
| Photocell | 0% | 5 | 0% | 0% |
| Timeclock | 0% | 5 | 0% | 0% |
| Photocell/Timeclock | 0% | 5 | 0% | 0% |
| Photocell with Dimming | 0% | 5 | 0% | 0% |
| EMS | 0% | 5 | 0% | 0% |
| None/Continuous | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-50
Other Fluorescent Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 94% | 7 | 84% | 104% |
| Dimmer | 0% | 7 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 7 | 0% | 0% |
| Photocell | 0% | 7 | 0% | 0% |
| Timeclock | 0% | 7 | 0% | 0% |
| Photocell/Timeclock | 0% | 7 | 0% | 0% |
| Photocell with Dimming | 0% | 7 | 0% | 0% |
| EMS | 6% | 7 | -4% | 15% |
| None/Continuous | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |
| Unknown | 0% | 7 | 0% | 1% |

Table B-51
Other Light Control Types (Square Foot)

| other Light control Types (equale 1 cot) | | | | |
|------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Manual On/Off Switch | 8% | 10 | -2% | 19% |
| Dimmer | 25% | 10 | -7% | 56% |
| Motion/Occupancy Sensor | 0% | 10 | 0% | 0% |
| Photocell | 0% | 10 | 0% | 0% |
| Timeclock | 0% | 10 | 0% | 0% |
| Photocell/Timeclock | 0% | 10 | 0% | 0% |
| Photocell with Dimming | 0% | 10 | 0% | 0% |
| EMS | 0% | 10 | 0% | 0% |
| None/Continuous | 67% | 10 | 32% | 102% |
| Other | 0% | 10 | 0% | 0% |
| Unknown | 0% | 10 | 0% | 0% |



Table B-52
Quartz Light Control Types (Square Foot)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 8% | 2 | -6% | 23% |
| Dimmer | 92% | 2 | 77% | 106% |
| Motion/Occupancy Sensor | 0% | 2 | 0% | 0% |
| Photocell | 0% | 2 | 0% | 0% |
| Timeclock | 0% | 2 | 0% | 0% |
| Photocell/Timeclock | 0% | 2 | 0% | 0% |
| Photocell with Dimming | 0% | 2 | 0% | 0% |
| EMS | 0% | 2 | 0% | 0% |
| None/Continuous | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |
| Unknown | 0% | 2 | 0% | 0% |

B.4. Premise Weighted Results

B.4.1. Usage

Table B-53
Overall Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 96% | 25 | 92% | 100% |
| Task | 1% | 25 | 0% | 1% |
| Exit | 1% | 25 | 0% | 2% |
| Display | 3% | 25 | -1% | 6% |
| Other | 0% | 25 | 0% | 0% |
| Unknown | 0% | 25 | 0% | 0% |

Table B-54
Incandescent Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 94% | 11 | 87% | 100% |
| Task | 4% | 11 | -1% | 10% |
| Exit | 0% | 11 | 0% | 0% |
| Display | 1% | 11 | -1% | 3% |
| Other | 1% | 11 | 0% | 2% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-55
CFL Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 96% | 15 | 91% | 101% |
| Task | 0% | 15 | 0% | 0% |
| Exit | 1% | 15 | 0% | 2% |
| Display | 4% | 15 | -1% | 8% |
| Other | 0% | 15 | 0% | 0% |
| Unknown | 0% | 15 | 0% | 0% |

Table B-56
HID Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 88% | 3 | 69% | 106% |
| Task | 0% | 3 | 0% | 0% |
| Exit | 0% | 3 | 0% | 0% |
| Display | 13% | 3 | -6% | 31% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-57
T5 Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 11 | 100% | 100% |
| Task | 0% | 11 | 0% | 0% |
| Exit | 0% | 11 | 0% | 0% |
| Display | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-58
Standard T8 Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 12 | 100% | 100% |
| Task | 0% | 12 | 0% | 0% |
| Exit | 0% | 12 | 0% | 0% |
| Display | 0% | 12 | 0% | 0% |
| Other | 0% | 12 | 0% | 0% |
| Unknown | 0% | 12 | 0% | 0% |

Table B-59
HP T8 Light Usage (Premise)

| Til To Light Osage (Freinise) | | | | |
|-------------------------------|---------|------------|------------|------------|
| | | | Lower 80% | Upper 80% |
| Usage | Percent | # of Cases | Confidence | Confidence |
| _ | | | Limit | Limit |
| Area | 100% | 8 | 100% | 100% |
| Task | 0% | 8 | 0% | 0% |
| Exit | 0% | 8 | 0% | 0% |
| Display | 0% | 8 | 0% | 0% |
| Other | 0% | 8 | 0% | 0% |
| Unknown | 0% | 8 | 0% | 0% |

Table B-60 Unknown T8 Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 98% | 5 | 95% | 101% |
| Task | 2% | 5 | -1% | 5% |
| Exit | 0% | 5 | 0% | 0% |
| Display | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-61
T12 Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 41% | 3 | 0% | 82% |
| Task | 59% | 3 | 18% | 100% |
| Exit | 0% | 3 | 0% | 0% |
| Display | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-62
Unknown Fluorescent Tube Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 5 | 100% | 100% |
| Task | 0% | 5 | 0% | 0% |
| Exit | 0% | 5 | 0% | 0% |
| Display | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |

Table B-63
Other Fluorescent Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 100% | 7 | 100% | 100% |
| Task | 0% | 7 | 0% | 0% |
| Exit | 0% | 7 | 0% | 0% |
| Display | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |
| Unknown | 0% | 7 | 0% | 0% |



Table B-64
Other Light Usage (Premise)

| Usage | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------|---------|------------|----------------------------------|----------------------------------|
| Area | 16% | 10 | 0% | 33% |
| Task | 2% | 10 | -1% | 5% |
| Exit | 35% | 10 | 6% | 63% |
| Display | 47% | 10 | 10% | 83% |
| Other | 0% | 10 | 0% | 1% |
| Unknown | 0% | 10 | 0% | 0% |

Table B-65
Quartz Light Usage (Premise)

| Quartz Light Osage (Fremise) | | | | | |
|------------------------------|---------|------------|------------|------------|--|
| | | | Lower 80% | Upper 80% | |
| Usage | Percent | # of Cases | Confidence | Confidence | |
| | | | Limit | Limit | |
| Area | 0% | 2 | 0% | 0% | |
| Task | 0% | 2 | 0% | 0% | |
| Exit | 0% | 2 | 0% | 0% | |
| Display | 100% | 2 | 100% | 100% | |
| Other | 0% | 2 | 0% | 0% | |
| Unknown | 0% | 2 | 0% | 0% | |

B.4.2. Ballast Types

Table B-66
Overall Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 25 | 0% | 0% |
| Energy Saving Magnetic | 1% | 25 | 0% | 2% |
| Electronic | 40% | 25 | 29% | 51% |
| Other | 0% | 25 | 0% | 0% |
| No Ballast | 58% | 25 | 47% | 70% |
| Unknown | 0% | 25 | 0% | 0% |



Table B-67
CFL Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 15 | 0% | 0% |
| Energy Saving Magnetic | 0% | 15 | 0% | 0% |
| Electronic | 64% | 15 | 45% | 83% |
| Other | 0% | 15 | 0% | 0% |
| No Ballast | 36% | 15 | 17% | 55% |
| Unknown | 0% | 15 | 0% | 0% |

Table B-68

HID Light Ballast Types (Premise) Upper 80% Lower 80% **Ballast Type** Percent # of Cases Confidence Confidence Limit Limit Standard Magnetic 0% 3 0% 0% Energy Saving Magnetic 63% 3 23% 102% Electronic 0% 3 0% 0% Other 0% 3 0% 0% No Ballast 38% 3 -2% 77% Unknown 0% 3 0% 0%

Table B-69
T5 Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 1% | 11 | -1% | 3% |
| Energy Saving Magnetic | 0% | 11 | 0% | 0% |
| Electronic | 67% | 11 | 35% | 98% |
| Other | 0% | 11 | 0% | 0% |
| No Ballast | 32% | 11 | 0% | 64% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-70
Standard T8 Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 12 | 0% | 0% |
| Energy Saving Magnetic | 9% | 12 | -1% | 19% |
| Electronic | 48% | 12 | 24% | 72% |
| Other | 0% | 12 | 0% | 0% |
| No Ballast | 43% | 12 | 15% | 72% |
| Unknown | 0% | 12 | 0% | 0% |

Table B-71
HP T8 Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 8 | 0% | 0% |
| Energy Saving Magnetic | 0% | 8 | 0% | 0% |
| Electronic | 100% | 8 | 100% | 100% |
| Other | 0% | 8 | 0% | 0% |
| No Ballast | 0% | 8 | 0% | 0% |
| Unknown | 0% | 8 | 0% | 0% |

Table B-72
Unknown T8 Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 5 | 0% | 0% |
| Energy Saving Magnetic | 0% | 5 | 0% | 0% |
| Electronic | 100% | 5 | 100% | 100% |
| Other | 0% | 5 | 0% | 0% |
| No Ballast | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-73
T12 Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 12% | 3 | -6% | 29% |
| Energy Saving Magnetic | 0% | 3 | 0% | 0% |
| Electronic | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| No Ballast | 88% | 3 | 71% | 106% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-74
Unknown Fluorescent Tube Light Ballast Types (Premise)

| Olikilowii i idoreseelit Tube Light Ballast Types (i Tellilse) | | | | | |
|----------------------------------------------------------------|---------|------------|------------|------------|--|
| | | | Lower 80% | Upper 80% | |
| Ballast Type | Percent | # of Cases | Confidence | Confidence | |
| | | | Limit | Limit | |
| Standard Magnetic | 0% | 5 | 0% | 0% | |
| Energy Saving Magnetic | 0% | 5 | 0% | 0% | |
| Electronic | 97% | 5 | 93% | 102% | |
| Other | 0% | 5 | 0% | 0% | |
| No Ballast | 3% | 5 | -2% | 7% | |
| Unknown | 0% | 5 | 0% | 0% | |

Table B-75
Other Fluorescent Light Ballast Types (Premise)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 7 | 0% | 0% |
| Energy Saving Magnetic | 0% | 7 | 0% | 0% |
| Electronic | 4% | 7 | 0% | 8% |
| Other | 0% | 7 | 0% | 0% |
| No Ballast | 96% | 7 | 92% | 100% |
| Unknown | 0% | 7 | 0% | 0% |



B.4.3. Control Types

Table B-76
Overall Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 82% | 25 | 70% | 95% |
| Dimmer | 4% | 25 | 0% | 9% |
| Motion/Occupancy Sensor | 4% | 25 | 1% | 8% |
| Photocell | 0% | 25 | 0% | 0% |
| Timeclock | 0% | 25 | 0% | 0% |
| Photocell/Timeclock | 0% | 25 | 0% | 0% |
| Photocell with Dimming | 0% | 25 | 0% | 0% |
| EMS | 7% | 25 | -1% | 15% |
| None/Continuous | 2% | 25 | 0% | 3% |
| Other | 0% | 25 | 0% | 0% |
| Unknown | 0% | 25 | 0% | 0% |

Table B-77
Incandescent Light Control Types (Premise)

| incandescent Light Control Types (Trennse) | | | | |
|--------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Manual On/Off Switch | 83% | 11 | 62% | 104% |
| Dimmer | 16% | 11 | -5% | 37% |
| Motion/Occupancy Sensor | 0% | 11 | 0% | 0% |
| Photocell | 0% | 11 | 0% | 0% |
| Timeclock | 0% | 11 | 0% | 0% |
| Photocell/Timeclock | 0% | 11 | 0% | 0% |
| Photocell with Dimming | 0% | 11 | 0% | 0% |
| EMS | 0% | 11 | 0% | 0% |
| None/Continuous | 0% | 11 | 0% | 0% |
| Other | 1% | 11 | 0% | 2% |
| Unknown | 0% | 11 | 0% | 0% |



Table B-78
CFL Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 88% | 15 | 78% | 98% |
| Dimmer | 6% | 15 | -2% | 15% |
| Motion/Occupancy Sensor | 2% | 15 | 1% | 4% |
| Photocell | 0% | 15 | 0% | 0% |
| Timeclock | 0% | 15 | 0% | 0% |
| Photocell/Timeclock | 0% | 15 | 0% | 0% |
| Photocell with Dimming | 0% | 15 | 0% | 0% |
| EMS | 3% | 15 | -1% | 6% |
| None/Continuous | 1% | 15 | 0% | 2% |
| Other | 0% | 15 | 0% | 0% |
| Unknown | 0% | 15 | 0% | 0% |

Table B-79
HID Light Control Types (Premise)

| The Light Control Types (Fremise) | | | | |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Manual On/Off Switch | 38% | 3 | -2% | 77% |
| Dimmer | 0% | 3 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 3 | 0% | 0% |
| Photocell | 63% | 3 | 23% | 102% |
| Timeclock | 0% | 3 | 0% | 0% |
| Photocell/Timeclock | 0% | 3 | 0% | 0% |
| Photocell with Dimming | 0% | 3 | 0% | 0% |
| EMS | 0% | 3 | 0% | 0% |
| None/Continuous | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |



Table B-80
T5 Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 52% | 11 | 27% | 77% |
| Dimmer | 0% | 11 | 0% | 0% |
| Motion/Occupancy Sensor | 16% | 11 | 3% | 29% |
| Photocell | 0% | 11 | 0% | 0% |
| Timeclock | 0% | 11 | 0% | 0% |
| Photocell/Timeclock | 0% | 11 | 0% | 0% |
| Photocell with Dimming | 0% | 11 | 0% | 0% |
| EMS | 32% | 11 | 0% | 64% |
| None/Continuous | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |

Table B-81
Standard T8 Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 65% | 12 | 35% | 95% |
| Dimmer | 0% | 12 | 0% | 0% |
| Motion/Occupancy Sensor | 2% | 12 | -1% | 4% |
| Photocell | 0% | 12 | 0% | 0% |
| Timeclock | 0% | 12 | 0% | 0% |
| Photocell/Timeclock | 0% | 12 | 0% | 0% |
| Photocell with Dimming | 0% | 12 | 0% | 0% |
| EMS | 33% | 12 | 3% | 63% |
| None/Continuous | 0% | 12 | 0% | 0% |
| Other | 0% | 12 | 0% | 0% |
| Unknown | 0% | 12 | 0% | 0% |



Table B-82
HP T8 Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 50% | 8 | 16% | 85% |
| Dimmer | 0% | 8 | 0% | 0% |
| Motion/Occupancy Sensor | 43% | 8 | 14% | 71% |
| Photocell | 0% | 8 | 0% | 0% |
| Timeclock | 0% | 8 | 0% | 0% |
| Photocell/Timeclock | 0% | 8 | 0% | 0% |
| Photocell with Dimming | 0% | 8 | 0% | 0% |
| EMS | 0% | 8 | 0% | 0% |
| None/Continuous | 7% | 8 | 1% | 12% |
| Other | 0% | 8 | 0% | 0% |
| Unknown | 0% | 8 | 0% | 0% |

Table B-83
Unknown T8 Light Control Types (Premise)

| Olikilowii to Light Colltiol Types (Freilise) | | | | | |
|-----------------------------------------------|---------|------------|----------------------------------|----------------------------------|--|
| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
| Manual On/Off Switch | 84% | 5 | 75% | 93% | |
| Dimmer | 0% | 5 | 0% | 0% | |
| Motion/Occupancy Sensor | 16% | 5 | 7% | 25% | |
| Photocell | 0% | 5 | 0% | 0% | |
| Timeclock | 0% | 5 | 0% | 0% | |
| Photocell/Timeclock | 0% | 5 | 0% | 0% | |
| Photocell with Dimming | 0% | 5 | 0% | 0% | |
| EMS | 0% | 5 | 0% | 0% | |
| None/Continuous | 0% | 5 | 0% | 0% | |
| Other | 0% | 5 | 0% | 0% | |
| Unknown | 0% | 5 | 0% | 0% | |



Table B-84
T12 Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 100% | 3 | 100% | 100% |
| Dimmer | 0% | 3 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 3 | 0% | 0% |
| Photocell | 0% | 3 | 0% | 0% |
| Timeclock | 0% | 3 | 0% | 0% |
| Photocell/Timeclock | 0% | 3 | 0% | 0% |
| Photocell with Dimming | 0% | 3 | 0% | 0% |
| EMS | 0% | 3 | 0% | 0% |
| None/Continuous | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table B-85

Unknown Fluorescent Tube Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 99% | 5 | 98% | 101% |
| Dimmer | 1% | 5 | -1% | 2% |
| Motion/Occupancy Sensor | 0% | 5 | 0% | 0% |
| Photocell | 0% | 5 | 0% | 0% |
| Timeclock | 0% | 5 | 0% | 0% |
| Photocell/Timeclock | 0% | 5 | 0% | 0% |
| Photocell with Dimming | 0% | 5 | 0% | 0% |
| EMS | 0% | 5 | 0% | 0% |
| None/Continuous | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Unknown | 0% | 5 | 0% | 0% |



Table B-86
Other Fluorescent Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 96% | 7 | 89% | 103% |
| Dimmer | 0% | 7 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 7 | 0% | 0% |
| Photocell | 0% | 7 | 0% | 0% |
| Timeclock | 0% | 7 | 0% | 0% |
| Photocell/Timeclock | 0% | 7 | 0% | 0% |
| Photocell with Dimming | 0% | 7 | 0% | 0% |
| EMS | 4% | 7 | -3% | 10% |
| None/Continuous | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |
| Unknown | 1% | 7 | 0% | 1% |

Table B-87
Other Light Control Types (Premise)

| | | | Lower 80% | Upper 80% |
|-------------------------|---------|------------|------------|------------|
| Control Type | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| Manual On/Off Switch | 19% | 10 | 1% | 37% |
| Dimmer | 47% | 10 | 10% | 83% |
| Motion/Occupancy Sensor | 0% | 10 | 0% | 0% |
| Photocell | 0% | 10 | 0% | 0% |
| Timeclock | 0% | 10 | 0% | 0% |
| Photocell/Timeclock | 0% | 10 | 0% | 0% |
| Photocell with Dimming | 0% | 10 | 0% | 0% |
| EMS | 0% | 10 | 0% | 0% |
| None/Continuous | 35% | 10 | 6% | 63% |
| Other | 0% | 10 | 0% | 0% |
| Unknown | 0% | 10 | 0% | 0% |



Table B-88
Quartz Light Control Types (Premise)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 12% | 2 | -8% | 31% |
| Dimmer | 88% | 2 | 69% | 108% |
| Motion/Occupancy Sensor | 0% | 2 | 0% | 0% |
| Photocell | 0% | 2 | 0% | 0% |
| Timeclock | 0% | 2 | 0% | 0% |
| Photocell/Timeclock | 0% | 2 | 0% | 0% |
| Photocell with Dimming | 0% | 2 | 0% | 0% |
| EMS | 0% | 2 | 0% | 0% |
| None/Continuous | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |
| Unknown | 0% | 2 | 0% | 0% |

B.5. Energy Efficient Opportunities

B.5.1. Square Foot Weighted Results

Table B-89
Overall EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 49% | 26 | 29% | 69% |
| Switch to Standard T8 | 4% | 26 | 0% | 7% |
| Switch to High Performance T8 | 38% | 26 | 19% | 57% |
| Switch to T5 | 8% | 26 | 0% | 15% |
| Switch to Pulse Start Metal Halide | 1% | 26 | 0% | 1% |
| Replace Ballasts for Automatic Daylighting | 27% | 26 | 4% | 49% |
| Occupancy Sensors | 77% | 26 | 66% | 89% |
| Dimmers | 15% | 26 | 4% | 26% |
| Other Controls | 4% | 26 | 0% | 7% |
| Other | 2% | 26 | -1% | 4% |



Table B-90 Incandescent EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 86% | 12 | 74% | 98% |
| Switch to Standard T8 | 0% | 12 | 0% | 0% |
| Switch to High Performance T8 | 0% | 12 | 0% | 0% |
| Switch to T5 | 0% | 12 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 1% | 12 | 0% | 2% |
| Replace Ballasts for Automatic Daylighting | 0% | 12 | 0% | 0% |
| Occupancy Sensors | 10% | 12 | -3% | 23% |
| Dimmers | 15% | 12 | 0% | 30% |
| Other Controls | 3% | 12 | -1% | 8% |
| Other | 0% | 12 | 0% | 0% |

Table B-91
CFL EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 15 | 0% | 0% |
| Switch to Standard T8 | 0% | 15 | 0% | 0% |
| Switch to High Performance T8 | 0% | 15 | 0% | 0% |
| Switch to T5 | 0% | 15 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 15 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 15 | 0% | 0% |
| Occupancy Sensors | 42% | 15 | 17% | 67% |
| Dimmers | 0% | 15 | 0% | 0% |
| Other Controls | 2% | 15 | -1% | 6% |
| Other | 0% | 15 | 0% | 0% |



Table B-92
HID EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 3 | 0% | 0% |
| Switch to Standard T8 | 0% | 3 | 0% | 0% |
| Switch to High Performance T8 | 0% | 3 | 0% | 0% |
| Switch to T5 | 60% | 3 | 20% | 100% |
| Switch to Pulse Start Metal Halide | 0% | 3 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 3 | 0% | 0% |
| Occupancy Sensors | 0% | 3 | 0% | 0% |
| Dimmers | 0% | 3 | 0% | 0% |
| Other Controls | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |

Table B-93

T5 EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 11 | 0% | 0% |
| Switch to Standard T8 | 0% | 11 | 0% | 0% |
| Switch to High Performance T8 | 0% | 11 | 0% | 0% |
| Switch to T5 | 0% | 11 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 11 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 11 | 0% | 0% |
| Occupancy Sensors | 56% | 11 | 32% | 80% |
| Dimmers | 15% | 11 | -3% | 34% |
| Other Controls | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |



Table B-94
St T8 EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 12 | 0% | 0% |
| Switch to Standard T8 | 0% | 12 | 0% | 0% |
| Switch to High Performance T8 | 51% | 12 | 22% | 80% |
| Switch to T5 | 4% | 12 | -2% | 9% |
| Switch to Pulse Start Metal Halide | 0% | 12 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 9% | 12 | 0% | 18% |
| Occupancy Sensors | 36% | 12 | 9% | 62% |
| Dimmers | 4% | 12 | 0% | 9% |
| Other Controls | 0% | 12 | 0% | 0% |
| Other | 3% | 12 | -1% | 6% |

Table B-95
HP T8 EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 9 | 0% | 0% |
| Switch to Standard T8 | 0% | 9 | 0% | 0% |
| Switch to High Performance T8 | 0% | 9 | 0% | 0% |
| Switch to T5 | 0% | 9 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 9 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 48% | 9 | 12% | 84% |
| Occupancy Sensors | 83% | 9 | 65% | 101% |
| Dimmers | 0% | 9 | 0% | 0% |
| Other Controls | 0% | 9 | 0% | 0% |
| Other | 0% | 9 | 0% | 0% |



Table B-96
Unknown T8 EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 5 | 0% | 0% |
| Switch to Standard T8 | 0% | 5 | 0% | 0% |
| Switch to High Performance T8 | 0% | 5 | 0% | 0% |
| Switch to T5 | 0% | 5 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 5 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 5 | 0% | 0% |
| Occupancy Sensors | 11% | 5 | -4% | 26% |
| Dimmers | 0% | 5 | 0% | 0% |
| Other Controls | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |

Table B-97
T12 EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 3 | 0% | 0% |
| Switch to Standard T8 | 83% | 3 | 58% | 107% |
| Switch to High Performance T8 | 57% | 3 | 16% | 97% |
| Switch to T5 | 57% | 3 | 16% | 97% |
| Switch to Pulse Start Metal Halide | 0% | 3 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 3 | 0% | 0% |
| Occupancy Sensors | 17% | 3 | -7% | 42% |
| Dimmers | 0% | 3 | 0% | 0% |
| Other Controls | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |



Table B-98
Unknown Fluorescent Tube EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 5 | 0% | 0% |
| Switch to Standard T8 | 0% | 5 | 0% | 0% |
| Switch to High Performance T8 | 38% | 5 | 0% | 75% |
| Switch to T5 | 0% | 5 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 5 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 5 | 0% | 0% |
| Occupancy Sensors | 81% | 5 | 57% | 105% |
| Dimmers | 0% | 5 | 0% | 0% |
| Other Controls | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |

Table B-99
Other Fluorescent EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 7 | 0% | 0% |
| Switch to Standard T8 | 0% | 7 | 0% | 0% |
| Switch to High Performance T8 | 0% | 7 | 0% | 0% |
| Switch to T5 | 0% | 7 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 7 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 7 | 0% | 0% |
| Occupancy Sensors | 22% | 7 | -4% | 47% |
| Dimmers | 13% | 7 | -1% | 27% |
| Other Controls | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |



Table B-100
Other Light Type EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 10 | 0% | 0% |
| Switch to Standard T8 | 0% | 10 | 0% | 0% |
| Switch to High Performance T8 | 0% | 10 | 0% | 0% |
| Switch to T5 | 0% | 10 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 10 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 10 | 0% | 0% |
| Occupancy Sensors | 2% | 10 | -1% | 4% |
| Dimmers | 0% | 10 | 0% | 0% |
| Other Controls | 4% | 10 | -2% | 11% |
| Other | 0% | 10 | 0% | 0% |

Table B-101
Quartz EE Opportunities (Square Foot)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 2 | 0% | 0% |
| Switch to Standard T8 | 0% | 2 | 0% | 0% |
| Switch to High Performance T8 | 0% | 2 | 0% | 0% |
| Switch to T5 | 0% | 2 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 2 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 2 | 0% | 0% |
| Occupancy Sensors | 0% | 2 | 0% | 0% |
| Dimmers | 0% | 2 | 0% | 0% |
| Other Controls | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |



B.5.2. Premise Weighted Results

Table B-102
Overall EE Opportunities (Premise)

| | | (1.10111100) | | |
|--------------------------------------------|-------------|--------------|------------|------------|
| | Minimum | | | |
| | Percent of | | Lower 80% | Upper 80% |
| Energy Efficiency Opportunity | Premises | # of Cases | Confidence | Confidence |
| | with | | Limit | Limit |
| | Opportunity | | | |
| Switch to CFL | 31% | 26 | 19% | 43% |
| Switch to Standard T8 | 8% | 26 | 1% | 15% |
| Switch to High Performance T8 | 31% | 26 | 19% | 43% |
| Switch to T5 | 8% | 26 | 1% | 15% |
| Switch to Pulse Start Metal Halide | 4% | 26 | -1% | 9% |
| Replace Ballasts for Automatic Daylighting | 12% | 26 | 3% | 20% |
| Occupancy Sensors | 62% | 26 | 49% | 74% |
| Dimmers | 19% | 26 | 9% | 30% |
| Other Controls | 8% | 26 | 1% | 15% |
| Other | 4% | 26 | -1% | 9% |

Table B-103
Incandescent EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 67% | 12 | 48% | 85% |
| Switch to Standard T8 | 0% | 12 | 0% | 0% |
| Switch to High Performance T8 | 0% | 12 | 0% | 0% |
| Switch to T5 | 0% | 12 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 8% | 12 | -2% | 19% |
| Replace Ballasts for Automatic Daylighting | 0% | 12 | 0% | 0% |
| Occupancy Sensors | 8% | 12 | -2% | 19% |
| Dimmers | 25% | 12 | 8% | 42% |
| Other Controls | 8% | 12 | -2% | 19% |
| Other | 0% | 12 | 0% | 0% |



Table B-104
CFL EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 15 | 0% | 0% |
| Switch to Standard T8 | 0% | 15 | 0% | 0% |
| Switch to High Performance T8 | 0% | 15 | 0% | 0% |
| Switch to T5 | 0% | 15 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 15 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 15 | 0% | 0% |
| Occupancy Sensors | 47% | 15 | 29% | 64% |
| Dimmers | 0% | 15 | 0% | 0% |
| Other Controls | 7% | 15 | -2% | 15% |
| Other | 0% | 15 | 0% | 0% |

Table B-105
HID EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 3 | 0% | 0% |
| Switch to Standard T8 | 0% | 3 | 0% | 0% |
| Switch to High Performance T8 | 0% | 3 | 0% | 0% |
| Switch to T5 | 33% | 3 | -3% | 70% |
| Switch to Pulse Start Metal Halide | 0% | 3 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 3 | 0% | 0% |
| Occupancy Sensors | 0% | 3 | 0% | 0% |
| Dimmers | 0% | 3 | 0% | 0% |
| Other Controls | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |



Table B-106
T5 EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 11 | 0% | 0% |
| Switch to Standard T8 | 0% | 11 | 0% | 0% |
| Switch to High Performance T8 | 0% | 11 | 0% | 0% |
| Switch to T5 | 0% | 11 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 11 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 11 | 0% | 0% |
| Occupancy Sensors | 36% | 11 | 17% | 56% |
| Dimmers | 9% | 11 | -3% | 21% |
| Other Controls | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |

Table B-107
St T8 EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 12 | 0% | 0% |
| Switch to Standard T8 | 0% | 12 | 0% | 0% |
| Switch to High Performance T8 | 58% | 12 | 39% | 77% |
| Switch to T5 | 8% | 12 | -2% | 19% |
| Switch to Pulse Start Metal Halide | 0% | 12 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 17% | 12 | 2% | 31% |
| Occupancy Sensors | 42% | 12 | 23% | 61% |
| Dimmers | 17% | 12 | 2% | 31% |
| Other Controls | 0% | 12 | 0% | 0% |
| Other | 8% | 12 | -2% | 19% |



Table B-108
HP T8 EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 9 | 0% | 0% |
| Switch to Standard T8 | 0% | 9 | 0% | 0% |
| Switch to High Performance T8 | 0% | 9 | 0% | 0% |
| Switch to T5 | 0% | 9 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 9 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 11% | 9 | -3% | 25% |
| Occupancy Sensors | 78% | 9 | 59% | 96% |
| Dimmers | 0% | 9 | 0% | 0% |
| Other Controls | 0% | 9 | 0% | 0% |
| Other | 0% | 9 | 0% | 0% |

Table B-109
Unknown T8 EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 5 | 0% | 0% |
| Switch to Standard T8 | 0% | 5 | 0% | 0% |
| Switch to High Performance T8 | 0% | 5 | 0% | 0% |
| Switch to T5 | 0% | 5 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 5 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 5 | 0% | 0% |
| Occupancy Sensors | 20% | 5 | -4% | 44% |
| Dimmers | 0% | 5 | 0% | 0% |
| Other Controls | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |



Table B-110
T12 EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 3 | 0% | 0% |
| Switch to Standard T8 | 67% | 3 | 30% | 103% |
| Switch to High Performance T8 | 33% | 3 | -3% | 70% |
| Switch to T5 | 33% | 3 | -3% | 70% |
| Switch to Pulse Start Metal Halide | 0% | 3 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 3 | 0% | 0% |
| Occupancy Sensors | 33% | 3 | -3% | 70% |
| Dimmers | 0% | 3 | 0% | 0% |
| Other Controls | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |

Table B-111
Unknown Fluorescent Tube EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 5 | 0% | 0% |
| Switch to Standard T8 | 0% | 5 | 0% | 0% |
| Switch to High Performance T8 | 20% | 5 | -4% | 44% |
| Switch to T5 | 0% | 5 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 5 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 5 | 0% | 0% |
| Occupancy Sensors | 80% | 5 | 56% | 104% |
| Dimmers | 0% | 5 | 0% | 0% |
| Other Controls | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |



Table B-112
Other Fluorescent EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 7 | 0% | 0% |
| Switch to Standard T8 | 0% | 7 | 0% | 0% |
| Switch to High Performance T8 | 0% | 7 | 0% | 0% |
| Switch to T5 | 0% | 7 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 7 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 7 | 0% | 0% |
| Occupancy Sensors | 14% | 7 | -3% | 32% |
| Dimmers | 29% | 7 | 6% | 51% |
| Other Controls | 0% | 7 | 0% | 0% |
| Other | 0% | 7 | 0% | 0% |

Table B-113

Other Light Type EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------------------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 10 | 0% | 0% |
| Switch to Standard T8 | 0% | 10 | 0% | 0% |
| Switch to High Performance T8 | 0% | 10 | 0% | 0% |
| Switch to T5 | 0% | 10 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 10 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 10 | 0% | 0% |
| Occupancy Sensors | 10% | 10 | -3% | 23% |
| Dimmers | 0% | 10 | 0% | 0% |
| Other Controls | 10% | 10 | -3% | 23% |
| Other | 0% | 10 | 0% | 0% |



Table B-114

Quartz EE Opportunities (Premise)

| Energy Efficiency Opportunity | Minimum Percent of Premises with | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------------|----------------------------------|------------|----------------------------------|----------------------------------|
| | Opportunity | | | |
| Switch to CFL | 0% | 2 | 0% | 0% |
| Switch to Standard T8 | 0% | 2 | 0% | 0% |
| Switch to High Performance T8 | 0% | 2 | 0% | 0% |
| Switch to T5 | 0% | 2 | 0% | 0% |
| Switch to Pulse Start Metal Halide | 0% | 2 | 0% | 0% |
| Replace Ballasts for Automatic Daylighting | 0% | 2 | 0% | 0% |
| Occupancy Sensors | 0% | 2 | 0% | 0% |
| Dimmers | 0% | 2 | 0% | 0% |
| Other Controls | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |



Appendix C: Outdoor Lighting

C.1. Types of Outdoor Lighting

Table C-1
Outdoor Lamp Types (Wattage)

| | , , | | -3-/ | | |
|----------------------------------------------------|-----|------|------------|-------------------------|-------------------------|
| Percent of Total Watts by Lamp Type | | | # of Cases | Lower 80% Confidence | Upper 80% Confidence |
| | | | | Limit | Limit |
| Watts / Premise | | 1247 | 21 | 993 | 1501 |
| Facilities Where Outdoor Lighting Wattage is Known | | 78% | 27 | 67% | 88% |
| HID | | 78% | 21 | 68% | 88% |
| Fluorescent | | 3% | 21 | 2% | 5% |
| Incandescent / Quartz | | 19% | 21 | 9% | 29% |
| LED / Exit Sign | | 0% | 21 | 0% | 0% |

Table C-2

Specific HID Lamps as a Percent of Overall Outdoor Lighting(Wattage)

| | | | Lower 80% | Upper 80% |
|-------------------------------------|---------|------------|------------|------------|
| Percent of Total Watts by Lamp Type | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| Mercury Vapor | 0% | 21 | 0% | 0% |
| Standard Metal Halide | 56% | 21 | 43% | 70% |
| PS Metal Halide | 17% | 21 | 3% | 31% |
| HP Sodium Vapor | 4% | 21 | 0% | 8% |
| LP Sodium Vapor | 0% | 21 | 0% | 0% |

Table C-3

Specific HID Lamps as a Percent of Outdoor HID Lighting (Wattage)

| | | | | | Lower 80% | Upper 80% |
|--------------------|-----------------|---|---------|------------|------------|------------|
| Percent of HID Wat | ts by Lamp Type | • | Percent | # of Cases | Confidence | Confidence |
| | | | | | Limit | Limit |
| Mercury Vapor | | | 0% | 17 | 0% | 0% |
| Standard Metal Ha | alide | | 73% | 17 | 56% | 89% |
| PS Metal Halide | | | 22% | 17 | 5% | 39% |
| HP Sodium Vapor | | | 5% | 17 | 0% | 11% |
| LP Sodium Vapor | | | 0% | 17 | 0% | 0% |



C.2. Usage

Table C-4
Outdoor Lighting Usage (Wattage)

| Percent of Total Watts per Area | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence | | |
|---------------------------------|---------|------------|-------------------------|-------------------------|--|--|
| • | | | Limit | Limit | | |
| Parking Lot | 58% | 21 | 46% | 70% | | |
| Parking Garage | 1% | 21 | 0% | 2% | | |
| Advertising | 1% | 21 | 0% | 2% | | |
| Building Facade | 26% | 21 | 15% | 37% | | |
| Walkway | 14% | 21 | 5% | 23% | | |

Table C-5
Parking Lot Lamps (Wattage)

| Lamp Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|----------------------------------|----------------------------------|
| HID | 98% | 14 | 97% | 100% |
| Fluorescent | 2% | 14 | 0% | 3% |
| Incandescent / Quartz | 0% | 14 | 0% | 0% |
| LED / Exit Sign | 0% | 14 | 0% | 0% |

Table C-6
Advertising Lamps (Wattage)

| Lamp Type | Percent | # of Cases | Lower 80% Confidence | | |
|-----------------------|-----------|------------|-------------------------|-------|--|
| | 1 5.00111 | c. 3000 | Limit | Limit | |
| HID | 0% | 3 | 0% | 0% | |
| Fluorescent | 30% | 3 | -6% | 65% | |
| Incandescent / Quartz | 70% | 3 | 35% | 106% | |
| LED / Exit Sign | 0% | 3 | 0% | 0% | |

Table C-7
Building Facade Lamps (Wattage)

| zanang rasaas zamps (matags) | | | | | | |
|------------------------------|---------|------------|------------|------------|--|--|
| | | | Lower 80% | Upper 80% | | |
| Lamp Type | Percent | # of Cases | Confidence | Confidence | | |
| | | | Limit | Limit | | |
| HID | 71% | 13 | 49% | 94% | | |
| Fluorescent | 4% | 13 | 0% | 8% | | |
| Incandescent / Quartz | 25% | 13 | 3% | 47% | | |
| LED / Exit Sign | 0% | 13 | 0% | 0% | | |



Table C-8
Walkway Lamps (Wattage)

| | | | Lower 80% | Upper 80% |
|-----------------------|---------|------------|------------|------------|
| Lamp Type | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| HID | 7% | 6 | -1% | 15% |
| Fluorescent | 8% | 6 | 1% | 15% |
| Incandescent / Quartz | 84% | 6 | 75% | 94% |
| LED / Exit Sign | 0% | 6 | 0% | 0% |

C.3. Control Types

Table C-9

Overall Outdoor Lighting Control Types (Wattage)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 17% | 21 | 4% | 30% |
| Dimmer | 0% | 21 | 0% | 0% |
| Motion/Occupancy Sensor | 1% | 21 | 0% | 3% |
| Photoœll | 34% | 21 | 21% | 46% |
| Timeclock | 12% | 21 | 4% | 20% |
| Photocell/Timeclock | 13% | 21 | 4% | 21% |
| Photocell with Dimming | 0% | 21 | 0% | 0% |
| Energy Management System | 7% | 21 | -2% | 17% |
| None/Continuous | 0% | 21 | 0% | 0% |
| Other | 0% | 21 | 0% | 0% |

Table C-10
Outdoor HID Control Types (Wattage)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 15% | 17 | 0% | 29% |
| Dimmer | 0% | 17 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 17 | 0% | 0% |
| Photoœll | 37% | 17 | 22% | 52% |
| Timeclock | 4% | 17 | 0% | 9% |
| Photoœll/Timeclock | 16% | 17 | 6% | 26% |
| Photoœll with Dimming | 0% | 17 | 0% | 0% |
| Energy Management System | 9% | 17 | -3% | 21% |
| None/Continuous | 0% | 17 | 0% | 0% |
| Other | 0% | 17 | 0% | 0% |



Table C-11
Outdoor Fluorescent Control Types (Wattage)

| Control Type | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence |
|--------------------------|---------|------------|-------------------------|-------------------------|
| | | | Limit | Limit |
| Manual On/Off Switch | 52% | 9 | 26% | 79% |
| Dimmer | 0% | 9 | 0% | 0% |
| Motion/Occupancy Sensor | 0% | 9 | 0% | 0% |
| Photocell | 7% | 9 | -3% | 17% |
| Timeclock | 19% | 9 | 1% | 36% |
| Photocell/Timeclock | 13% | 9 | -3% | 29% |
| Photocell with Dimming | 0% | 9 | 0% | 0% |
| Energy Management System | 0% | 9 | 0% | 0% |
| None/Continuous | 0% | 9 | 0% | 0% |
| Other | 0% | 9 | 0% | 0% |

Table C-12
Outdoor Incandescent / Quartz Control Types (Wattage)

| Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Manual On/Off Switch | 21% | 6 | -4% | 45% |
| Dimmer | 0% | 6 | 0% | 0% |
| Motion/Occupancy Sensor | 6% | 6 | -2% | 15% |
| Photocell | 24% | 6 | -3% | 52% |
| Timeclock | 40% | 6 | 10% | 70% |
| Photocell/Timeclock | 0% | 6 | 0% | 0% |
| Photocell with Dimming | 0% | 6 | 0% | 0% |
| Energy Management System | 0% | 6 | 0% | 0% |
| None/Continuous | 0% | 6 | 0% | 0% |
| Other | 0% | 6 | 0% | 0% |

C.4. Ballast Types

Table C-13
Overall Outdoor Lighting Ballast Types (Wattage)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 8% | 21 | 1% | 15% |
| Energy Saving Magnetic | 12% | 21 | 1% | 24% |
| Electronic | 1% | 21 | 0% | 1% |
| Other | 0% | 21 | 0% | 0% |
| No Ballast | 73% | 21 | 60% | 85% |
| Unknown | 6% | 21 | 1% | 12% |



Table C-14
Outdoor HID Ballast Types (Wattage)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 11% | 17 | 2% | 19% |
| Energy Saving Magnetic | 16% | 17 | 2% | 30% |
| Electronic | 0% | 17 | 0% | 0% |
| Other | 0% | 17 | 0% | 0% |
| No Ballast | 66% | 17 | 50% | 82% |
| Unknown | 8% | 17 | 0% | 15% |

Table C-15
Outdoor Fluorescent Ballast Types (Wattage)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 0% | 9 | 0% | 0% |
| Energy Saving Magnetic | 0% | 9 | 0% | 0% |
| Electronic | 15% | 9 | -1% | 32% |
| Other | 0% | 9 | 0% | 0% |
| No Ballast | 68% | 9 | 46% | 90% |
| Unknown | 17% | 9 | 1% | 32% |

Table C-16
Outdoor Standard Metal Halide Ballast Types (Wattage)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 7% | 14 | -2% | 17% |
| Energy Saving Magnetic | 6% | 14 | -2% | 14% |
| Electronic | 0% | 14 | 0% | 0% |
| Other | 0% | 14 | 0% | 0% |
| No Ballast | 76% | 14 | 61% | 92% |
| Unknown | 10% | 14 | 0% | 20% |



Table C-17
Outdoor High Pressure Sodium Ballast Types (Wattage)

| Ballast Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Standard Magnetic | 100% | 2 | 100% | 100% |
| Energy Saving Magnetic | 0% | 2 | 0% | 0% |
| Electronic | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |
| No Ballast | 0% | 2 | 0% | 0% |
| Unknown | 0% | 2 | 0% | 0% |

C.5. Energy Efficiency Opportunities

C.5.1. Premise Weighted

Table C-18
Overall Outdoor Lighting EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 17% | 24 | 6% | 27% |
| Switch to Pulse-Start Metal Halide | 17% | 24 | 6% | 27% |
| Switch to T5 | 0% | 24 | 0% | 0% |
| Astronomical Time Clock | 13% | 24 | 3% | 22% |
| Light Sensing Controls | 4% | 24 | -1% | 10% |
| Other Controls | 4% | 24 | -1% | 10% |
| Other | 0% | 24 | 0% | 0% |

C.5.2. Wattage Weighted

Table C-19
Overall Outdoor Lighting EE Ops (Wattage)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 8% | 21 | 1% | 14% |
| Switch to Pulse-Start Metal Halide | 10% | 21 | 2% | 17% |
| Switch to T5 | 0% | 21 | 0% | 0% |
| Astronomical Time Clock | 8% | 21 | 1% | 15% |
| Light Sensing Controls | 4% | 21 | -1% | 10% |
| Other Controls | 0% | 21 | 0% | 1% |
| Other | 0% | 21 | 0% | 0% |



Table C-20
HID Outdoor Lighting EE Ops (Wattage)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 17 | 0% | 0% |
| Switch to Pulse-Start Metal Halide | 12% | 17 | 3% | 22% |
| Switch to T5 | 0% | 17 | 0% | 0% |
| Astronomical Time Clock | 4% | 17 | 0% | 7% |
| Light Sensing Controls | 0% | 17 | 0% | 0% |
| Other Controls | 0% | 17 | 0% | 0% |
| Other | 0% | 17 | 0% | 0% |

Table C-21
Fluorescent Outdoor Lighting EE Ops (Wattage)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 9 | 0% | 0% |
| Switch to Pulse-Start Metal Halide | 0% | 9 | 0% | 0% |
| Switch to T5 | 0% | 9 | 0% | 0% |
| Astronomical Time Clock | 40% | 9 | 11% | 68% |
| Light Sensing Controls | 9% | 9 | -3% | 22% |
| Other Controls | 7% | 9 | -3% | 17% |
| Other | 0% | 9 | 0% | 0% |

Table C-22
Incandescent / Quartz Outdoor Lighting EE Ops (Wattage)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 40% | 6 | 12% | 68% |
| Switch to Pulse-Start Metal Halide | 0% | 6 | 0% | 0% |
| Switch to T5 | 0% | 6 | 0% | 0% |
| Astronomical Time Clock | 21% | 6 | -4% | 45% |
| Light Sensing Controls | 21% | 6 | -4% | 45% |
| Other Controls | 0% | 6 | 0% | 0% |
| Other | 0% | 6 | 0% | 0% |



Table C-23
Standard Metal Halide Outdoor Lighting EE Ops (Wattage)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence |
|------------------------------------|---------|------------|-------------------------|-------------------------|
| | | | Limit | Limit |
| Switch to CFL | 0% | 14 | 0% | 0% |
| Switch to Pulse-Start Metal Halide | 17% | 14 | 4% | 30% |
| Switch to T5 | 0% | 14 | 0% | 0% |
| Astronomical Time Clock | 5% | 14 | 0% | 10% |
| Light Sensing Controls | 0% | 14 | 0% | 0% |
| Other Controls | 0% | 14 | 0% | 0% |
| Other | 0% | 14 | 0% | 0% |

Table C-24
High Pressure Sodium Outdoor Lighting EE Ops (Wattage)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Switch to CFL | 0% | 2 | 0% | 0% |
| Switch to Pulse-Start Metal Halide | 0% | 2 | 0% | 0% |
| Switch to T5 | 0% | 2 | 0% | 0% |
| Astronomical Time Clock | 0% | 2 | 0% | 0% |
| Light Sensing Controls | 0% | 2 | 0% | 0% |
| Other Controls | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |



Appendix D: Cooling

Table D-1
Percent of Floorspace with Cooling

| Conditioned Type | Percent of Floorspace | # of Cases | | Upper 80% Confidence Limit |
|---------------------------------|-----------------------|------------|-------|----------------------------------|
| Cooled (Overall Floorspace) | 48.1% | 27 | 36.7% | 59.5% |
| Cooled (Conditioned Floorspace) | 50.4% | 27 | 39.3% | 61.4% |

Table D-2 Percent of Premises with Cooling

| Conditioned Type | Percent of Premises | # of Cases | | Upper 80% Confidence Limit |
|-------------------------------|------------------------|------------|-------|----------------------------------|
| Cooled (Overall Premises) | 85.2% | 27 | 76.0% | 94.3% |
| Cooled (Conditioned Premises) | 88.5% | 27 | 80.1% | 96.9% |

D.1. Cooling Types by Tonnage

Table D-3
Percent of Known Tons by Cooling Type (Premise)

| Cooling Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Packaged HVAC | 13% | 19 | 4% | 22% |
| Split System HVAC | 36% | 19 | 15% | 57% |
| Chiller | 39% | 19 | 10% | 68% |
| Window | 0% | 19 | 0% | 0% |
| Heat Pump | 12% | 19 | 2% | 22% |
| Miscellaneous Cooling | 0% | 19 | 0% | 0% |
| Percent of Units with Unknown Tonnage | 13% | 19 | 2% | 25% |



D.2. Conditioned Square Foot Weighted Results

D.2.1. Equipment Types

Table D-4
Percent of Facilities with Cooling of Type (Conditioned Square Foot)

| | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|----------------------------------|----------------------------------|
| None | 9% | 26 | 1% | 17% |
| Packaged HVAC | 48% | 26 | 29% | 67% |
| Split System HVAC | 62% | 26 | 46% | 79% |
| Chiller | 12% | 26 | 1% | 24% |
| Window | 0% | 26 | 0% | 0% |
| Heat Pump | 26% | 26 | 8% | 44% |
| Miscellaneous Cooling | 0% | 26 | 0% | 0% |

Table D-5
Percent of Units with Cooling of Type (Conditioned Square Foot)

| Cooling Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|----------------------------------|----------------------------------|
| Packaged HVAC | 17% | 22 | 9% | 25% |
| Split System HVAC | 36% | 22 | 15% | 56% |
| Chiller | 4% | 22 | 0% | 8% |
| Window | 0% | 22 | 0% | 0% |
| Heat Pump | 43% | 22 | 18% | 69% |
| Miscellaneous Cooling | 0% | 22 | 0% | 0% |

D.2.2. Energy Efficiency Opportunities

Table D-6
Overall Cooling EE Ops (Premise)

| O Torium O O ming 22 Opo (1 Torimoo) | | | | | | |
|--------------------------------------|---------|------------|----------------------------------|----------------------------------|--|--|
| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
| Economizer | 38% | 21 | 24% | 52% | | |
| Upgrade to NEMA Efficiency Motors | 22% | 9 | 4% | 41% | | |
| ECM | 38% | 8 | 15% | 60% | | |
| Automatic Setback Thermostat | 23% | 22 | 11% | 35% | | |
| Other HVAC Controls | 15% | 20 | 4% | 26% | | |
| Refrigerant Charge | 0% | 21 | 0% | 0% | | |
| Other O&M | 0% | 21 | 0% | 0% | | |
| Other EE Op | 5% | 22 | -1% | 10% | | |



Table D-7
Packaged HVAC EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 25% | 8 | 4% | 46% |
| Upgrade to NEMA Efficiency Motors | 25% | 8 | 4% | 46% |
| ECM | 38% | 8 | 15% | 60% |
| Automatic Setback Thermostat | 25% | 8 | 4% | 46% |
| Other HVAC Controls | 25% | 8 | 4% | 46% |
| Refrigerant Charge | 0% | 8 | 0% | 0% |
| Other O&M | 0% | 8 | 0% | 0% |
| Other EE Op | 13% | 8 | -3% | 28% |

Table D-8
Split System HVAC EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 46% | 13 | 28% | 65% |
| Automatic Setback Thermostat | 23% | 13 | 7% | 39% |
| Other HVAC Controls | 8% | 13 | -2% | 18% |
| Refrigerant Charge | 0% | 13 | 0% | 0% |
| Other O&M | 0% | 13 | 0% | 0% |
| Other EE Op | 0% | 13 | 0% | 0% |

Table D-9
Heat Pump EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 50% | 2 | 3% | 97% |
| Upgrade to NEMA Efficiency Motors | 100% | 1 | 100% | 100% |
| ECM | 100% | 1 | 100% | 100% |
| Automatic Setback Thermostat | 20% | 5 | -4% | 44% |
| Other HVAC Controls | 50% | 2 | 3% | 97% |
| Refrigerant Charge | 0% | 2 | 0% | 0% |
| Other O&M | 0% | 2 | 0% | 0% |
| Other EE Op | 0% | 5 | 0% | 0% |



D.2.3. Equipment Details

Table D-10
Overall Cooling Characteristics (Conditioned Square Foot)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|---------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 13.0 | 22 | 8.60 | 17.49 |
| Efficiency of Units (EER) | 11.1 | 9 | 9.96 | 12.17 |
| Percent of Units Missing Efficiency | 10% | 9 | 3% | 17% |
| Unit Size (tons) | 3.2 | 19 | 1.63 | 4.81 |
| Percent of Units Missing Size | 11% | 19 | 1% | 20% |
| Tons per Premise | 39.0 | 19 | 23.66 | 54.35 |

Table D-11

Packaged HVAC Cooling Characteristics (Conditioned Square Foot)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|------------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 4.2 | 8 | 2.54 | 5.88 |
| Efficiency of Units (EER) | 11.7 | 2 | 11.54 | 11.94 |
| Percent of Units Missing Efficiency | 0% | 2 | 0% | 0% |
| Unit Size (tons) | 4.3 | 5 | 2.75 | 5.78 |
| Percent of Units Missing Size | 3% | 5 | -1% | 7% |
| Tons per Premise | 14.5 | 5 | 9.72 | 19.31 |

Table D-12
Split System HVAC Cooling Characteristics (Conditioned Square Foot)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|------------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 6.8 | 13 | 3.58 | 9.93 |
| Efficiency of Units (EER) | 12.7 | 5 | 11.63 | 13.71 |
| Percent of Units Missing Efficiency | 2% | 5 | -1% | 4% |
| Unit Size (tons) | 3.2 | 12 | 2.80 | 3.52 |
| Percent of Units Missing Size | 0% | 12 | 0% | 0% |
| Tons per Premise | 21.3 | 12 | 12.24 | 30.44 |



Table D-13
Heat Pump Cooling Characteristics (Conditioned Square Foot)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|------------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 19.7 | 5 | 15.47 | 23.83 |
| Efficiency of Units (EER) | 10.8 | 4 | 9.62 | 12.04 |
| Percent of Units Missing Efficiency | 5% | 4 | -3% | 12% |
| Unit Size (tons) | 0.9 | 5 | 0.50 | 1.34 |
| Percent of Units Missing Size | 5% | 5 | -3% | 12% |
| Tons per Premise | 17.3 | 5 | 7.26 | 27.32 |

D.2.4. Thermostat Controls

Table D-14
Overall Cooling Thermostat Types (Conditioned Square Foot)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 37% | 21 | 16% | 57% |
| Manual Thermostat | 34% | 21 | 11% | 57% |
| EMS | 25% | 21 | -2% | 52% |
| Always on, constant Temp | 0% | 21 | 0% | 0% |
| Manually Shut on/off | 0% | 21 | 0% | 0% |
| Other | 0% | 21 | 0% | 0% |
| Missing | 3% | 21 | 0% | 6% |

Table D-15
Packaged HVAC Thermostat Types (Conditioned Square Foot)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 12% | 8 | -1% | 24% |
| Manual Thermostat | 48% | 8 | 9% | 88% |
| EMS | 39% | 8 | 2% | 75% |
| Always on, constant Temp | 0% | 8 | 0% | 0% |
| Manually Shut on/off | 0% | 8 | 0% | 0% |
| Other | 0% | 8 | 0% | 0% |
| Missing | 1% | 8 | 0% | 3% |



Table D-16
Split System HVAC Thermostat Types (Conditioned Square Foot)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 94% | 13 | 88% | 101% |
| Manual Thermostat | 3% | 13 | -1% | 8% |
| EMS | 1% | 13 | -1% | 3% |
| Always on, constant Temp | 0% | 13 | 0% | 0% |
| Manually Shut on/off | 0% | 13 | 0% | 0% |
| Other | 0% | 13 | 0% | 0% |
| Missing | 2% | 13 | -1% | 4% |

Table D-17
Heat Pump Thermostat Types (Conditioned Square Foot)

| | | (| | |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Programmable Thermostat | 0% | 5 | 0% | 0% |
| Manual Thermostat | 55% | 5 | 11% | 99% |
| EMS | 40% | 5 | -3% | 83% |
| Always on, constant Temp | 0% | 5 | 0% | 0% |
| Manually Shut on/off | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Missing | 5% | 5 | -2% | 12% |

D.2.5. Economizers

Table D-18
Overall Cooling Economizer Types (Conditioned Square Foot)

| Economizer Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent of Units with Economizers | 3% | 21 | 0% | 6% |
| Percent of Facilities with Economizers | 26% | 21 | 9% | 43% |
| Dry Bulb | 0% | 5 | 0% | 0% |
| Single Enthalpy | 57% | 5 | 25% | 88% |
| Dual Enthalpy | 0% | 5 | 0% | 0% |
| DCV | 24% | 5 | -4% | 52% |
| Other | 0% | 5 | 0% | 0% |
| Missing Type | 19% | 5 | -4% | 43% |



Table D-19
Packaged HVAC Cooling Economizer Types (Conditioned Square Foot)

| Economizer Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent of Units with Economizers | 12% | 8 | -1% | 25% |
| Percent of Facilities with Economizers | 35% | 8 | 7% | 64% |
| Dry Bulb | 0% | 3 | 0% | 0% |
| Single Enthalpy | 65% | 3 | 27% | 104% |
| Dual Enthalpy | 0% | 3 | 0% | 0% |
| DCV | 35% | 3 | -4% | 73% |
| Other | 0% | 3 | 0% | 0% |
| Missing Type | 0% | 3 | 0% | 0% |

Table D-20
Split System HVAC Cooling Economizer Types (Conditioned Square Foot)

| Economizer Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent of Units with Economizers | 3% | 13 | -1% | 6% |
| Percent of Facilities with Economizers | 10% | 13 | 0% | 21% |
| Dry Bulb | 0% | 2 | 0% | 0% |
| Single Enthalpy | 38% | 2 | -7% | 82% |
| Dual Enthalpy | 0% | 2 | 0% | 0% |
| DCV | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |
| Missing Type | 62% | 2 | 18% | 107% |

D.2.6. Energy Efficiency Opportunities

Table D-21
Overall Cooling EE Ops (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 39% | 21 | 19% | 59% |
| Upgrade to NEMA Efficiency Motors | 35% | 9 | 8% | 62% |
| ECM | 31% | 8 | 6% | 56% |
| Automatic Setback Thermostat | 43% | 22 | 21% | 64% |
| Other HVAC Controls | 16% | 20 | 3% | 29% |
| Refrigerant Charge | 0% | 21 | 0% | 0% |
| Other O&M | 0% | 21 | 0% | 0% |
| Other EE Op | 3% | 22 | -1% | 6% |



Table D-22
Packaged HVAC EE Ops (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 25% | 8 | 2% | 49% |
| Upgrade to NEMA Efficiency Motors | 39% | 8 | 9% | 69% |
| ECM | 31% | 8 | 6% | 56% |
| Automatic Setback Thermostat | 49% | 8 | 17% | 80% |
| Other HVAC Controls | 20% | 8 | -1% | 40% |
| Refrigerant Charge | 0% | 8 | 0% | 0% |
| Other O&M | 0% | 8 | 0% | 0% |
| Other EE Op | 5% | 8 | -2% | 12% |

Table D-23
Split System HVAC EE Ops (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 37% | 13 | 11% | 62% |
| Automatic Setback Thermostat | 25% | 13 | 2% | 48% |
| Other HVAC Controls | 7% | 13 | -2% | 16% |
| Refrigerant Charge | 0% | 13 | 0% | 0% |
| Other O&M | 0% | 13 | 0% | 0% |
| Other EE Op | 0% | 13 | 0% | 0% |

Table D-24
Heat Pump EE Ops (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 79% | 2 | 49% | 110% |
| Upgrade to NEMA Efficiency Motors | 100% | 1 | 100% | 100% |
| ECM | 100% | 1 | 100% | 100% |
| Automatic Setback Thermostat | 27% | 5 | -6% | 60% |
| Other HVAC Controls | 79% | 2 | 49% | 110% |
| Refrigerant Charge | 0% | 2 | 0% | 0% |
| Other O&M | 0% | 2 | 0% | 0% |
| Other EE Op | 0% | 5 | 0% | 0% |



D.3. Premise Weighted Results

D.3.1. Equipment Types

Table D-25
Percent of Facilities with Cooling of Type (Conditioned Square Foot)

| | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|----------------------------------|----------------------------------|
| None | 19% | 27 | 9% | 29% |
| Packaged HVAC | 30% | 27 | 18% | 41% |
| Split System HVAC | 48% | 27 | 35% | 61% |
| Chiller | 7% | 27 | 1% | 14% |
| Window | 0% | 27 | 0% | 0% |
| Heat Pump | 19% | 27 | 9% | 29% |
| Miscellaneous Cooling | 0% | 27 | 0% | 0% |

Table D-26
Percent of Units with Cooling of Type (Conditioned Square Foot)

| Cooling Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|----------------------------------|----------------------------------|
| Packaged HVAC | 16% | 22 | 10% | 22% |
| Split System HVAC | 38% | 22 | 21% | 56% |
| Chiller | 5% | 22 | 0% | 10% |
| Window | 0% | 22 | 0% | 0% |
| Heat Pump | 41% | 22 | 23% | 59% |
| Miscellaneous Cooling | 0% | 22 | 0% | 0% |

D.3.2. Equipment Details

Table D-27
Overall Cooling Characteristics (Premise)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|------------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 7.4 | 22 | 4.70 | 10.03 |
| Efficiency of Units (EER) | 11.7 | 9 | 10.93 | 12.47 |
| Percent of Units Missing Efficiency | 17% | 9 | 0% | 34% |
| Unit Size (tons) | 4.2 | 19 | 2.17 | 6.21 |
| Percent of Units Missing Size | 13% | 19 | 2% | 25% |
| Tons per Premise | 29.3 | 19 | 16.3 | 42.3 |
| Conditioned Sq. Ft. per Ton | 666 | 19 | 350 | 983 |
| Indoor Sq. Ft. per Ton | 723 | 19 | 371 | 1,075 |



Table D-28
Packaged HVAC Cooling Characteristics (Premise)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|------------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 3.3 | 8 | 1.96 | 4.54 |
| Efficiency of Units (EER) | 11.6 | 2 | 11.09 | 12.02 |
| Percent of Units Missing Efficiency | 0% | 2 | 0% | 0% |
| Unit Size (tons) | 4.3 | 5 | 3.09 | 5.58 |
| Percent of Units Missing Size | 6% | 5 | -1% | 13% |
| Tons per Premise | 14.8 | 5 | 10.58 | 18.92 |

Table D-29
Split System HVAC Cooling Characteristics (Premise)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|---------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 4.8 | 13 | 3.44 | 6.10 |
| Efficiency of Units (EER) | 12.9 | 5 | 12.14 | 13.74 |
| Percent of Units Missing Efficiency | 5% | 5 | -1% | 11% |
| Unit Size (tons) | 3.7 | 12 | 3.04 | 4.30 |
| Percent of Units Missing Size | 0% | 12 | 0% | 0% |
| Tons per Premise | 16.8 | 12 | 12.89 | 20.77 |

Table D-30
Heat Pump Cooling Characteristics (Premise)

| Detail | Percent or Quantity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------|------------------------|------------|----------------------------------|----------------------------------|
| Units Per Facility | 13.2 | 5 | 6.65 | 19.75 |
| Efficiency of Units (EER) | 11.3 | 4 | 10.16 | 12.43 |
| Percent of Units Missing Efficiency | 20% | 4 | -5% | 45% |
| Unit Size (tons) | 1.3 | 5 | 0.76 | 1.74 |
| Percent of Units Missing Size | 20% | 5 | -5% | 44% |
| Tons per Premise | 13.3 | 5 | 4.61 | 21.89 |



D.3.3. Thermostat Controls

Table D-31
Overall Cooling Thermostat Types (Premise)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 38% | 21 | 21% | 56% |
| Manual Thermostat | 22% | 21 | 6% | 37% |
| EMS | 26% | 21 | 1% | 51% |
| Always on, constant Temp | 0% | 21 | 0% | 0% |
| Manually Shut on/off | 0% | 21 | 0% | 0% |
| Other | 0% | 21 | 0% | 0% |
| Missing | 12% | 21 | 1% | 24% |

Table D-32
Packaged HVAC Thermostat Types (Premise)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 27% | 8 | 6% | 48% |
| Manual Thermostat | 23% | 8 | -4% | 50% |
| EMS | 42% | 8 | 11% | 73% |
| Always on, constant Temp | 0% | 8 | 0% | 0% |
| Manually Shut on/off | 0% | 8 | 0% | 0% |
| Other | 0% | 8 | 0% | 0% |
| Missing | 8% | 8 | -1% | 16% |

Table D-33
Split System HVAC Thermostat Types (Premise)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 85% | 13 | 74% | 97% |
| Manual Thermostat | 8% | 13 | -1% | 17% |
| EMS | 2% | 13 | -1% | 4% |
| Always on, constant Temp | 0% | 13 | 0% | 0% |
| Manually Shut on/off | 0% | 13 | 0% | 0% |
| Other | 0% | 13 | 0% | 0% |
| Missing | 5% | 13 | -2% | 11% |



Table D-34
Heat Pump Thermostat Types (Premise)

| Thermostat Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 0% | 5 | 0% | 0% |
| Manual Thermostat | 35% | 5 | 1% | 69% |
| EMS | 44% | 5 | 4% | 84% |
| Always on, constant Temp | 0% | 5 | 0% | 0% |
| Manually Shut on/off | 0% | 5 | 0% | 0% |
| Other | 0% | 5 | 0% | 0% |
| Missing | 21% | 5 | -4% | 46% |

D.3.4. Economizers

Table D-35
Overall Cooling Economizer Types (Premise)

| Economizer Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent of Units with Economizers | 6% | 21 | 2% | 11% |
| Percent of Facilities with Economizers | 24% | 21 | 11% | 36% |
| Dry Bulb | 0% | 5 | 0% | 0% |
| Single Enthalpy | 40% | 5 | 10% | 70% |
| Dual Enthalpy | 0% | 5 | 0% | 0% |
| DCV | 30% | 5 | -2% | 62% |
| Other | 0% | 5 | 0% | 0% |
| Missing Type | 30% | 5 | -2% | 62% |

Table D-36
Packaged HVAC Cooling Economizer Types (Premise)

| Economizer Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent of Units with Economizers | 23% | 8 | 4% | 42% |
| Percent of Facilities with Economizers | 38% | 8 | 15% | 60% |
| Dry Bulb | 0% | 3 | 0% | 0% |
| Single Enthalpy | 50% | 3 | 8% | 92% |
| Dual Enthalpy | 0% | 3 | 0% | 0% |
| DCV | 50% | 3 | 8% | 92% |
| Other | 0% | 3 | 0% | 0% |
| Missing Type | 0% | 3 | 0% | 0% |



Table D-37
Split System HVAC Cooling Economizer Types (Premise)

| Economizer Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent of Units with Economizers | 6% | 13 | -1% | 13% |
| Percent of Facilities with Economizers | 15% | 13 | 2% | 29% |
| Dry Bulb | 0% | 2 | 0% | 0% |
| Single Enthalpy | 25% | 2 | -11% | 61% |
| Dual Enthalpy | 0% | 2 | 0% | 0% |
| DCV | 0% | 2 | 0% | 0% |
| Other | 0% | 2 | 0% | 0% |
| Missing Type | 75% | 2 | 39% | 111% |

D.4. Surveyed Chiller Results

Table D-38 Chiller Details

| | Chillers Surveyed | | | | | | |
|-------------------------------------------|-------------------|----------|------------|------------|--|--|--|
| Site | 1 | 1 | 2 | 2 | | | |
| Chiller Number | Α | В | Α | В | | | |
| Chilled Water Loop | Yes | No | UNK | UNK | | | |
| Compressor Type | Scroll | Scroll | Scroll | Scroll | | | |
| Equipment Age (Years) | 1 | 1 | 2 | 2 | | | |
| Fuel Type | Electric | Electric | Electric | Electric | | | |
| Number of Units | 1 | 1 | 4 | 2 | | | |
| Nominal Capacity (tons) | 20 | 5 | 40 | 15 | | | |
| Control Type | Lead/Lag | Lead/Lag | UNK | UNK | | | |
| Energy Management System Control Strategy | UNK | UNK | UNK | UNK | | | |
| Condenser Type | Cooling Tower | UNK | Air-Cooled | Air-Cooled | | | |
| Number of Fan Condenser Motors | 1.5 | UNK | 1 | UNK | | | |
| Serves Chilled Water Loop | Yes | No | UNK | UNK | | | |
| Chilled Water System Pump HP | 15 | 2 | UNK | UNK | | | |
| Pump Motor Efficiency | 93 | 87 | UNK | UNK | | | |

Table D-39 Chiller EE Opportunities

| Energy Efficiency Opportunities | | | | | | |
|---------------------------------|-----|-----|-----|-----|--|--|
| Site 1 1 2 2 | | | | | | |
| Chiller Number | Α | В | Α | В | | |
| NEMA Premium Motors | Yes | Yes | UNK | UNK | | |
| Automatic Setback Thermostat | Yes | Yes | No | No | | |
| Energy Management System | Yes | Yes | Yes | Yes | | |





Appendix E: Heating Results

E.1. Overall Heating

E.1.1. Conditioned Square Foot Weighted Results

E.1.1.1. Details

Table E-1
Heating Fuel Types (Conditioned Square Foot)

| Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------|---------|------------|----------------------------------|----------------------------------|
| Have Heating Equipment | 100% | 26 | 100% | 100% |
| Electric | 22% | 26 | 5% | 38% |
| Natural Gas | 24% | 26 | 5% | 42% |
| Fuel Oil | 25% | 26 | 12% | 37% |
| LPG | 38% | 26 | 20% | 57% |
| Not Electric or Natural Gas | 8% | 26 | 1% | 15% |
| Other | 10% | 26 | 2% | 18% |
| Unknown | 11% | 26 | 1% | 22% |

Table E-2
Percent of Heating Units of Fuel Type (Conditioned Square Foot)

| Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------|---------|------------|----------------------------------|----------------------------------|
| Electric | 30% | 26 | 7% | 54% |
| Natural Gas | 26% | 26 | 2% | 49% |
| Fuel Oil | 4% | 26 | 1% | 7% |
| LPG | 19% | 26 | 7% | 32% |
| Not Electric or Natural Gas | 10% | 26 | -3% | 22% |
| Other | 4% | 26 | -1% | 9% |
| Unknown | 7% | 26 | 1% | 12% |



Table E-3
Heating Equipment Types (Conditioned Square Foot)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 72% | 26 | 56% | 88% |
| Furnace | 22% | 26 | 10% | 35% |
| Electric Resistance | 15% | 26 | 0% | 29% |
| Unit Heater | 7% | 26 | 0% | 13% |
| Cabinet Unit Heater | 4% | 26 | -1% | 10% |
| Heat Pump | 7% | 26 | -2% | 16% |
| Other | 6% | 26 | 0% | 12% |
| Unknown | 3% | 26 | 0% | 5% |

Table E-4
Percent of Heating Units by Equipment Type (Conditioned Square Foot)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 36% | 26 | 13% | 58% |
| Furnace | 17% | 26 | 5% | 30% |
| Electric Resistance | 4% | 26 | -1% | 10% |
| Unit Heater | 8% | 26 | -2% | 19% |
| Cabinet Unit Heater | 1% | 26 | 0% | 3% |
| Heat Pump | 32% | 26 | 2% | 62% |
| Other | 1% | 26 | 0% | 1% |
| Unknown | 0% | 26 | 0% | 1% |

Table E-5
Heating Control Types (Conditioned Square Foot)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 30% | 26 | 13% | 47% |
| Manual Thermostat | 15% | 26 | 1% | 28% |
| EMS | 49% | 26 | 20% | 78% |
| Multiple Zones | 0% | 26 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 26 | 0% | 1% |
| Other | 0% | 26 | 0% | 0% |
| Unknown | 6% | 26 | 0% | 12% |

Table E-6
Efficiency of Heating Equipment (Conditioned Square Foot)

| Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------|---------|------------|-----|----------------------------------|
| Mean | 0.8 | 21 | 0.7 | 0.9 |
| Unknown | 61% | 26 | 44% | 78% |



E.1.1.2. Energy Efficiency Opportunities

Table E-7
Heating Energy Efficiency Opportunities (Conditioned Square Foot)

| Treating Energy Emciency Oppo | 1 | | Lower 80% | Upper 80% |
|-------------------------------------------|---------|------------|------------|------------|
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence |
| 3, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, | | | Limit | Limit |
| Economizer | 14% | 26 | 2% | 25% |
| Automatic Setback Thermostat | 35% | 26 | 14% | 55% |
| Install VFD on Pump Motors | 22% | 26 | 5% | 39% |
| ECM | 24% | 26 | 10% | 38% |
| Install NEMA Premium Motors | 29% | 26 | 11% | 47% |
| Outdoor Reset | 11% | 26 | 2% | 19% |
| Outdoor Cut-off | 4% | 26 | 0% | 8% |
| Modulating Boiler | 6% | 26 | 1% | 11% |
| Duct Sealing/Insulation | 0% | 26 | 0% | 0% |
| Pipe Insulation | 3% | 26 | -1% | 7% |
| Refrigerant Charge | 0% | 26 | 0% | 0% |
| Replace Steam Traps | 0% | 26 | 0% | 0% |
| Replace Steam Vents | 0% | 26 | 0% | 0% |
| Balance System | 2% | 26 | -1% | 4% |
| Other HVAC Controls | 14% | 26 | 3% | 25% |
| Other O & M | 5% | 26 | 0% | 9% |
| Other EE Op | 4% | 26 | 0% | 8% |

E.1.2. Premise Weighted Results

E.1.2.1. Details

Table E-8 Heating Fuel Types (Premise)

| Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------|---------|------------|----------------------------------|----------------------------------|
| Have Heating Equipment | 96% | 27 | 91% | 101% |
| Electric | 12% | 26 | 3% | 20% |
| Natural Gas | 15% | 26 | 6% | 25% |
| Fuel Oil | 42% | 26 | 29% | 55% |
| LPG | 35% | 26 | 22% | 47% |
| Not Electric or Natural Gas | 12% | 26 | 3% | 20% |
| Other | 12% | 26 | 3% | 20% |
| Unknown | 8% | 26 | 1% | 15% |



Table E-9
Percent of Heating Units of Fuel Type (Premise)

| Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------|---------|------------|----------------------------------|----------------------------------|
| Electric | 21% | 26 | 2% | 40% |
| Natural Gas | 20% | 26 | 6% | 33% |
| Fuel Oil | 8% | 26 | 4% | 13% |
| LPG | 28% | 26 | 12% | 43% |
| Not Electric or Natural Gas | 13% | 26 | -1% | 27% |
| Other | 5% | 26 | 0% | 10% |
| Unknown | 6% | 26 | 2% | 10% |

Table E-10
Heating Equipment Types (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 69% | 26 | 57% | 81% |
| Furnace | 31% | 26 | 19% | 43% |
| Electric Resistance | 8% | 26 | 1% | 15% |
| Unit Heater | 8% | 26 | 1% | 15% |
| Cabinet Unit Heater | 4% | 26 | -1% | 9% |
| Heat Pump | 4% | 26 | -1% | 9% |
| Other | 8% | 26 | 1% | 15% |
| Unknown | 8% | 26 | 1% | 15% |

Table E-11
Percent of Heating Units by Equipment Type (Premise)

| : ordere or reducing crists | | | | | | |
|-----------------------------|---------|------------|----------------------------------|----------------------------------|--|--|
| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
| Boiler | 25% | 26 | 14% | 35% | | |
| Furnace | 36% | 26 | 17% | 54% | | |
| Electric Resistance | 2% | 26 | 0% | 5% | | |
| Unit Heater | 10% | 26 | -2% | 22% | | |
| Cabinet Unit Heater | 2% | 26 | 0% | 4% | | |
| Heat Pump | 23% | 26 | -1% | 47% | | |
| Other | 1% | 26 | 0% | 2% | | |
| Unknown | 1% | 26 | 0% | 2% | | |



Table E-12
Heating Control Types (Premise)

| | , | | Lower 80% | Upper 80% |
|---------------------------|---------|------------|------------|------------|
| Thermostat Control | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| Programmable Thermostat | 26% | 26 | 13% | 39% |
| Manual Thermostat | 19% | 26 | 3% | 34% |
| EMS | 43% | 26 | 19% | 67% |
| Multiple Zones | 0% | 26 | 0% | 0% |
| Outdoor Temperature Reset | 1% | 26 | 0% | 3% |
| Other | 0% | 26 | 0% | 0% |
| Unknown | 11% | 26 | 3% | 19% |

Table E-13
Capacity of Heating Equipment (Premise)

| Capacity (kbtu / hr) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Mean | 130.5 | 22 | 69.0 | 192.0 |
| 250 or less | 61% | 26 | 44% | 79% |
| 250 - 500 | 7% | 26 | 3% | 10% |
| 500 - 1,000 | 3% | 26 | 1% | 5% |
| Larger than 1,000 | 1% | 26 | 0% | 1% |
| Unknown | 29% | 26 | 13% | 45% |

Table E-14
Efficiency of Heating Equipment (Premise)

| Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------|---------|------------|-----|----------------------------------|
| Mean | 0.9 | 21 | 0.8 | 0.9 |
| Unknown | 54% | 26 | 36% | 72% |



E.1.2.2. Energy Efficiency Opportunities

Table E-15
Heating Energy Efficiency Opportunities (Premise)

| neating Energy Efficiency Opportunities (Fremise) | | | | | |
|---------------------------------------------------|---------|------------|------------|------------|--|
| | | | Lower 80% | Upper 80% | |
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence | |
| | | | Limit | Limit | |
| Economizer | 12% | 26 | 3% | 20% | |
| Automatic Setback Thermostat | 12% | 26 | 3% | 20% | |
| Install VFD on Pump Motors | 15% | 26 | 6% | 25% | |
| ECM | 23% | 26 | 12% | 34% | |
| Install NEMA Premium Motors | 19% | 26 | 9% | 30% | |
| Outdoor Reset | 15% | 26 | 6% | 25% | |
| Outdoor Cut-off | 8% | 26 | 1% | 15% | |
| Modulating Boiler | 12% | 26 | 3% | 20% | |
| Duct Sealing/Insulation | 0% | 26 | 0% | 0% | |
| Pipe Insulation | 4% | 26 | -1% | 9% | |
| Refrigerant Charge | 0% | 26 | 0% | 0% | |
| Replace Steam Traps | 0% | 26 | 0% | 0% | |
| Replace Steam Vents | 0% | 26 | 0% | 0% | |
| Balance System | 4% | 26 | -1% | 9% | |
| Other HVAC Controls | 12% | 26 | 3% | 20% | |
| Other O & M | 8% | 26 | 1% | 15% | |
| Other EE Op | 8% | 26 | 1% | 15% | |

E.2. Electric Heating

E.2.1. Conditioned Square Foot Weighted Results

E.2.1.1. Details

Table E-16
Percent of Electric Heating Units Equipment Types (Conditioned Square Foot)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 0% | 3 | 0% | 0% |
| Furnace | 0% | 3 | 0% | 0% |
| Electric Resistance | 15% | 3 | -8% | 38% |
| Unit Heater | 0% | 3 | 0% | 0% |
| Cabinet Unit Heater | 0% | 3 | 0% | 0% |
| Heat Pump | 85% | 3 | 62% | 108% |
| Other | 0% | 3 | 0% | 0% |



Table E-17
Electric Heating Control Types (Conditioned Square Foot)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 14% | 3 | -8% | 36% |
| Manual Thermostat | 0% | 3 | 0% | 0% |
| EMS | 86% | 3 | 64% | 108% |
| Multiple Zones | 0% | 3 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table E-18
Electric Heating Efficiency of Equipment (Conditioned Square Foot)

| Efficiency | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------|---------|------------|----------------------------------|----------------------------------|
| Mean | 9% | 1 | 9% | 9% |
| Unknown | 86% | 3 | 64% | 108% |

E.2.1.2. Energy Efficiency Opportunities

Table E-19
Electric Heating Energy Efficiency Opportunities (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 33% | 3 | -5% | 71% |
| Automatic Setback Thermostat | 87% | 3 | 67% | 106% |
| Install VFD on Pump Motors | 0% | 3 | 0% | 0% |
| ECM | 46% | 3 | 4% | 88% |
| Install NEMA Premium Motors | 33% | 3 | -5% | 71% |
| Outdoor Reset | 0% | 3 | 0% | 0% |
| Outdoor Cut-off | 0% | 3 | 0% | 0% |
| Modulating Boiler | 0% | 3 | 0% | 0% |
| Duct Sealing/Insulation | 0% | 3 | 0% | 0% |
| Pipe Insulation | 0% | 3 | 0% | 0% |
| Refrigerant Charge | 0% | 3 | 0% | 0% |
| Replace Steam Traps | 0% | 3 | 0% | 0% |
| Replace Steam Vents | 0% | 3 | 0% | 0% |
| Balance System | 0% | 3 | 0% | 0% |
| Other HVAC Controls | 33% | 3 | -5% | 71% |
| Other O & M | 0% | 3 | 0% | 0% |
| Other EE Op | 0% | 3 | 0% | 0% |



E.2.2. Premise Weighted Results

E.2.2.1. Details

Table E-20
Percent of Electric Heating Units Equipment Types (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 0% | 3 | 0% | 0% |
| Furnace | 0% | 3 | 0% | 0% |
| Electric Resistance | 11% | 3 | -6% | 29% |
| Unit Heater | 0% | 3 | 0% | 0% |
| Cabinet Unit Heater | 0% | 3 | 0% | 0% |
| Heat Pump | 89% | 3 | 71% | 106% |
| Other | 0% | 3 | 0% | 0% |

Table E-21
Electric Heating Control Types (Premise)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 9% | 3 | -6% | 23% |
| Manual Thermostat | 0% | 3 | 0% | 0% |
| EMS | 91% | 3 | 77% | 106% |
| Multiple Zones | 0% | 3 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 3 | 0% | 0% |
| Other | 0% | 3 | 0% | 0% |
| Unknown | 0% | 3 | 0% | 0% |

Table E-22
Electric Heating Capacity of Equipment (Premise)

| Capacity (kbtu / hr) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
|------------------------|---------|------------|----------------------------------|----------------------------------|--|--|
| Mean | 25.4 | 2 | 23.9 | 27.0 | | |
| 250 or less | 97% | 3 | 92% | 102% | | |
| 250 - 500 | 0% | 3 | 0% | 0% | | |
| 500 - 1,000 | 0% | 3 | 0% | 0% | | |
| Larger than 1,000 | 0% | 3 | 0% | 0% | | |
| Unknown | 3% | 3 | -2% | 8% | | |



Table E-23
Electric Heating Efficiency of Equipment (Premise)

| Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------|---------|------------|-----|----------------------------------|
| Mean | 9% | 1 | 9% | 9% |
| Unknown | 91% | 3 | 77% | 106% |

E.2.2.2. Energy Efficiency Opportunities

Table E-24
Electric Heating Energy Efficiency Opportunities (Premise)

| Electric Heating Energy Efficiency Opportunities (Premise) | | | | | | | |
|------------------------------------------------------------|---------|------------|-------------------------|-------------------------|--|--|--|
| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence | | | |
| | | | Limit | Limit | | | |
| Economizer | 33% | 3 | -3% | 70% | | | |
| Automatic Setback Thermostat | 67% | 3 | 30% | 103% | | | |
| Install VFD on Pump Motors | 0% | 3 | 0% | 0% | | | |
| ECM | 67% | 3 | 30% | 103% | | | |
| Install NEMA Premium Motors | 33% | 3 | -3% | 70% | | | |
| Outdoor Reset | 0% | 3 | 0% | 0% | | | |
| Outdoor Cut-off | 0% | 3 | 0% | 0% | | | |
| Modulating Boiler | 0% | 3 | 0% | 0% | | | |
| Duct Sealing/Insulation | 0% | 3 | 0% | 0% | | | |
| Pipe Insulation | 0% | 3 | 0% | 0% | | | |
| Refrigerant Charge | 0% | 3 | 0% | 0% | | | |
| Replace Steam Traps | 0% | 3 | 0% | 0% | | | |
| Replace Steam Vents | 0% | 3 | 0% | 0% | | | |
| Balance System | 0% | 3 | 0% | 0% | | | |
| Other HVAC Controls | 33% | 3 | -3% | 70% | | | |
| Other O & M | 0% | 3 | 0% | 0% | | | |
| Other EE Op | 0% | 3 | 0% | 0% | | | |



E.3. Natural Gas Heating

E.3.1. Conditioned Square Foot Weighted Results

E.3.1.1. Details

Table E-25

Percent of Natural Gas Heating Units Equipment Types (Conditioned Square Foot)

| ercent of Natural Cas fleating Offics Equipment Types (Conditioned Oquale 1 Oot) | | | | |
|----------------------------------------------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Boiler | 78% | 4 | 52% | 104% |
| Furnace | 22% | 4 | -4% | 48% |
| Electric Resistance | 0% | 4 | 0% | 0% |
| Unit Heater | 0% | 4 | 0% | 0% |
| Cabinet Unit Heater | 0% | 4 | 0% | 0% |
| Heat Pump | 0% | 4 | 0% | 0% |
| Other | 0% | 4 | 0% | 0% |

Table E-26

Natural Gas Heating Control Types (Conditioned Square Foot)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 48% | 4 | 37% | 59% |
| Manual Thermostat | 45% | 4 | 28% | 63% |
| EMS | 3% | 4 | -2% | 7% |
| Multiple Zones | 0% | 4 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 4 | 0% | 0% |
| Other | 0% | 4 | 0% | 0% |
| Unknown | 4% | 4 | -2% | 10% |

Table E-27

Natural Gas Efficiency of Heating Equipment (Conditioned Square Foot)

| | Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|---------|------------|---------|------------|-----|----------------------------------|
| Mean | | 92% | 4 | 91% | 93% |
| Unknown | | 49% | 4 | 36% | 63% |



E.3.1.2. Energy Efficiency Opportunities

Table E-28
Natural Gas Heating Energy Efficiency Opportunities (Conditioned Square Foot)

| Natural Gas Heating Energy Emclericy Opportunities (Conditioned Square Foot) | | | | | | |
|------------------------------------------------------------------------------|---------|------------|------------|------------|--|--|
| | | | Lower 80% | Upper 80% | | |
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence | | |
| | | | Limit | Limit | | |
| Economizer | 7% | 4 | -4% | 19% | | |
| Automatic Setback Thermostat | 69% | 4 | 36% | 102% | | |
| Install VFD on Pump Motors | 0% | 4 | 0% | 0% | | |
| ECM | 0% | 4 | 0% | 0% | | |
| Install NEMA Premium Motors | 0% | 4 | 0% | 0% | | |
| Outdoor Reset | 0% | 4 | 0% | 0% | | |
| Outdoor Cut-off | 0% | 4 | 0% | 0% | | |
| Modulating Boiler | 0% | 4 | 0% | 0% | | |
| Duct Sealing/Insulation | 0% | 4 | 0% | 0% | | |
| Pipe Insulation | 0% | 4 | 0% | 0% | | |
| Refrigerant Charge | 0% | 4 | 0% | 0% | | |
| Replace Steam Traps | 0% | 4 | 0% | 0% | | |
| Replace Steam Vents | 0% | 4 | 0% | 0% | | |
| Balance System | 7% | 4 | -4% | 19% | | |
| Other HVAC Controls | 0% | 4 | 0% | 0% | | |
| Other O & M | 12% | 4 | -6% | 31% | | |
| Other EE Op | 0% | 4 | 0% | 0% | | |

E.3.2. Premise Weighted Results

E.3.2.1. Details

Table E-29
Percent of Natural Gas Heating Units Equipment Types (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 36% | 4 | 4% | 68% |
| Fumace | 64% | 4 | 32% | 96% |
| Electric Resistance | 0% | 4 | 0% | 0% |
| Unit Heater | 0% | 4 | 0% | 0% |
| Cabinet Unit Heater | 0% | 4 | 0% | 0% |
| Heat Pump | 0% | 4 | 0% | 0% |
| Other | 0% | 4 | 0% | 0% |



Table E-30
Natural Gas Heating Control Types (Premise)

| | | | Lower 80% | Upper 80% |
|---------------------------|---------|------------|------------|------------|
| Thermostat Control | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| Programmable Thermostat | 61% | 4 | 45% | 76% |
| Manual Thermostat | 18% | 4 | -2% | 38% |
| EMS | 6% | 4 | -2% | 14% |
| Multiple Zones | 0% | 4 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 4 | 0% | 0% |
| Other | 0% | 4 | 0% | 0% |
| Unknown | 15% | 4 | -1% | 32% |

Table E-31
Natural Gas Capacity of Heating Equipment (Premise)

| Capacity (kbtu / hr) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Mean | 127.4 | 4 | 65.4 | 189.4 |
| 250 or less | 64% | 4 | 32% | 96% |
| 250 - 500 | 18% | 4 | 4% | 32% |
| 500 - 1,000 | 0% | 4 | 0% | 0% |
| Larger than 1,000 | 0% | 4 | 0% | 0% |
| Unknown | 18% | 4 | -2% | 38% |

Table E-32
Natural Gas Efficiency of Equipment (Premise)

| Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------|---------|------------|-----|----------------------------------|
| Mean | 92% | 4 | 89% | 94% |
| Unknown | 33% | 4 | 15% | 51% |



E.3.2.2. Energy Efficiency Opportunities

Table E-33
Natural Gas Heating Energy Efficiency Opportunities (Premise)

| Natural Gas Heating Energy E | 1 | 1 | Lower 80% | Upper 80% |
|-------------------------------|---------|------------|---------------------|---------------------|
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence Limit | Confidence Limit |
| Economizer | 25% | 4 | -4% | 54% |
| Automatic Setback Thermostat | 25% | 4 | -4% | 54% |
| Install VFD on Pump Motors | 0% | 4 | 0% | 0% |
| ECM | 0% | 4 | 0% | 0% |
| Install NEMA Premium Motors | 0% | 4 | 0% | 0% |
| Outdoor Reset | 0% | 4 | 0% | 0% |
| Outdoor Cut-off | 0% | 4 | 0% | 0% |
| Modulating Boiler | 0% | 4 | 0% | 0% |
| Duct Sealing/Insulation | 0% | 4 | 0% | 0% |
| Pipe Insulation | 0% | 4 | 0% | 0% |
| Refrigerant Charge | 0% | 4 | 0% | 0% |
| Replace Steam Traps | 0% | 4 | 0% | 0% |
| Replace Steam Vents | 0% | 4 | 0% | 0% |
| Balance System | 25% | 4 | -4% | 54% |
| Other HVAC Controls | 0% | 4 | 0% | 0% |
| Other O & M | 25% | 4 | -4% | 54% |
| Other EE Op | 0% | 4 | 0% | 0% |

E.4. Fuel Oil Heating

E.4.1. Conditioned Square Foot Weighted Results

E.4.1.1. Details

Table E-34
Percent of Fuel Oil Heating Units Equipment Types (Conditioned Square Foot)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 100% | 11 | 100% | 100% |
| Furnace | 0% | 11 | 0% | 0% |
| Electric Resistance | 0% | 11 | 0% | 0% |
| Unit Heater | 0% | 11 | 0% | 0% |
| Cabinet Unit Heater | 0% | 11 | 0% | 0% |
| Heat Pump | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |



Table E-35
Fuel Oil Heating Control Types (Conditioned Square Foot)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 21% | 11 | 2% | 41% |
| Manual Thermostat | 30% | 11 | 8% | 53% |
| EMS | 38% | 11 | 11% | 64% |
| Multiple Zones | 0% | 11 | 0% | 0% |
| Outdoor Temperature Reset | 11% | 11 | -3% | 25% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |

Table E-36
Fuel Oil Heating Efficiency of Equipment (Conditioned Square Foot)

| Efficiency | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------|---------|------------|----------------------------------|----------------------------------|
| Mean | 82% | 8 | 80% | 85% |
| Unknown | 24% | 11 | 5% | 42% |

E.4.1.2. Energy Efficiency Opportunities

Table E-37
Fuel Oil Heating Energy Efficiency Opportunities (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------|---------|------------|----------------------------------|----------------------------------|
| Economizer | 0% | 11 | 0% | 0% |
| Automatic Setback Thermostat | 0% | 11 | 0% | 0% |
| Install VFD on Pump Motors | 33% | 11 | 10% | 55% |
| ECM | 35% | 11 | 11% | 59% |
| Install NEMA Premium Motors | 33% | 11 | 10% | 55% |
| Outdoor Reset | 35% | 11 | 11% | 59% |
| Outdoor Cut-off | 16% | 11 | 0% | 32% |
| Modulating Boiler | 25% | 11 | 6% | 44% |
| Duct Sealing/Insulation | 0% | 11 | 0% | 0% |
| Pipe Insulation | 12% | 11 | -3% | 28% |
| Refrigerant Charge | 0% | 11 | 0% | 0% |
| Replace Steam Traps | 0% | 11 | 0% | 0% |
| Replace Steam Vents | 0% | 11 | 0% | 0% |
| Balance System | 0% | 11 | 0% | 0% |
| Other HVAC Controls | 0% | 11 | 0% | 0% |
| Other O & M | 0% | 11 | 0% | 0% |
| Other EE Op | 0% | 11 | 0% | 0% |



E.4.2. Premise Weighted Results

E.4.2.1. Details

Table E-38
Percent of Fuel Oil Heating Units Equipment Types (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 100% | 11 | 100% | 100% |
| Furnace | 0% | 11 | 0% | 0% |
| Electric Resistance | 0% | 11 | 0% | 0% |
| Unit Heater | 0% | 11 | 0% | 0% |
| Cabinet Unit Heater | 0% | 11 | 0% | 0% |
| Heat Pump | 0% | 11 | 0% | 0% |
| Other | 0% | 11 | 0% | 0% |

Table E-39
Fuel Oil Heating Control Types (Premise)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 14% | 11 | 1% | 27% |
| Manual Thermostat | 43% | 11 | 22% | 64% |
| EMS | 29% | 11 | 9% | 48% |
| Multiple Zones | 0% | 11 | 0% | 0% |
| Outdoor Temperature Reset | 14% | 11 | -3% | 32% |
| Other | 0% | 11 | 0% | 0% |
| Unknown | 0% | 11 | 0% | 0% |

Table E-40
Fuel Oil Heating Capacity of Equipment (Premise)

| ruci on ricating capacity of Equipment (i remise) | | | | | | |
|---------------------------------------------------|---------|------------|----------------------------------|----------------------------------|--|--|
| Capacity (kbtu / hr) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
| Mean | 497.0 | 10 | 336.4 | 657.6 | | |
| 250 or less | 43% | 11 | 22% | 64% | | |
| 250 - 500 | 14% | 11 | 1% | 27% | | |
| 500 - 1,000 | 36% | 11 | 14% | 57% | | |
| Larger than 1,000 | 0% | 11 | 0% | 0% | | |
| Unknown | 7% | 11 | -2% | 17% | | |



Table E-41
Fuel Oil Heating Efficiency of Equipment (Premise)

| Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------|---------|------------|-----|----------------------------------|
| Mean | 84% | 8 | 83% | 86% |
| Unknown | 29% | 11 | 9% | 48% |

E.4.2.2. Energy Efficiency Opportunities

Table E-42
Fuel Oil Heating Energy Efficiency Opportunities (Premise)

| ruel on heating Energy Emclency Opportunities (Fremise) | | | | | | | |
|---------------------------------------------------------|---------|------------|------------|------------|--|--|--|
| | | | Lower 80% | Upper 80% | | | |
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence | | | |
| | | | Limit | Limit | | | |
| Economizer | 0% | 11 | 0% | 0% | | | |
| Automatic Setback Thermostat | 0% | 11 | 0% | 0% | | | |
| Install VFD on Pump Motors | 27% | 11 | 9% | 45% | | | |
| ECM | 27% | 11 | 9% | 45% | | | |
| Install NEMA Premium Motors | 27% | 11 | 9% | 45% | | | |
| Outdoor Reset | 27% | 11 | 9% | 45% | | | |
| Outdoor Cut-off | 18% | 11 | 3% | 34% | | | |
| Modulating Boiler | 27% | 11 | 9% | 45% | | | |
| Duct Sealing/Insulation | 0% | 11 | 0% | 0% | | | |
| Pipe Insulation | 9% | 11 | -3% | 21% | | | |
| Refrigerant Charge | 0% | 11 | 0% | 0% | | | |
| Replace Steam Traps | 0% | 11 | 0% | 0% | | | |
| Replace Steam Vents | 0% | 11 | 0% | 0% | | | |
| Balance System | 0% | 11 | 0% | 0% | | | |
| Other HVAC Controls | 0% | 11 | 0% | 0% | | | |
| Other O & M | 0% | 11 | 0% | 0% | | | |
| Other EE Op | 0% | 11 | 0% | 0% | | | |



E.5. LPG Heating

E.5.1. Conditioned Square Foot Weighted Results

E.5.1.1. Details

Table E-43
Percent of LPG Heating Units Equipment Types (Conditioned Square Foot)

| referred to the difference by the string of the Equipment Types (| | Conditioned Square 1 oot) | | | |
|-------------------------------------------------------------------|-----|---------------------------|----------------------------------|----------------------------------|--|
| Equipment Type | | | Lower 80% Confidence Limit | Upper 80% Confidence Limit | |
| Boiler | 58% | 9 | 28% | 88% | |
| Furnace | 42% | 9 | 12% | 72% | |
| Electric Resistance | 0% | 9 | 0% | 0% | |
| Unit Heater | 0% | 9 | 0% | 0% | |
| Cabinet Unit Heater | 0% | 9 | 0% | 0% | |
| Heat Pump | 0% | 9 | 0% | 0% | |
| Other | 0% | 9 | 0% | 0% | |

Table E-44
LPG Heating Control Types (Conditioned Square Foot)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 44% | 9 | 15% | 73% |
| Manual Thermostat | 9% | 9 | -3% | 21% |
| EMS | 23% | 9 | 1% | 44% |
| Multiple Zones | 0% | 9 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 9 | 0% | 0% |
| Other | 0% | 9 | 0% | 0% |
| Unknown | 24% | 9 | 2% | 46% |

Table E-45
LPG Heating Efficiency of Equipment (Conditioned Square Foot)

| 21 o mouning Emolonoy of Equipment (Containone Equato 1 Cot) | | | | | | |
|--------------------------------------------------------------|---------|------------|------------|------------|--|--|
| | | | Lower 80% | Upper 80% | | |
| Efficiency | Percent | # of Cases | Confidence | Confidence | | |
| | | | Limit | Limit | | |
| Mean | 90% | 8 | 89% | 92% | | |
| Unknown | 24% | 9 | 2% | 46% | | |



E.5.1.2. Energy Efficiency Opportunities

Table E-46
LPG Heating Energy Efficiency Opportunities (Conditioned Square Foot)

| LFG Heating Energy Enricency Opportunities (Conditioned Square Foot) | | | | | |
|----------------------------------------------------------------------|---------|------------|------------|------------|--|
| · | | | Lower 80% | Upper 80% | |
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence | |
| | | | Limit | Limit | |
| Economizer | 13% | 9 | -4% | 31% | |
| Automatic Setback Thermostat | 0% | 9 | 0% | 0% | |
| Install VFD on Pump Motors | 38% | 9 | 5% | 72% | |
| ECM | 15% | 9 | -2% | 33% | |
| Install NEMA Premium Motors | 38% | 9 | 5% | 72% | |
| Outdoor Reset | 2% | 9 | -1% | 5% | |
| Outdoor Cut-off | 2% | 9 | -1% | 5% | |
| Modulating Boiler | 2% | 9 | -1% | 5% | |
| Duct Sealing/Insulation | 0% | 9 | 0% | 0% | |
| Pipe Insulation | 0% | 9 | 0% | 0% | |
| Refrigerant Charge | 0% | 9 | 0% | 0% | |
| Replace Steam Traps | 0% | 9 | 0% | 0% | |
| Replace Steam Vents | 0% | 9 | 0% | 0% | |
| Balance System | 0% | 9 | 0% | 0% | |
| Other HVAC Controls | 6% | 9 | -2% | 15% | |
| Other O & M | 0% | 9 | 0% | 0% | |
| Other EE Op | 6% | 9 | -2% | 15% | |
| | | | | | |

E.5.2. Premise Weighted Results

E.5.2.1. Details

Table E-47
Percent of LPG Heating Units Equipment Types (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------|---------|------------|----------------------------------|----------------------------------|
| Boiler | 28% | 9 | 9% | 48% |
| Fumace | 72% | 9 | 52% | 91% |
| Electric Resistance | 0% | 9 | 0% | 0% |
| Unit Heater | 0% | 9 | 0% | 0% |
| Cabinet Unit Heater | 0% | 9 | 0% | 0% |
| Heat Pump | 0% | 9 | 0% | 0% |
| Other | 0% | 9 | 0% | 0% |



Table E-48
LPG Heating Heating Control Types (Premise)

| Thermostat Control | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------|---------|------------|----------------------------------|----------------------------------|
| Programmable Thermostat | 22% | 9 | 5% | 38% |
| Manual Thermostat | 41% | 9 | 6% | 76% |
| EMS | 13% | 9 | 0% | 27% |
| Multiple Zones | 0% | 9 | 0% | 0% |
| Outdoor Temperature Reset | 0% | 9 | 0% | 0% |
| Other | 0% | 9 | 0% | 0% |
| Unknown | 24% | 9 | 3% | 45% |

Table E-49
LPG Heating Capacity of Equipment (Premise)

| Capacity (kbtu / hr) | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------|---------|------------|----------------------------------|----------------------------------|
| Mean | 87.5 | 8 | 24.5 | 150.6 |
| 250 or less | 72% | 9 | 52% | 91% |
| 250 - 500 | 7% | 9 | -3% | 16% |
| 500 - 1,000 | 0% | 9 | 0% | 0% |
| Larger than 1,000 | 0% | 9 | 0% | 0% |
| Unknown | 22% | 9 | 4% | 39% |

Table E-50
LPG Heating Efficiency of Equipment (Premise)

| Efficiency | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------|---------|------------|-----|----------------------------------|
| Mean | 91% | 8 | 89% | 92% |
| Unknown | 24% | 9 | 3% | 45% |



E.5.2.2. Energy Efficiency Opportunities

Table E-51
LPG Heating Energy Efficiency Opportunities (Premise)

| Lower 80% Upper 80 | | | | | | |
|-------------------------------|---------|------------|------------|------------|--|--|
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence | | |
| | | | Limit | Limit | | |
| Economizer | 11% | 9 | -3% | 25% | | |
| Automatic Setback Thermostat | 0% | 9 | 0% | 0% | | |
| Install VFD on Pump Motors | 22% | 9 | 4% | 41% | | |
| ECM | 22% | 9 | 4% | 41% | | |
| Install NEMA Premium Motors | 22% | 9 | 4% | 41% | | |
| Outdoor Reset | 11% | 9 | -3% | 25% | | |
| Outdoor Cut-off | 11% | 9 | -3% | 25% | | |
| Modulating Boiler | 11% | 9 | -3% | 25% | | |
| Duct Sealing/Insulation | 0% | 9 | 0% | 0% | | |
| Pipe Insulation | 0% | 9 | 0% | 0% | | |
| Refrigerant Charge | 0% | 9 | 0% | 0% | | |
| Replace Steam Traps | 0% | 9 | 0% | 0% | | |
| Replace Steam Vents | 0% | 9 | 0% | 0% | | |
| Balance System | 0% | 9 | 0% | 0% | | |
| Other HVAC Controls | 11% | 9 | -3% | 25% | | |
| Other O & M | 0% | 9 | 0% | 0% | | |
| Other EE Op | 11% | 9 | -3% | 25% | | |

E.6. Boiler Energy Efficiency Opportunities

E.6.1. Conditioned Square Foot Weighted Results

Table E-52
Boiler Energy Efficiency Opportunities (Conditioned Square Foot)

| | iono y opportamino (oonanonoa odaaro root) | | | | |
|-------------------------------|--------------------------------------------|------------|-------------------------|-------------------------|--|
| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence | |
| | | | Limit | Limit | |
| VFD on Pump Motors | 31% | 18 | 8% | 53% | |
| ECM | 12% | 18 | 1% | 23% | |
| NEMA Premium Motors | 31% | 18 | 8% | 53% | |
| Outdoor Reset | 15% | 18 | 3% | 26% | |
| Outdoor Cut off | 5% | 18 | -1% | 11% | |
| Modulating Boiler | 8% | 18 | 1% | 16% | |
| Duct Sealing / Insulation | 0% | 18 | 0% | 0% | |
| Pipe Insulation | 4% | 18 | -2% | 10% | |
| Refrigerant Charge | 0% | 18 | 0% | 0% | |
| Replace Steam Traps | 0% | 18 | 0% | 0% | |
| Replace Steam Vents | 0% | 18 | 0% | 0% | |
| Balance System | 0% | 18 | 0% | 0% | |
| Other O & M | 7% | 18 | 0% | 13% | |
| Other Opportunities | 3% | 18 | -1% | 6% | |



E.6.2. Premise Weighted Results

Table E-53
Boiler Energy Efficiency Opportunities (Premise)

| | nergy Emolericy Opportunities (Fremise) | | | | | |
|-------------------------------|-----------------------------------------|----------------|------------|------------|--|--|
| F | D | " - 5 O | Lower 80% | Upper 80% | | |
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence | | |
| | | | Limit | Limit | | |
| VFD on Pump Motors | 22% | 18 | 9% | 35% | | |
| ECM | 17% | 18 | 5% | 28% | | |
| NEMA Premium Motors | 22% | 18 | 9% | 35% | | |
| Outdoor Reset | 22% | 18 | 9% | 35% | | |
| Outdoor Cut off | 11% | 18 | 1% | 21% | | |
| Modulating Boiler | 17% | 18 | 5% | 28% | | |
| Duct Sealing / Insulation | 0% | 18 | 0% | 0% | | |
| Pipe Insulation | 6% | 18 | -2% | 13% | | |
| Refrigerant Charge | 0% | 18 | 0% | 0% | | |
| Replace Steam Traps | 0% | 18 | 0% | 0% | | |
| Replace Steam Vents | 0% | 18 | 0% | 0% | | |
| Balance System | 0% | 18 | 0% | 0% | | |
| Other O & M | 11% | 18 | 1% | 21% | | |
| Other Opportunities | 6% | 18 | -2% | 13% | | |

E.7. Furnace Energy Efficiency Opportunities

E.7.1. Conditioned Square Foot Weighted Results

Table E-54
Furnace Energy Efficiency Opportunities (Conditioned Square Foot)

| Turnade Energy Emoience | | 1 | Lower 80% | Upper 80% |
|-------------------------------|---------|------------|------------|------------|
| Energy Efficiency Opportunity | Percent | # of Cases | Confidence | Confidence |
| | | | Limit | Limit |
| VFD on Pump Motors | 5% | 5 | -2% | 13% |
| ECM | 39% | 5 | 5% | 74% |
| NEMA Premium Motors | 5% | 5 | -2% | 13% |
| Outdoor Reset | 39% | 5 | 5% | 74% |
| Outdoor Cut off | 5% | 5 | -2% | 13% |
| Modulating Boiler | 5% | 5 | -2% | 13% |
| Duct Sealing / Insulation | 0% | 5 | 0% | 0% |
| Pipe Insulation | 0% | 5 | 0% | 0% |
| Refrigerant Charge | 0% | 5 | 0% | 0% |
| Replace Steam Traps | 0% | 5 | 0% | 0% |
| Replace Steam Vents | 0% | 5 | 0% | 0% |
| Balance System | 12% | 5 | -4% | 28% |
| Other O & M | 0% | 5 | 0% | 0% |
| Other Opportunities | 0% | 5 | 0% | 0% |



E.7.2. Premise Weighted Results

Table E-55
Furnace Energy Efficiency Opportunities (Premise)

| 1 4111455 =115197 | | remes (Frances) | | | |
|-------------------------------|---------|-----------------|-------------------------|-------------------------|--|
| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence | Upper 80% Confidence | |
| | | | Limit | Limit | |
| VFD on Pump Motors | 20% | 5 | -4% | 44% | |
| ECM | 40% | 5 | 11% | 69% | |
| NEMA Premium Motors | 20% | 5 | -4% | 44% | |
| Outdoor Reset | 40% | 5 | 11% | 69% | |
| Outdoor Cut off | 20% | 5 | -4% | 44% | |
| Modulating Boiler | 20% | 5 | -4% | 44% | |
| Duct Sealing / Insulation | 0% | 5 | 0% | 0% | |
| Pipe Insulation | 0% | 5 | 0% | 0% | |
| Refrigerant Charge | 0% | 5 | 0% | 0% | |
| Replace Steam Traps | 0% | 5 | 0% | 0% | |
| Replace Steam Vents | 0% | 5 | 0% | 0% | |
| Balance System | 20% | 5 | -4% | 44% | |
| Other O & M | 0% | 5 | 0% | 0% | |
| Other Opportunities | 0% | 5 | 0% | 0% | |



Appendix F: Domestic Hot Water Results

F.1.Overall Results

Table F-1
Overall DHW Fuel Type (Premise)

| Water Heater Fuel Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------|---------|------------|----------------------------------|----------------------------------|
| Premises with Water Heater | 88.9% | 27 | 80.8% | 97.0% |
| Electric | 17.2% | 24 | 8.3% | 26.2% |
| Natural Gas | 13.8% | 24 | 3.4% | 24.2% |
| Fuel Oil | 20.7% | 24 | 10.2% | 31.2% |
| LPG | 34.5% | 24 | 20.6% | 48.3% |
| Steam | 0.0% | 24 | 0.0% | 0.0% |
| Heat Recovery | 3.5% | 24 | -1.0% | 7.9% |
| Solar | 0.0% | 24 | 0.0% | 0.0% |
| Other Fuel | 3.5% | 24 | -1.1% | 8.0% |
| Unknown Fuel | 6.9% | 24 | 0.7% | 13.0% |

Table F-2
Overall DHW Type (Premise)

| Water Heater Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Self-Contained WH Tank | 34.5% | 24 | 22.3% | 46.7% |
| Space Heating Boiler w/ Separate Water Tank | 55.2% | 24 | 41.5% | 68.8% |
| Heat Pump Water Heater | 0.0% | 24 | 0.0% | 0.0% |
| Instantaneous (Tankless) | 10.3% | 24 | 2.9% | 17.8% |
| HW Generator with Separate Tank | 0.0% | 24 | 0.0% | 0.0% |
| Side Arm Heater | 0.0% | 24 | 0.0% | 0.0% |
| Other | 0.0% | 24 | 0.0% | 0.0% |
| Unknown | 0.0% | 24 | 0.0% | 0.0% |

Table F-3
Overall DHW Tank Capacity (Premise)

| Tank Capacity | Ratio | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|-------|------------|----------------------------------|----------------------------------|
| Units Per Premise | 1.2 | 24 | 1.1 | 1.3 |
| Average Tank Capacity Per Premise | 87.2 | 19 | 68.9 | 105.5 |
| Average Tank Capacity Per Unit | 69.0 | 19 | 58.1 | 80.0 |
| Percent Tankless Units | 11.5% | 21 | 3.3% | 19.8% |
| <= 30 gallons | 3.5% | 24 | -1.1% | 8.0% |
| 31 - 50 gallons | 20.7% | 24 | 9.0% | 32.3% |
| 51-100 gallons | 37.9% | 24 | 24.9% | 51.0% |
| 101+ gallons | 17.2% | 24 | 5.0% | 29.5% |
| Unknown | 10.3% | 24 | 2.6% | 18.1% |



Table F-4
Overall DHW EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Install Timers | 37.5% | 24 | 24.3% | 50.7% |
| Install Pipe Insulation | 16.7% | 24 | 6.5% | 26.9% |
| Install Supplemental Tank Insulation | 16.7% | 24 | 6.5% | 26.9% |
| Repair Leaks | 0.0% | 24 | 0.0% | 0.0% |
| Other Operations and Maintenance | 0.0% | 24 | 0.0% | 0.0% |
| Other Opportunities | 4.2% | 24 | -1.3% | 9.6% |

F.2.Electric DHW Results

Table F-5
Electric DHW Type (Premise)

| Water Heater Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Self-Contained WH Tank | 80.0% | 5 | 56.0% | 104.0% |
| Space Heating Boiler w/ Separate Water Tank | 0.0% | 5 | 0.0% | 0.0% |
| Heat Pump Water Heater | 0.0% | 5 | 0.0% | 0.0% |
| Instantaneous (Tankless) | 20.0% | 5 | -4.0% | 44.0% |
| HW Generator with Separate Tank | 0.0% | 5 | 0.0% | 0.0% |
| Side Arm Heater | 0.0% | 5 | 0.0% | 0.0% |
| Other | 0.0% | 5 | 0.0% | 0.0% |
| Unknown | 0.0% | 5 | 0.0% | 0.0% |

Table F-6
Electric DHW Tank Capacity (Premise)

| Tank Capacity | Ratio | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|-------|------------|----------------------------------|----------------------------------|
| Units Per Premise | 1.0 | 5 | 1.0 | 1.0 |
| Average Tank Capacity Per Premise | 13.2 | 19 | 4.9 | 21.4 |
| Average Tank Capacity Per Unit | 62.5 | 4 | 50.5 | 74.5 |
| Percent Tankless Units | 20.0% | 5 | -4.0% | 44.0% |
| <= 30 gallons | 0.0% | 5 | 0.0% | 0.0% |
| 31 - 50 gallons | 40.0% | 5 | 10.6% | 69.4% |
| 51-100 gallons | 40.0% | 5 | 10.6% | 69.4% |
| 101+ gallons | 0.0% | 5 | 0.0% | 0.0% |
| Unknown | 0.0% | 5 | 0.0% | 0.0% |



Table F-7
Electric DHW Details (Premise)

| Detail | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------|---------|------------|----------------------------------|----------------------------------|
| Average Size (kW) | 3.8 | 5 | 3.1 | 4.5 |
| Unknown Size (kW) | 0.0% | 5 | 0.0% | 0.0% |
| Controlled By a Timer | 20.0% | 5 | -4.0% | 44.0% |
| Controlled by Utility | 0.0% | 5 | 0.0% | 0.0% |
| On Time of Use Rate | 0.0% | 4 | 0.0% | 0.0% |

Table F-8
Electric DHW EE Ops (Premise)

| 2.001.10 2.111 | 0 0 0 (: : 0: | | | |
|--------------------------------------|---------------|------------|----------------------------------|----------------------------------|
| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
| Install Timers | 40.0% | 5 | 10.6% | 69.4% |
| Install Pipe Insulation | 20.0% | 5 | -4.0% | 44.0% |
| Install Supplemental Tank Insulation | 20.0% | 5 | -4.0% | 44.0% |
| Repair Leaks | 0.0% | 5 | 0.0% | 0.0% |
| Other Operations and Maintenance | 0.0% | 5 | 0.0% | 0.0% |
| Other Opportunities | 0.0% | 5 | 0.0% | 0.0% |

F.3. Natural Gas DHW Results

Table F-9
Natural Gas DHW Type (Premise)

| titude and a state of the state | | | | | | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|------------|----------------------------------|----------------------------------|--|--|
| Water Heater Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit | | |
| Self-Contained WH Tank | 50.0% | 3 | 9.0% | 91.0% | | |
| Space Heating Boiler w/ Separate Water Tank | 50.0% | 3 | 9.0% | 91.0% | | |
| Heat Pump Water Heater | 0.0% | 3 | 0.0% | 0.0% | | |
| Instantaneous (Tankless) | 0.0% | 3 | 0.0% | 0.0% | | |
| HW Generator with Separate Tank | 0.0% | 3 | 0.0% | 0.0% | | |
| Side Arm Heater | 0.0% | 3 | 0.0% | 0.0% | | |
| Other | 0.0% | 3 | 0.0% | 0.0% | | |
| Unknown | 0.0% | 3 | 0.0% | 0.0% | | |



Table F-10
Natural Gas DHW Tank Capacity (Premise)

| Tank Capacity | Ratio | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|-------|------------|----------------------------------|----------------------------------|
| Units Per Premise | 1.3 | 3 | 1.0 | 1.7 |
| Average Tank Capacity Per Premise | 18.7 | 19 | 1.8 | 35.7 |
| Average Tank Capacity Per Unit | 89.0 | 3 | 62.8 | 115.2 |
| Percent Tankless Units | 0.0% | 3 | 0.0% | 0.0% |
| <= 30 gallons | 0.0% | 3 | 0.0% | 0.0% |
| 31 - 50 gallons | 25.0% | 3 | -6.3% | 56.3% |
| 51-100 gallons | 25.0% | 3 | -6.3% | 56.3% |
| 101+ gallons | 50.0% | 3 | 9.0% | 91.0% |
| Unknown | 0.0% | 3 | 0.0% | 0.0% |

Table F-11
Natural Gas DHW EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Install Timers | 33.3% | 3 | -3.1% | 69.8% |
| Install Pipe Insulation | 0.0% | 3 | 0.0% | 0.0% |
| Install Supplemental Tank Insulation | 33.3% | 3 | -3.1% | 69.8% |
| Repair Leaks | 0.0% | 3 | 0.0% | 0.0% |
| Other Operations and Maintenance | 0.0% | 3 | 0.0% | 0.0% |
| Other Opportunities | 0.0% | 3 | 0.0% | 0.0% |

F.4. Fuel Oil DHW Results

Table F-12 Fuel Oil DHW Type (Premise)

| Water Heater Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Self-Contained WH Tank | 0.0% | 6 | 0.0% | 0.0% |
| Space Heating Boiler w/ Separate Water Tank | 100.0% | 6 | 100.0% | 100.0% |
| Heat Pump Water Heater | 0.0% | 6 | 0.0% | 0.0% |
| Instantaneous (Tankless) | 0.0% | 6 | 0.0% | 0.0% |
| HW Generator with Separate Tank | 0.0% | 6 | 0.0% | 0.0% |
| Side Arm Heater | 0.0% | 6 | 0.0% | 0.0% |
| Other | 0.0% | 6 | 0.0% | 0.0% |
| Unknown | 0.0% | 6 | 0.0% | 0.0% |



Table F-13
Fuel Oil DHW Tank Capacity (Premise)

| Tank Capacity | Ratio | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|-------|------------|----------------------------------|----------------------------------|
| Units Per Premise | 1.0 | 6 | 1.0 | 1.0 |
| Average Tank Capacity Per Premise | 13.7 | 19 | 6.3 | 21.1 |
| Average Tank Capacity Per Unit | 52.0 | 5 | 43.2 | 60.8 |
| Percent Tankless Units | 0.0% | 5 | 0.0% | 0.0% |
| <= 30 gallons | 16.7% | 6 | -3.7% | 37.1% |
| 31 - 50 gallons | 16.7% | 6 | -3.7% | 37.1% |
| 51-100 gallons | 50.0% | 6 | 22.6% | 77.4% |
| 101+ gallons | 0.0% | 6 | 0.0% | 0.0% |
| Unknown | 16.7% | 6 | -3.7% | 37.1% |

Table F-14
Fuel Oil DHW EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Install Timers | 66.7% | 6 | 40.9% | 92.5% |
| Install Pipe Insulation | 33.3% | 6 | 7.5% | 59.1% |
| Install Supplemental Tank Insulation | 33.3% | 6 | 7.5% | 59.1% |
| Repair Leaks | 0.0% | 6 | 0.0% | 0.0% |
| Other Operations and Maintenance | 0.0% | 6 | 0.0% | 0.0% |
| Other Opportunities | 16.7% | 6 | -3.7% | 37.1% |

F.5.LPG DHW Results

Table F-15 LPG DHW Type (Premise)

| Water Heater Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Self-Contained WH Tank | 20.0% | 8 | 4.4% | 35.6% |
| Space Heating Boiler w/ Separate Water Tank | 60.0% | 8 | 35.1% | 84.9% |
| Heat Pump Water Heater | 0.0% | 8 | 0.0% | 0.0% |
| Instantaneous (Tankless) | 20.0% | 8 | 4.4% | 35.6% |
| HW Generator with Separate Tank | 0.0% | 8 | 0.0% | 0.0% |
| Side Arm Heater | 0.0% | 8 | 0.0% | 0.0% |
| Other | 0.0% | 8 | 0.0% | 0.0% |
| Unknown | 0.0% | 8 | 0.0% | 0.0% |



Table F-16
LPG DHW Tank Capacity (Premise)

| Tank Capacity | Ratio | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|-------|------------|----------------------------------|----------------------------------|
| Units Per Premise | 1.3 | 8 | 1.0 | 1.5 |
| Average Tank Capacity Per Premise | 29.3 | 19 | 11.7 | 46.9 |
| Average Tank Capacity Per Unit | 69.6 | 6 | 47.6 | 91.6 |
| Percent Tankless Units | 22.2% | 7 | 5.2% | 39.3% |
| <= 30 gallons | 0.0% | 8 | 0.0% | 0.0% |
| 31 - 50 gallons | 10.0% | 8 | -3.0% | 23.0% |
| 51-100 gallons | 40.0% | 8 | 19.9% | 60.1% |
| 101+ gallons | 20.0% | 8 | -3.1% | 43.1% |
| Unknown | 10.0% | 8 | -3.0% | 23.0% |

Table F-17 LPG DHW EE Ops (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Install Timers | 25.0% | 8 | 4.5% | 45.5% |
| Install Pipe Insulation | 12.5% | 8 | -3.2% | 28.2% |
| Install Supplemental Tank Insulation | 0.0% | 8 | 0.0% | 0.0% |
| Repair Leaks | 0.0% | 8 | 0.0% | 0.0% |
| Other Operations and Maintenance | 0.0% | 8 | 0.0% | 0.0% |
| Other Opportunities | 0.0% | 8 | 0.0% | 0.0% |



Appendix G: Air Handler Results

G.1. Conditioned Square Foot Weighted Results

Table G-1
Air Handlers and Economizers (Conditioned Square Foot)

| Details | Percent | # of Cases | Lower 80% Confidence Limit | |
|-----------------------------------------------------|---------|------------|----------------------------------|-----|
| Percent of Conditioned Square Feet with Air Handler | 78% | 26 | 66% | 90% |
| Percent of Air Handlers with Economizers | 39% | 12 | 14% | 65% |

Table G-2
Air Handler Percent of Fans with Control Type (Conditioned Square Foot)

| Percent of Fans with Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Discharge Damper | 38% | 15 | 19% | 58% |
| Inlet Vane | 3% | 15 | -1% | 7% |
| VFD | 5% | 15 | 0% | 10% |
| Other | 5% | 15 | -1% | 11% |
| Not Applicable | 13% | 15 | 3% | 23% |
| Unknown | 36% | 15 | 21% | 50% |

Table G-3
Air Handler EE Ops by Building Type (Conditioned Square Foot)

| Energy Efficiency Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------|---------|------------|----------------------------------|----------------------------------|
| VFD on Motors | 48% | 15 | 24% | 71% |
| O & M | 26% | 15 | 3% | 49% |
| Other EE Opportunity | 0% | 15 | 0% | 0% |

G.2. Premise Weighted Results

Table G-4
Air Handlers and Economizers (Premise)

| Details | Percent | # of Cases | | Upper 80% Confidence Limit |
|------------------------------------------|---------|------------|-----|----------------------------------|
| Percent of Premises with Air Handler | 56% | 27 | 43% | 68% |
| Percent of Air Handlers with Economizers | 33% | 12 | 15% | 52% |



Table G-5
Air Handler Percent of Fans with Control Type (Premise)

| Percent of Fans with Control Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------|---------|------------|----------------------------------|----------------------------------|
| Discharge Damper | 22% | 15 | 8% | 37% |
| Inlet Vane | 3% | 15 | -1% | 7% |
| VFD | 7% | 15 | 2% | 13% |
| Other | 1% | 15 | -1% | 4% |
| Not Applicable | 24% | 15 | 7% | 41% |
| Unknown | 42% | 15 | 26% | 58% |

Table G-6
Air Handler EE Ops by Building Type (Premise)

| Energy Efficiency Opportunity | Percent | # of Cases | | Upper 80% Confidence Limit |
|-------------------------------|---------|------------|-----|----------------------------------|
| VFD on Motors | 33% | 15 | 17% | 50% |
| O & M | 13% | 15 | 2% | 25% |
| Other EE Opportunity | 0% | 15 | 0% | 0% |



Appendix H: Cooking Equipment Results

H.1. Square Foot Weighted

Table H-1
Cooking Equipment (Square Foot)

| Cooking Equipment | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|--------------------------------|---------|------------|----------------------------------|----------------------------------|
| Percent with Cooking Equipment | 33% | 27 | 15% | 50% |
| Fryers | 28% | 10 | 5% | 51% |
| Griddle/Grill | 18% | 10 | -2% | 38% |
| Range | 51% | 10 | 20% | 82% |
| Oven-Baking | 5% | 10 | -1% | 10% |
| Oven-General | 84% | 10 | 69% | 98% |
| Steam Kettle | 18% | 10 | -2% | 38% |
| Dishwater Booster Heater | 44% | 10 | 15% | 73% |

Table H-2
Electric Cooking Equipment (Square Foot)

| Electric Cooking Equipment | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------|---------|------------|----------------------------------|----------------------------------|
| Fryers | 35% | 4 | 0% | 69% |
| Griddle/Grill | 0% | 2 | 0% | 0% |
| Range | 37% | 7 | 10% | 64% |
| Oven-Baking | 41% | 2 | -5% | 86% |
| Oven-General | 62% | 6 | 29% | 94% |
| Steam Kettle | 0% | 2 | 0% | 0% |
| Dishwater Booster Heater | 28% | 5 | 0% | 55% |

Table H-3
Cooking EE Options in Place (Square Foot)

| gooking 22 options in Flace (equals 1 oot) | | | | | | | |
|----------------------------------------------|---------|------------|------------|------------|--|--|--|
| | | | Lower 80% | Upper 80% | | | |
| Energy Efficient Equipment in Place | Percent | # of Cases | Confidence | Confidence | | | |
| | | | Limit | Limit | | | |
| Infrared Fryers | 0% | 10 | 0% | 0% | | | |
| Infrared Stovetops | 0% | 10 | 0% | 0% | | | |
| Convection Ovens | 25% | 10 | 3% | 47% | | | |
| Smart Range Hoods (Melink-sensor Controlled) | 0% | 10 | 0% | 0% | | | |
| Engineered Pre-rinse Nozzles | 0% | 10 | 0% | 0% | | | |



Table H-4
Cooking EE Opportunities (Square Foot)

| Energy Efficient Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Infrared Fryers | 0% | 4 | 0% | 0% |
| Infrared Stovetops | 0% | 4 | 0% | 0% |
| Convection Ovens | 0% | 4 | 0% | 0% |
| Smart Range Hoods (Melink-sensor Controlled) | 72% | 4 | 44% | 99% |
| Engineered Pre-rinse Nozzles | 0% | 4 | 0% | 0% |

H.2. Premise Weighted

Table H-5
Cooking Equipment (Premise)

| Cooking Equipment | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------|---------|------------|----------------------------------|----------------------------------|
| Premises with Cooking Equipment | 37% | 27 | 25% | 49% |
| Fryers | 40% | 10 | 19% | 61% |
| Griddle/Grill | 20% | 10 | 3% | 37% |
| Range | 70% | 10 | 51% | 89% |
| Oven-Baking | 20% | 10 | 3% | 37% |
| Oven-General | 60% | 10 | 39% | 81% |
| Steam Kettle | 20% | 10 | 3% | 37% |
| Dishwater Booster Heater | 50% | 10 | 29% | 71% |

Table H-6
Electric Cooking Equipment (Premise)

| 21001110 0001111 | | 1 10111100) | Lower 80% | Upper 80% |
|----------------------------|---------|-------------|------------|------------|
| Electric Cooking Equipment | Percent | # of Cases | Confidence | Confidence |
| 5 1 . | | | Limit | Limit |
| Fryers | 50% | 4 | 16% | 84% |
| Griddle/Grill | 0% | 2 | 0% | 0% |
| Range | 57% | 7 | 32% | 82% |
| Oven-Baking | 50% | 2 | 3% | 97% |
| Oven-General | 50% | 6 | 23% | 77% |
| Steam Kettle | 0% | 2 | 0% | 0% |
| Dishwater Booster Heater | 40% | 5 | 11% | 69% |



Table H-7
Cooking EE Options in Place (Premise)

| | | | Lower 80% | Upper 80% | | | |
|----------------------------------------------|---------|------------|------------|------------|--|--|--|
| Energy Efficient Equipment in Place | Percent | # of Cases | Confidence | Confidence | | | |
| | | | Limit | Limit | | | |
| Infrared Fryers | 0% | 10 | 0% | 0% | | | |
| Infrared Stovetops | 0% | 10 | 0% | 0% | | | |
| Convection Ovens | 30% | 10 | 11% | 49% | | | |
| Smart Range Hoods (Melink-sensor Controlled) | 0% | 10 | 0% | 0% | | | |
| Engineered Pre-rinse Nozzles | 0% | 10 | 0% | 0% | | | |

Table H-8
Cooking EE Opportunities (Premise)

| Energy Efficient Opportunity | Percent | # of Cases | Lower 80% Confidence Limit | |
|----------------------------------------------|---------|------------|----------------------------------|-----|
| Infrared Fryers | 0% | 4 | 0% | 0% |
| Infrared Stovetops | 0% | 4 | 0% | 0% |
| Convection Ovens | 0% | 4 | 0% | 0% |
| Smart Range Hoods (Melink-sensor Controlled) | 50% | 4 | 16% | 84% |
| Engineered Pre-rinse Nozzles | 0% | 4 | 0% | 0% |





Appendix I: Miscellaneous Equipment

I.1.Details

Table I-1
Computer Equipment Inventory (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|---------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Total Premises with Desktop Computers | 77.8% | 27 | 67.1% | 88.5% |
| Desktop Computers per Premise | 16.2 | 21 | 6.6 | 25.8 |
| Total Premises with Inkjet Printers | 48.2% | 27 | 35.3% | 61.0% |
| Inkjet Printers per Premise | 2.2 | 13 | 1.6 | 2.8 |
| Total Premises with Laser Printers | 48.2% | 27 | 35.3% | 61.0% |
| Laser Printers per Premise | 3.3 | 13 | 2.4 | 4.2 |
| Total Premises with Servers | 37.0% | 27 | 24.6% | 49.5% |
| Servers per Premise | 1.0 | 10 | 1.0 | 1.0 |

Table I-2
Copier Equipment Inventory (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------|---------|------------|----------------------------------|----------------------------------|
| | | | | |
| Total Premises with Small Copiers | 18.5% | 27 | 8.5% | 28.5% |
| Small Copiers per Premise | 1.8 | 5 | 1.4 | 2.2 |
| Total Premises with Medium Copiers | 33.3% | 27 | 21.2% | 45.5% |
| Medium Copiers per Premise | 1.7 | 9 | 1.0 | 2.4 |
| Total Premises with Large Copiers | 22.2% | 27 | 11.5% | 32.9% |
| Large Copiers per Premise | 1.2 | 6 | 1.0 | 1.4 |
| Total Premises with Fax Machines | 48% | 27 | 35% | 61% |
| Fax Machines per Premise | 1.1 | 13 | 1.0 | 1.2 |



Table I-3
Vending Equipment Inventory (Premise)

| Equipment Type | Percent with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-------------------------------------------------|--------------------------|------------|----------------------------------|----------------------------------|
| Total Premises with Hot Food Vending | 0.0% | 27 | 0.0% | 0.0% |
| Hot Food Vending Machines / Premise | 0.0 | 0 | 0.0 | 0.0 |
| Total Premises with Refrigerated Vending | 18.5% | 27 | 8.5% | 28.5% |
| Refrigerated Vending Machines / Premise | 1.2 | 5 | 1.0 | 1.4 |
| Total Premises with Non-Refrigerated Vending | 11.1% | 27 | 3.0% | 19.2% |
| Non-Refrigerated Vending Machines / Premise | 1.0 | 3 | 1.0 | 1.0 |
| Total Premises with Vending Miser | 0.0% | 27 | 0.0% | 0.0% |
| Vending Miser / Premise | 0.0 | 0 | 0.0 | 0.0 |

Table I-4
Elevator Equipment Inventory (Premise)

| Equipment Type | Percent with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|--------------------------|------------|----------------------------------|----------------------------------|
| Total Premises with Hydraulic Elevator | 33.3% | 27 | 21.2% | 45.5% |
| Hydraulic Elevators per Premise | 1.1 | 9 | 1.0 | 1.3 |
| Total Premises with Cable Elevator | 0.0% | 27 | 0.0% | 0.0% |
| Cable Elevators per Premise | 0.0 | 0 | 0.0 | 0.0 |
| Total Premises with Escalator | 0.0% | 27 | 0.0% | 0.0% |
| Escalators per Premise | 0.0 | 0 | 0.0 | 0.0 |
| Total Premises with Hoist | 3.7% | 27 | -1.2% | 8.6% |
| Hoists per Premise | 1.0 | 1 | 1.0 | 1.0 |



Table I-5
Laundry Equipment Inventory (Premise)

| Equipment Type | Percent | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|----------------------------------------|---------|------------|----------------------------------|----------------------------------|
| Total Premises with Residential Dryer | 14.8% | 27 | 5.7% | 24.0% |
| Residential Dryers per Premise | 1.0 | 4 | 1.0 | 1.0 |
| Total Premises with Residential Washer | 14.8% | 27 | 5.7% | 24.0% |
| Residential Washers per Premise | 1.0 | 4 | 1.0 | 1.0 |
| Total Premises with Commercial Dryer | 7.4% | 27 | 0.7% | 14.2% |
| Commercial Dryers per Premise | 4.0 | 2 | 1.2 | 6.8 |
| Total Premises with Commercial Washer | 7.4% | 27 | 0.7% | 14.2% |
| Commercial Washers per Premise | 4.0 | 2 | 1.2 | 6.8 |

I.2. Energy Efficiency Opportunities

Table I-6
Office Equipmet EE Opportunities (Premise)

| Energy Efficiency Opportunity | Percent with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|-----------------------------------------|--------------------------|------------|----------------------------------|----------------------------------|
| Total Premises with Office Equipment | 77.8% | 27 | 67.1% | 88.5% |
| Premises with No Energy Star | 19.1% | 21 | 7.6% | 30.5% |
| Premises with No Computer Sleep | 0.0% | 21 | 0.0% | 0.0% |
| Premises with No Copier Sleep | 4.8% | 21 | -1.5% | 11.0% |
| Premises with No Hard Shut-off at Night | 47.6% | 21 | 33.0% | 62.2% |

Table I-7
Vending Machine EE Opportunities (Premise)

| Energy Efficiency Opportunity | Percent with Opportunity | # of Cases | Lower 80% Confidence Limit | |
|--------------------------------------|--------------------------|------------|----------------------------------|--------|
| Total Premises with Vending Machines | 18.5% | 27 | 8.5% | 28.5% |
| Premises with No Energy Star | 80.0% | 5 | 56.0% | 104.0% |
| Premises with No Vending Miser | 100.0% | 5 | 100.0% | 100.0% |



Table I-8
Elevator EE Opportunities (Premise)

| Energy Efficiency Opportunity | Percent with Opportunity | # of Cases | Lower 80% Confidence Limit | Upper 80% Confidence Limit |
|------------------------------------------------------|--------------------------|------------|----------------------------------|----------------------------------|
| Total Premises with Elevators | 29.6% | 27 | 17.9% | 41.4% |
| Elevator Premises with No Shutdown Equipment | 75.0% | 8 | 54.5% | 95.5% |
| Elevator Premises without Optimal Cab Positioning | 75.0% | 8 | 54.5% | 95.5% |

Table I-9
Laundry EE Opportunities (Premise)

| Energy Efficiency Opportunity | Percent with Opportunity | # OT 1 3000 | Lower 80% Confidence Limit | |
|---------------------------------------------------|--------------------------|-------------|----------------------------------|-------|
| Total Premises with Laundry Equipment | 25.9% | 27 | 14.6% | 37.2% |
| Laundry Premises with no Energy Star Equipment | 14.3% | 7 | -3.4% | 32.0% |